

FLINDERS REEF, Australia

WMO: 942900

Lat: 17.719S

Lon: 148.448E

Elev: 21

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	68.8	70.0	N/A	N/A	N/A	N/A	N/A	N/A	32.4	71.9	31.1	72.2	20.5	140	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.9	90.0	N/A	86.2	N/A	85.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.2	30.0	28.1	DB	65.4	91.5	5.6	7.1	61.3	96.6	58.1	100.7	54.9	104.7	50.8	109.8	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.1	82.1	82.4	81.2	79.7	77.9	74.7	73.4	73.4	75.0	77.2	79.1	81.3		
	DBStd	3.87	1.64	1.88	1.92	2.68	4.28	1.97	1.73	1.63	1.73	1.69	1.53	1.77		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	10249	994	906	967	891	865	740	725	725	751	842	873	970		
	CDD65	4774	529	486	502	441	400	290	260	260	301	377	423	505		
	CDH74	38896	6078	5766	5600	4292	3144	979	387	289	879	2338	3692	5452		
	CDH80	7370	1679	1812	1332	538	556	1	0	0	6	48	231	1167		
(14) Wind	WSAvg	16.6	14.5	14.1	16.7	19.3	18.7	19.1	19.3	17.4	15.5	15.2	14.7	14.0		
(15) Precipitation	PrecAvg	34.4	6.6	8.1	5.4	2.6	1.7	1.4	0.9	0.8	0.4	0.9	1.5	4.0		
	PrecMax	66.3	14.8	21.0	14.5	9.6	8.6	4.9	4.6	4.8	2.2	6.7	11.3	15.4		
	PrecMin	17.9	0.7	0.9	0.5	0.6	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.6		
	PrecStd	11.6	4.3	5.8	4.2	2.5	1.7	1.3	1.2	1.1	0.4	1.3	2.2	3.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.0	88.5	87.1	102.2	106.8	79.9	78.1	78.4	80.7	82.7	84.6	87.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	86.2	86.5	85.4	83.6	98.4	78.8	77.2	76.9	79.1	81.4	82.9	85.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	85.1	85.5	84.5	82.5	81.3	78.0	76.5	76.1	78.1	80.2	81.9	84.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	84.3	84.7	83.8	81.8	79.9	77.3	75.9	75.5	77.2	79.3	81.3	83.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.5	3.9	3.5	3.2	3.8	2.8	2.7	2.6	2.7	2.8	3.0	3.3		
		MCDBR	4.7	4.5	4.4	5.0	11.6	3.3	2.9	3.2	3.9	4.1	4.1	4.5		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.393	0.392	0.394	0.380	0.366	0.364	0.342	0.352	0.372	0.383	0.388	0.387		
	taud		2.592	2.608	2.581	2.600	2.604	2.593	2.644	2.594	2.513	2.511	2.533	2.577		
	Ebn at Noon		302	299	291	284	277	272	282	289	293	298	301	304		
	Edh at Noon		34	33	32	30	28	27	26	30	34	36	35	34		
(44) All-Sky Solar Radiation	RadAvg		2121	2004	1823	1682	1448	1284	1385	1689	2040	2250	2331	2286		
	RadStd		174	201	144	121	111	104	88	98	70	92	198	208		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page