

FLINDERS REEF, Australia

WMO: 942900

Lat: 17.719S

Lon: 148.448E

Elev: 7

StdP: 101.25

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.5	21.1	N/A	N/A	N/A	N/A	N/A	N/A	14.5	22.2	13.9	22.3	9.2	140	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.1	32.2	N/A	30.1	N/A	29.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.2	0

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
14.4	13.4	12.6	DB	18.5	33.1	3.1	3.9	16.3	35.9	14.5	38.2	12.7	40.4	10.5	43.2	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	27.8	28.0	27.3	26.5	25.5	23.7	23.0	23.0	23.9	25.1	26.2	27.4
	DBStd	2.15	0.91	1.04	1.07	1.49	2.38	1.10	0.96	0.90	0.96	0.94	0.85	0.98
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5694	552	503	537	495	481	411	403	403	417	468	485	539
	CDD18.3	2652	294	270	279	245	222	161	144	144	167	209	235	281
	CDH23.3	21609	3377	3203	3111	2384	1747	544	215	161	488	1299	2051	3029
	CDH26.7	4094	933	1007	740	299	309	1	0	0	3	27	128	648
Wind	WSAvg	7.4	6.5	6.3	7.5	8.6	8.3	8.5	8.6	7.8	6.9	6.8	6.6	6.3
Precipitation	PrecAvg	874	168	207	136	66	44	36	24	21	11	22	37	102
	PrecMax	1684	375	534	369	243	219	125	117	122	57	169	287	391
	PrecMin	455	17	22	12	15	5	6	1	1	0	1	1	14
	PrecStd	294	109	148	107	64	43	32	30	29	11	33	57	97
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.4	30.6	39.0	41.6	26.6	25.6	25.8	27.1	28.2	29.2	30.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	30.1	30.3	29.6	28.6	36.9	26.0	25.1	24.9	26.2	27.5	28.3	29.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	29.5	29.7	29.2	28.1	27.4	25.6	24.7	24.5	25.6	26.8	27.7	29.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	29.1	29.3	28.8	27.7	26.6	25.2	24.4	24.1	25.1	26.3	27.4	28.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.9	2.1	2.0	1.8	2.1	1.6	1.5	1.5	1.5	1.6	1.7	1.8
		MCDBR	2.6	2.5	2.4	2.8	6.4	1.8	1.6	1.8	2.1	2.3	2.3	2.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.393	0.392	0.394	0.380	0.366	0.364	0.342	0.352	0.372	0.383	0.388	0.387	
	taud	2.592	2.608	2.581	2.600	2.604	2.593	2.644	2.594	2.513	2.511	2.533	2.577	
	Ebn at Noon	952	943	918	895	873	856	890	910	925	940	950	957	
	Edh at Noon	106	103	102	94	88	85	83	93	107	112	111	107	
All-Sky Solar Radiation	RadAvg	6.69	6.32	5.75	5.30	4.56	4.05	4.37	5.32	6.43	7.09	7.35	7.21	
	RadStd	0.55	0.63	0.45	0.38	0.35	0.33	0.28	0.31	0.22	0.29	0.62	0.66	

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page