

LUCINDA POINT, Australia

WMO: 942950

Lat: 18.520S

Lon: 146.386E

Elev: 33

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	61.0	62.9	40.6	37.3	68.0	44.7	43.6	68.6	29.0	68.0	26.0	68.7	12.8	240	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.1	87.6	76.9	86.4	77.0	85.5	76.7	80.5	84.2	79.5	83.8	78.6	83.3	10.2	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.3	152.4	83.3	78.2	146.5	83.0	77.2	141.5	82.6	44.2	84.3	43.2	83.8	42.3	83.4	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.3	24.2	21.7	DB	56.6	91.7	5.8	3.1	52.4	93.9	49.0	95.7	45.7	97.4	41.5	99.7	
			WB	49.7	80.7	1.9	1.6	48.4	81.8	47.3	82.8	46.2	83.7	44.8	84.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.5	81.9	82.0	80.9	78.2	74.5	70.7	69.1	70.2	73.6	76.5	79.1	81.5	(6)
	DBStd	5.09	1.85	2.18	1.88	2.23	2.39	3.05	2.64	2.41	2.13	1.93	1.73	1.70	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	8	0	0	0	0	0	3	4	1	0	0	0	0	(9)
	CDD50	9668	990	895	957	847	758	622	593	627	708	823	872	976	(10)
	CDD65	4201	525	475	492	397	293	175	132	163	258	358	422	511	(11)
	CDH74	33308	6011	5446	5185	3216	1101	160	27	93	666	2087	3692	5624	(12)
	CDH80	6610	1771	1678	1170	265	15	0	0	3	37	301	1370		(13)
(14) Wind	WSAvg	12.1	12.5	12.2	12.5	12.6	12.3	12.2	11.2	11.2	11.1	12.3	12.1	12.4	(14)
(15) Precipitation	PrecAvg	85.9	14.1	19.4	15.0	8.8	5.4	2.6	1.7	2.0	1.5	1.8	4.1	8.1	(15)
	PrecMax	139.3	62.2	47.1	41.7	27.0	16.1	11.6	7.8	6.6	8.2	8.1	22.4	32.2	(16)
	PrecMin	37.6	1.0	2.7	2.0	0.5	0.4	0.0	0.0	0.0	0.0	0.0	0.1	0.6	(17)
	PrecStd	22.0	12.6	10.6	9.2	6.1	3.6	2.5	1.4	1.8	1.9	2.1	5.0	7.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	89.6	90.0	87.9	85.5	81.8	78.3	76.3	77.9	80.4	82.5	85.2	87.8		(19)
	0.4% MCWB	75.0	76.8	76.1	76.0	74.1	72.6	68.5	69.3	71.9	71.4	74.5	76.8		(20)
	2% DB	87.2	87.7	86.3	83.5	80.0	76.7	74.6	76.1	79.0	81.0	83.4	85.8		(21)
	2% MCWB	76.8	77.4	76.8	74.3	72.5	71.5	68.2	68.3	71.0	72.2	74.7	77.1		(22)
	5% DB	86.1	86.4	85.0	82.3	79.0	75.7	73.7	75.0	78.0	80.1	82.5	84.8		(23)
	5% MCWB	76.6	77.4	76.1	73.5	71.3	70.1	67.8	67.7	70.1	72.1	74.4	76.3		(24)
	10% DB	85.1	85.5	84.1	81.5	78.1	74.8	72.9	73.9	77.1	79.4	81.7	84.0		(25)
	10% MCWB	76.3	77.2	75.3	73.1	70.6	69.1	67.2	66.9	69.3	71.7	73.8	75.8		(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	80.1	82.2	81.4	77.1	76.0	75.3	72.0	72.3	75.1	76.4	78.1	81.0		(27)
	0.4% MCDB	84.5	84.5	84.5	80.7	79.6	76.0	73.8	75.6	77.6	79.6	82.4	84.0		(28)
	2% WB	79.3	80.9	79.0	75.7	74.7	72.7	70.7	70.8	73.5	75.3	77.0	79.8		(29)
	2% MCDB	84.0	84.5	83.5	80.3	78.7	75.0	73.1	74.4	77.4	79.4	81.6	83.5		(30)
	5% WB	78.6	79.9	78.0	75.1	73.6	71.3	69.7	69.5	72.3	74.0	75.9	78.5		(31)
	5% MCDB	83.6	84.1	82.9	80.0	77.6	74.7	72.7	73.5	76.7	78.8	81.0	83.2		(32)
	10% WB	77.7	79.0	77.2	74.4	72.2	70.1	68.6	68.3	71.4	72.9	75.1	77.3		(33)
	10% MCDB	83.2	83.5	82.3	79.7	76.7	73.6	72.1	72.8	76.1	78.2	80.6	82.8		(34)
(35) Mean Daily Temperature Range	MDBR	5.8	6.1	5.6	5.5	5.8	5.9	6.3	6.2	5.7	4.7	4.6	4.8		(35)
	5% DB MCDBR	7.1	7.3	7.0	6.2	6.8	6.2	6.9	7.3	6.8	5.4	5.3	5.7		(36)
	5% WB MCWBR	3.3	3.9	3.2	2.9	3.3	4.0	3.8	4.2	3.4	3.0	3.0	3.1		(37)
	5% WB MCDBR	6.0	6.5	6.1	5.0	5.3	4.9	4.7	5.9	5.3	4.7	5.0	5.3		(38)
(40) Clear-Sky Solar Irradiance	taub	0.402	0.402	0.391	0.374	0.358	0.348	0.332	0.340	0.370	0.396	0.398	0.408		(40)
	taud	2.541	2.544	2.563	2.596	2.600	2.607	2.640	2.604	2.502	2.456	2.491	2.489		(41)
	Ebn at Noon	299	296	292	285	279	276	285	292	293	294	298	297		(42)
	Edh at Noon	35	35	33	30	28	26	26	29	34	37	37	37		(43)
(44) All-Sky Solar Radiation	RadAvg	1964	1841	1702	1517	1320	1186	1323	1601	1914	2105	2158	2121		(44)
	RadStd	182	223	177	158	123	114	105	127	128	144	204	221		(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page