

LUCINDA POINT, Australia

WMO: 942950

Lat: 18.520S

Lon: 146.386E

Elev: 10

StdP: 101.20

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	17.1	4.8	5.3	20.0	7.0	6.2	20.3	13.0	20.0	11.6	20.4	5.7	240	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.4	30.9	25.0	30.2	25.0	29.7	24.8	26.9	29.0	26.4	28.8	25.9	28.5	4.6	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.8	28.5	25.7	20.9	28.3	25.1	20.2	28.1	85.0	29.1	82.7	28.8	80.4	28.6	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.8	9.7	13.7	33.2	3.2	1.7	11.3	34.4	9.4	35.4	7.6	36.4	5.3	37.6		
(5)			9.8	27.1	1.0	0.9	9.1	27.7	8.5	28.2	7.9	28.7	7.1	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	27.7	27.8	27.1	25.7	23.6	21.5	20.6	21.2	23.1	24.7	26.1	27.5		
	DBStd	2.83	1.03	1.21	1.04	1.24	1.33	1.70	1.47	1.34	1.18	1.07	0.96	0.95		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	4	0	0	0	0	0	2	2	1	0	0	0	0		
	CDD10.0	5371	550	497	532	471	421	346	329	348	393	457	484	542		
	CDD18.3	2334	292	264	273	221	163	97	73	91	143	199	234	284		
	CDH23.3	18504	3339	3026	2881	1787	612	89	15	52	370	1159	2051	3124		
	CDH26.7	3672	984	932	650	147	8	0	0	0	2	21	167	761		
(14) Wind	WSAvg	5.4	5.6	5.5	5.6	5.6	5.5	5.5	5.0	5.0	5.0	5.5	5.4	5.5		
(15) Precipitation	PrecAvg	2183	359	493	380	223	136	65	44	50	39	45	103	207		
	PrecMax	3538	1581	1197	1058	686	410	294	197	168	208	205	570	817		
	PrecMin	955	26	68	52	12	9	1	0	0	0	0	3	15		
	PrecStd	558	319	269	233	154	92	63	36	46	47	53	126	194		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	32.2	31.0	29.7	27.7	25.7	24.6	25.5	26.9	28.1	29.5	31.0		
		MCWB	23.9	24.9	24.5	24.5	23.4	22.5	20.3	20.7	22.2	21.9	23.6	24.9		
	2%	DB	30.7	30.9	30.1	28.6	26.7	24.8	23.7	24.5	26.1	27.2	28.5	29.9		
		MCWB	24.9	25.2	24.9	23.5	22.5	21.9	20.1	20.2	21.7	22.3	23.7	25.1		
	5%	DB	30.0	30.2	29.5	28.0	26.1	24.3	23.2	23.9	25.5	26.7	28.0	29.3		
		MCWB	24.8	25.2	24.5	23.0	21.9	21.2	19.9	19.8	21.2	22.3	23.5	24.6		
	10%	DB	29.5	29.7	28.9	27.5	25.6	23.8	22.7	23.3	25.0	26.4	27.6	28.9		
		MCWB	24.6	25.1	24.1	22.9	21.5	20.6	19.6	19.4	20.7	22.0	23.2	24.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	27.9	27.4	25.1	24.4	24.1	22.2	22.4	23.9	24.7	25.6	27.2		
		MCDB	29.2	29.2	29.2	27.0	26.4	24.4	23.2	24.2	25.3	26.4	28.0	28.9		
	2%	WB	26.3	27.2	26.1	24.3	23.7	22.6	21.5	21.6	23.1	24.1	25.0	26.6		
		MCDB	28.9	29.2	28.6	26.8	26.0	23.9	22.8	23.6	25.2	26.3	27.6	28.6		
	5%	WB	25.9	26.6	25.6	23.9	23.1	21.8	21.0	20.8	22.4	23.3	24.4	25.8		
		MCDB	28.7	28.9	28.3	26.7	25.3	23.7	22.6	23.1	24.8	26.0	27.2	28.4		
	10%	WB	25.4	26.1	25.1	23.6	22.3	21.2	20.3	20.2	21.9	22.7	23.9	25.2		
		MCDB	28.5	28.6	27.9	26.5	24.8	23.1	22.3	22.6	24.5	25.7	27.0	28.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.2	3.4	3.1	3.0	3.2	3.3	3.5	3.4	3.2	2.6	2.5	2.7		
		MCDBR	3.9	4.0	3.9	3.5	3.8	3.5	3.9	4.1	3.8	3.0	3.0	3.2		
	5% WB	MCWBR	1.8	2.2	1.8	1.6	1.8	2.2	2.1	2.3	1.9	1.7	1.7	1.7		
		MCWBR	3.3	3.6	3.4	2.8	3.0	2.7	2.6	3.3	2.9	2.6	2.8	3.0		
(40) Clear-Sky Solar Irradiance	taub		0.402	0.402	0.391	0.374	0.358	0.348	0.332	0.340	0.370	0.396	0.398	0.408		
		taud	2.541	2.544	2.563	2.596	2.600	2.607	2.640	2.604	2.502	2.456	2.491	2.489		
	Ebn at Noon		943	932	920	900	878	869	897	920	925	928	941	937		
		Edh at Noon	111	109	104	94	87	83	83	91	108	118	116	117		
(44) All-Sky Solar Radiation	RadAvg		6.19	5.80	5.36	4.78	4.16	3.74	4.17	5.05	6.03	6.63	6.80	6.69		
	RadStd		0.57	0.70	0.56	0.50	0.39	0.36	0.33	0.40	0.41	0.46	0.64	0.70		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page