

THEVENARD ISLAND, Australia

WMO: 943030

Lat: 21.461S

Lon: 115.020E

Elev: 6

StdP: 101.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	17.2	4.4	5.2	21.1	5.7	5.7	21.2	17.4	20.4	14.4	20.6	5.9	170	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.3	35.6	24.4	34.3	24.6	33.3	24.7	28.2	30.1	27.7	30.0	27.2	30.0	5.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.8	23.9	29.0	27.2	22.9	28.9	26.5	22.0	28.8	91.1	30.1	88.5	29.8	86.1	29.9	32.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.2	12.8	11.1	DB	14.0	40.0	1.3	1.4	13.0	41.0	12.3	41.8	11.5	42.6	10.5	43.6	(4)
(5)			WB	9.6	29.2	0.7	1.4	9.1	30.2	8.7	31.0	8.3	31.7	7.8	32.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	29.0	29.5	29.8	28.1	24.7	22.0	21.0	21.6	22.8	24.9	26.1	27.5	(6)
(7)		DBStd	3.51	1.87	1.81	1.62	1.71	1.78	1.61	1.34	1.36	1.48	1.85	1.75	1.98	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(9)
(10)		CDD10.0	5681	589	547	613	543	456	359	342	360	384	461	484	543	(10)
(11)		CDD18.3	2640	331	314	354	293	198	109	84	102	134	202	234	285	(11)
(12)		CDH23.3	24016	3941	3921	4488	3202	1234	244	102	246	529	1331	1911	2869	(12)
(13)		CDH26.7	8934	1686	1797	2098	1171	219	6	2	16	68	317	532	1023	(13)
(14)	Wind	WSAvg	6.2	6.7	6.5	5.8	5.5	5.7	5.9	5.6	5.6	6.5	6.9	6.9	6.8	(14)
(15)	Precipitation	PrecAvg	295	43	76	58	21	28	34	15	5	1	2	13	(15)	
(16)		PrecMax	557	142	369	277	91	184	122	100	32	11	13	14	68	(16)
(17)		PrecMin	98	0	0	4	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	136	46	94	74	25	40	38	25	7	2	2	3	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.1	37.1	37.3	35.2	31.4	27.4	26.6	28.5	30.7	33.4	34.3	35.9	(19)
(20)			MCWB	24.8	25.1	24.0	22.8	20.7	19.8	18.4	17.7	19.1	20.5	21.0	24.1	(20)
(21)		2%	DB	34.8	35.1	35.0	33.4	29.9	26.4	25.2	26.6	28.4	31.0	32.0	33.6	(21)
(22)			MCWB	25.1	25.5	24.8	22.8	20.6	19.2	18.6	18.2	19.0	20.7	21.9	23.7	(22)
(23)		5%	DB	33.3	33.7	33.7	32.3	28.9	25.6	24.5	25.6	27.1	29.5	30.6	32.3	(23)
(24)			MCWB	25.3	25.6	25.1	23.0	20.8	18.9	18.1	18.0	19.0	20.9	22.4	24.1	(24)
(25)		10%	DB	32.2	32.6	32.6	31.2	27.8	24.8	23.7	24.7	26.1	28.4	29.5	30.9	(25)
(26)			MCWB	25.5	25.7	25.1	23.1	20.5	18.8	17.6	17.8	18.8	20.9	22.3	24.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.5	29.0	29.1	28.1	25.9	24.4	23.2	22.5	23.1	24.5	26.0	28.0	(27)
(28)			MCDWB	30.6	30.6	30.2	29.4	27.3	25.3	24.3	23.7	24.9	26.6	27.6	30.0	(28)
(29)		2%	WB	27.7	28.2	28.1	26.8	24.2	23.1	21.4	21.2	21.8	23.4	25.0	26.7	(29)
(30)			MCDWB	29.9	30.4	29.7	28.9	26.4	24.3	23.0	23.1	24.5	26.5	27.5	29.6	(30)
(31)		5%	WB	27.2	27.6	27.4	25.8	23.4	22.1	20.4	20.4	21.1	22.8	24.4	26.0	(31)
(32)			MCDWB	30.0	30.3	29.9	28.6	26.1	23.6	22.3	22.8	24.1	26.5	27.4	29.0	(32)
(33)		10%	WB	26.7	27.2	26.7	25.0	22.7	21.0	19.4	19.6	20.4	22.1	23.7	25.3	(33)
(34)			MCDWB	29.9	30.1	30.1	28.5	25.8	23.3	21.9	22.5	23.9	26.5	27.3	28.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	6.1	6.3	6.4	6.0	5.5	5.9	7.0	7.3	7.4	7.1	6.7	(35)
(36)			MCDBR	7.7	7.4	7.4	7.5	7.1	6.1	6.5	7.9	8.4	8.5	8.2	8.2	(36)
(37)			MCWBR	3.4	3.6	3.7	4.3	4.3	4.0	4.0	4.2	4.5	4.3	4.0	3.8	(37)
(38)		5% WB	MCDWB	6.3	6.2	6.3	6.4	6.0	4.6	5.4	7.0	7.4	7.5	6.7	6.7	(38)
(39)			MCWBR	3.0	3.3	3.6	4.2	4.2	4.0	4.1	4.4	4.2	4.0	3.6	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.396	0.395	0.374	0.353	0.331	0.322	0.315	0.316	0.330	0.346	0.352	0.369	(40)	
(41)		taud	2.527	2.549	2.596	2.618	2.624	2.631	2.629	2.590	2.543	2.519	2.535	2.552	(41)	
(42)		Ebn at Noon	949	938	932	913	897	886	905	937	961	973	985	976	(42)	
(43)		Edh at Noon	113	108	99	90	83	79	81	91	103	110	111	110	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.70	7.30	6.45	5.43	4.54	4.07	4.39	5.48	6.55	7.47	8.05	8.15	(44)	
(45)		RadStd	0.37	0.42	0.40	0.32	0.33	0.29	0.33	0.18	0.22	0.20	0.21	0.32	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (6 neighbors)	+0.31	N/A	-1.02	N/A	N/A	N/A	N/A	N/A	+153	+160	(47)

Nomenclature: See separate page