

ONslow, Australia

WMO: 943050

Lat: 21.633S

Lon: 115.117E

Elev: 4

StdP: 101.28

Time Zone: 8.00 (E08)

Period: 94-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	12.8	0.5	3.9	19.1	2.6	4.6	19.9	9.2	19.0	8.1	20.4	1.8	180	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.7	38.7	22.3	36.5	23.5	34.7	24.3	28.6	32.5	27.7	32.2	27.2	31.6	4.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.5	31.5	26.5	22.1	30.8	25.9	21.3	30.3	92.5	32.5	88.5	32.2	86.1	31.7	36.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.2	7.4	9.2	43.6	0.9	2.0	8.5	45.0	8.0	46.2	7.5	47.3	6.8	48.7		
(5)			6.2	31.4	1.2	2.9	5.3	33.4	4.7	35.1	4.0	36.7	3.2	38.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.8	29.1	29.6	29.3	27.0	23.7	20.2	19.3	20.2	21.5	24.3	25.6	27.8		
	DBStd	4.19	2.37	1.91	1.80	1.70	2.08	2.02	1.89	1.67	1.71	2.55	2.23	2.44		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	21	0	0	0	0	0	5	12	4	1	0	0	0		
	CDD10.0	5385	591	548	598	509	423	304	288	316	345	443	467	552		
	CDD18.3	2364	333	314	339	259	165	59	42	61	96	185	217	294		
	CDH23.3	25369	4324	4171	4392	2747	1192	244	156	325	608	1653	2083	3473		
	CDH26.7	10874	2121	2094	2204	1077	286	16	13	36	110	604	766	1548		
(14) Wind	WSAvg	3.5	4.2	3.9	3.5	2.6	2.4	2.4	2.6	2.8	3.7	4.2	4.6	4.8		
(15) Precipitation	PrecAvg	287	26	74	50	18	45	49	13	8	2	1	1	1		
	PrecMax	998	144	545	369	117	229	227	90	60	25	27	23	19		
	PrecMin	75	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	200	37	131	82	27	54	58	19	14	4	5	4	4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	40.5	39.2	35.5	32.1	28.4	28.3	29.5	32.3	38.6	39.0	41.0		
		MCWB	21.8	23.0	23.4	23.3	22.2	19.8	17.8	17.5	18.1	19.8	19.8	21.7		
	2%	DB	37.7	36.8	36.5	33.6	30.6	26.9	26.3	27.7	29.6	34.4	34.7	36.7		
		MCWB	23.2	25.0	24.9	23.8	22.1	19.6	17.6	17.7	17.8	19.5	20.2	22.5		
	5%	DB	35.3	34.5	34.8	32.4	29.4	25.9	25.0	26.4	27.8	31.5	32.1	33.8		
		MCWB	24.4	26.3	25.6	23.7	21.9	19.2	17.9	17.7	18.5	19.5	21.1	23.3		
	10%	DB	33.3	33.2	33.5	31.2	28.3	24.9	24.0	25.3	26.6	29.6	30.4	32.1		
		MCWB	25.3	26.4	25.9	23.6	21.6	18.7	17.8	17.8	18.8	19.8	21.8	24.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.3	29.6	33.1	27.4	26.0	23.5	22.5	21.7	22.5	24.6	25.1	27.7		
		MCDB	32.8	34.0	33.9	30.5	29.0	25.9	24.2	24.8	25.9	28.9	30.2	32.0		
	2%	WB	27.5	28.2	29.5	26.1	24.8	22.4	21.0	20.7	21.6	23.4	24.5	26.7		
		MCDB	32.3	32.8	31.4	30.0	27.8	24.9	23.4	24.2	25.4	28.0	29.5	31.3		
	5%	WB	27.0	27.7	27.8	25.6	24.0	21.4	19.9	20.0	21.0	22.5	23.9	26.1		
		MCDB	31.6	32.2	32.1	29.7	27.1	23.9	23.0	23.4	25.0	27.5	28.8	30.8		
	10%	WB	26.5	27.2	27.1	25.0	23.2	20.3	19.0	19.1	20.2	21.7	23.3	25.6		
		MCDB	31.1	31.6	31.4	29.4	26.7	23.1	22.2	23.1	24.5	27.1	28.1	30.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	7.7	9.2	9.3	9.4	9.5	10.1	11.1	11.3	11.7	10.2	8.9		
		MCDBR	13.2	10.7	11.8	10.6	10.4	10.3	11.2	12.6	13.2	15.0	13.8	12.7		
		MCWBR	6.7	5.1	5.9	5.8	5.8	5.6	6.1	6.7	6.8	6.9	6.8	6.2		
	5% WB	MCDBR	8.2	7.5	8.7	8.5	8.0	7.3	8.8	9.6	10.3	10.8	9.6	8.1		
		MCWBR	5.3	4.2	5.7	5.3	5.0	4.4	5.7	6.2	6.4	7.1	5.8	5.5		
(40) Clear-Sky Solar Irradiance	taub		0.394	0.395	0.375	0.352	0.331	0.322	0.314	0.317	0.329	0.346	0.351	0.367		
	taud		2.513	2.527	2.573	2.597	2.599	2.608	2.607	2.561	2.521	2.496	2.512	2.533		
	Ebn at Noon		951	937	931	913	896	885	905	935	961	973	986	977		
	Edh at Noon		114	111	101	92	85	80	83	93	105	113	114	112		
(44) All-Sky Solar Radiation	RadAvg		7.71	7.30	6.43	5.43	4.53	4.06	4.38	5.47	6.56	7.48	8.07	8.17		
	RadStd		0.37	0.41	0.40	0.31	0.33	0.28	0.33	0.18	0.21	0.20	0.22	0.34		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.31	N/A	-1.02	N/A	N/A	N/A	N/A	N/A	N/A	+153	+160

Nomenclature: See separate page