

LEGENDRE ISLAND, Australia

WMO: 943070

Lat: 20.358S

Lon: 116.843E

Elev: 97

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	62.5	64.1	40.7	37.5	70.7	43.5	41.8	71.3	34.6	66.6	33.1	66.5	13.4	150	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	9.1	94.5	79.2	92.6	79.7	91.1	79.7	86.3	88.2	85.4	87.4	84.5	86.8	10.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
86.1	191.5	87.4	85.0	184.6	86.4	84.1	179.3	85.7	51.2	88.3	50.0	87.7	49.0	86.7	90.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.9	28.5	25.7	59.9	99.5	1.5	1.9	58.9	100.8	58.0	101.9	57.2	103.0	56.1	104.3		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.8	84.4	85.1	86.0	83.2	77.0	71.8	70.1	71.3	74.6	78.8	81.0	82.7
	DBStd	6.16	2.39	2.52	2.77	2.32	3.37	3.07	2.64	2.37	2.44	3.19	3.06	2.95
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDD50	10512	1066	984	1115	996	837	654	625	662	737	892	930	1014
	CDD65	5038	601	564	650	546	372	204	161	197	287	427	480	549
	CDH74	49219	7369	7194	8559	6487	2803	593	258	449	1271	3421	4705	6110
	CDH80	18104	3063	3236	4156	2446	492	15	4	15	135	864	1460	2218
Wind	WSAvg	13.7	14.7	14.0	12.5	11.0	13.4	15.0	13.4	12.6	13.2	14.0	15.6	15.1
Precipitation	PrecAvg	11.7	2.0	3.4	1.8	0.8	1.1	1.5	0.4	0.1	0.0	0.0	0.0	0.5
	PrecMax	28.1	9.1	13.7	8.0	4.4	5.2	6.2	2.8	0.9	0.7	0.5	1.3	4.1
	PrecMin	3.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.5	2.4	3.9	2.4	1.1	1.4	1.8	0.7	0.2	0.2	0.1	0.2	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.5	96.3	97.6	93.4	88.2	81.8	80.1	81.7	86.4	92.3	93.6	94.9
		MCWB	78.1	79.5	77.2	77.8	73.2	71.8	65.8	68.7	68.6	72.0	75.9	78.4
	2%	DB	91.8	93.0	94.7	91.0	86.0	80.0	78.1	79.3	83.1	88.6	90.6	91.5
		MCWB	82.2	81.5	79.9	77.0	71.8	69.5	66.4	66.7	68.9	72.0	75.5	79.1
	5%	DB	90.2	91.2	92.6	89.4	84.3	78.6	76.6	77.8	81.3	86.4	88.4	89.4
		MCWB	81.4	81.7	80.4	76.4	71.5	68.4	66.0	65.8	68.5	72.7	76.0	79.9
	10%	DB	88.8	89.8	90.9	88.0	82.7	77.2	75.3	76.4	79.8	84.4	86.4	87.8
		MCWB	80.8	81.4	80.9	76.2	71.2	67.1	64.8	65.4	67.8	72.9	76.0	79.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	86.4	87.6	86.9	87.6	79.8	79.1	76.6	75.0	76.8	80.2	84.2	89.0
		MCDB	88.4	89.1	88.5	89.9	81.9	79.7	77.0	76.9	79.3	83.0	85.9	90.2
	2%	WB	85.3	85.5	85.6	85.8	78.1	76.7	73.2	72.8	74.7	78.8	82.2	85.5
		MCDB	87.4	87.6	87.4	87.9	80.3	77.9	74.3	75.3	77.6	82.1	84.5	87.6
	5%	WB	84.4	84.6	84.8	83.7	77.0	73.7	71.0	71.5	73.4	77.6	80.6	83.5
		MCDB	86.2	87.0	87.0	86.3	80.3	76.1	73.6	74.4	76.5	81.4	83.7	86.3
	10%	WB	83.4	83.9	84.1	82.0	75.8	71.7	69.1	70.0	72.1	76.4	79.1	82.1
		MCDB	85.6	86.5	86.7	85.1	80.0	75.4	72.8	73.4	76.2	80.8	83.0	85.6
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.4	9.1	9.6	9.1	8.4	9.3	10.2	10.4	10.4	9.9	8.9
		MCDBR	9.9	10.3	11.6	11.4	10.7	9.7	10.9	11.8	12.2	12.8	12.1	10.7
		MCWBR	4.9	5.8	6.9	7.2	7.0	6.4	8.1	7.2	6.8	6.4	5.8	6.1
	5% WB	MCDBR	8.1	9.5	10.1	10.3	9.2	7.8	9.4	10.6	10.8	10.6	9.2	8.5
		MCWBR	5.2	6.1	6.8	6.0	7.2	6.9	8.9	6.8	6.4	5.4	5.2	5.8
Clear-Sky Solar Irradiance	taub	0.403	0.395	0.377	0.352	0.336	0.324	0.314	0.313	0.334	0.357	0.361	0.377	
	taud	2.527	2.566	2.609	2.637	2.619	2.639	2.648	2.606	2.549	2.507	2.535	2.559	
	Ebn at Noon	299	298	296	291	284	282	289	299	304	305	310	307	
	Edh at Noon	36	34	31	28	27	25	26	29	33	36	35	35	
All-Sky Solar Radiation	RadAvg	2363	2266	2029	1774	1476	1340	1457	1796	2114	2392	2546	2539	
	RadStd	146	157	148	98	114	97	91	49	80	45	54	97	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	+0.83	N/A	N/A	N/A	N/A	+0.86	+1.01	N/A	N/A	N/A	+284

Nomenclature: See separate page