

BEDOUT ISLAND, AustraliaWMO: **943100**Lat: **19.589S**Lon: **119.100E**Elev: **32**StdP: **14.68**Time Zone: **8.00 (E08)**Period: **94-12**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	65.3	66.7	27.0	21.0	73.5	33.1	27.7	73.9	37.0	66.5	34.7	67.6	19.5	110	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	8.4	94.3	79.3	93.0	79.8	91.9	79.5	84.4	90.0	83.6	89.3	82.9	88.6	11.2	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.2	173.4	87.1	82.2	167.8	87.1	81.4	163.7	86.9	48.7	89.7	47.8	89.8	47.0	88.8	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.2	31.8	28.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			49.8	85.4	3.4	1.1	47.3	86.2	45.3	86.8	43.3	87.4	40.8	88.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.7	86.1	86.3	86.6	84.8	79.4	73.9	72.5	73.6	76.8	80.9	83.4	84.8
	DBStd	5.73	2.26	2.44	2.55	2.44	3.50	3.03	2.31	1.92	2.30	2.54	2.35	2.41
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11215	1118	1017	1135	1043	911	718	697	733	804	958	1002	1079
	CDD65	5740	653	597	670	593	446	268	232	268	354	493	552	614
	CDH74	59095	8529	7874	8939	7340	3864	914	473	789	1944	4619	6238	7572
	CDH80	23934	4110	3882	4530	3152	895	51	6	26	302	1364	2347	3269
Wind	WSAvg	14.1	15.8	15.5	12.7	11.1	14.3	15.2	14.0	13.0	12.7	13.0	15.4	16.3
Precipitation	PrecAvg	18.0	3.4	4.6	3.1	1.4	1.5	1.0	0.5	0.2	0.1	0.1	0.1	1.9
	PrecMax	34.8	14.6	13.0	13.8	6.8	5.8	5.7	2.4	1.7	1.0	0.4	0.3	7.9
	PrecMin	6.1	0.0	0.1	0.2	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	7.1	3.5	3.6	3.5	1.7	1.7	1.3	0.6	0.4	0.2	0.1	0.1	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.0	95.4	96.1	94.0	90.4	83.5	80.9	82.4	86.9	91.8	93.5	95.2
		MCWB	83.2	80.1	79.5	77.2	73.2	69.3	69.3	64.5	70.8	75.8	74.7	76.1
	2%	DB	93.1	93.5	93.9	91.7	88.4	81.7	79.3	80.5	84.7	89.4	91.2	92.8
		MCWB	82.3	81.5	78.9	76.9	72.6	68.7	67.4	65.8	70.1	75.3	76.4	78.9
	5%	DB	91.7	92.3	92.4	90.4	86.4	80.0	78.0	79.2	83.1	87.7	89.8	91.3
		MCWB	81.7	81.2	79.1	76.2	71.5	67.7	66.1	65.1	69.5	75.0	76.8	79.5
	10%	DB	90.6	90.9	91.2	89.0	84.5	78.4	76.7	78.1	81.6	86.1	88.5	89.8
		MCWB	81.2	80.6	79.1	75.4	70.4	66.6	65.2	64.6	68.9	74.9	76.9	79.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	85.2	85.9	84.6	83.0	78.2	74.7	73.9	72.9	75.9	80.7	83.5	83.2
		MCDB	91.4	90.2	88.9	88.3	83.2	78.2	77.6	77.5	81.7	85.6	87.9	90.5
	2%	WB	84.0	84.8	83.7	81.8	77.1	73.4	71.9	71.8	74.9	79.8	81.9	82.2
		MCDB	90.9	89.5	89.1	87.0	83.5	77.0	75.7	75.8	80.4	85.0	86.8	89.0
	5%	WB	83.3	83.8	82.9	80.9	76.0	72.0	70.8	70.7	73.9	78.9	80.7	81.5
		MCDB	89.7	88.9	88.5	86.3	82.9	76.5	74.8	74.9	79.1	84.3	86.9	88.0
	10%	WB	82.6	82.9	82.3	79.9	75.0	70.5	69.4	69.3	72.7	78.0	79.6	80.8
		MCDB	88.7	88.4	87.9	85.8	82.2	75.5	74.1	74.1	78.0	83.5	86.0	87.0
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.7	8.4	8.4	8.0	7.3	8.3	9.5	10.0	10.3	9.8	9.2
		MCDBR	9.6	9.9	9.8	9.4	9.7	8.8	9.7	10.6	11.2	11.8	10.8	10.4
		MCWBR	3.9	4.7	5.9	6.1	6.6	6.5	6.6	7.2	6.6	5.9	6.0	4.6
	5% WB	MCDBR	9.2	9.4	9.5	8.9	8.8	7.8	8.6	9.3	10.3	10.7	9.9	9.9
		MCWBR	4.0	4.3	4.8	5.6	6.0	6.4	6.2	5.9	4.7	4.7	5.2	4.2
Clear-Sky Solar Irradiance	taub		0.410	0.408	0.381	0.356	0.343	0.327	0.319	0.317	0.344	0.373	0.377	0.387
	taud		2.525	2.545	2.609	2.633	2.600	2.640	2.638	2.598	2.535	2.484	2.516	2.562
	Ebn at Noon		297	294	295	290	282	282	288	298	301	301	305	304
	Edh at Noon		36	35	31	29	27	25	26	29	33	36	36	35
All-Sky Solar Radiation	RadAvg		2277	2210	2036	1835	1530	1388	1516	1850	2142	2403	2538	2493
	RadStd		193	193	180	103	115	125	92	43	80	51	53	109