

BEDOUT ISLAND, AustraliaWMO: **943100**Lat: **19.589S**Lon: **119.100E**Elev: **10**StdP: **101.21**Time Zone: **8.00 (E08)**Period: **94-12**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	19.3	-2.8	3.0	23.0	0.6	4.0	23.3	16.6	19.2	15.5	19.8	8.7	110	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	4.7	34.6	26.3	33.9	26.6	33.3	26.4	29.1	32.2	28.7	31.8	28.3	31.4	5.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.4	24.8	30.6	27.9	24.0	30.6	27.5	23.4	30.5	95.5	32.1	93.3	32.1	91.4	31.6	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.7	14.2	12.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			9.9	29.7	1.9	0.6	8.5	30.1	7.4	30.5	6.3	30.8	4.9	31.2 (5)		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	30.0	30.2	30.3	29.3	26.3	23.3	22.5	23.1	24.9	27.2	28.5	29.3
	DBStd	3.18	1.26	1.35	1.42	1.35	1.94	1.68	1.28	1.07	1.28	1.41	1.31	1.34
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6231	621	565	631	579	506	399	387	407	447	532	557	599
	CDD18.3	3189	363	332	372	329	248	149	129	149	197	274	307	341
	CDH23.3	32831	4738	4374	4966	4078	2147	508	263	438	1080	2566	3466	4207
CDH26.7	13297	2283	2157	2517	1751	497	28	3	14	168	758	1304	1816	
Wind	WSAvg	6.3	7.1	6.9	5.7	4.9	6.4	6.8	6.2	5.8	5.7	5.8	6.9	7.3
Precipitation	PrecAvg	456	87	118	78	36	37	26	13	6	3	3	2	47
	PrecMax	883	372	329	350	172	147	145	60	44	25	10	8	201
	PrecMin	155	1	2	4	1	0	2	1	0	0	0	0	0
	PrecStd	181	88	92	89	42	42	34	16	10	5	2	2	54
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.0	35.2	35.6	34.4	32.5	28.6	27.1	28.0	30.5	33.2	34.2	35.1
		MCWB	28.5	26.7	26.4	25.1	22.9	20.7	20.7	18.1	21.5	24.4	23.7	24.5
	2%	DB	33.9	34.2	34.4	33.2	31.4	27.6	26.3	27.0	29.3	31.9	32.9	33.8
		MCWB	27.9	27.5	26.1	24.9	22.6	20.4	19.6	18.8	21.2	24.1	24.7	26.0
	5%	DB	33.2	33.5	33.6	32.4	30.2	26.7	25.6	26.2	28.4	30.9	32.1	32.9
		MCWB	27.6	27.4	26.2	24.5	21.9	19.8	19.0	18.4	20.9	23.9	24.9	26.4
	10%	DB	32.5	32.7	32.9	31.7	29.2	25.8	24.9	25.6	27.6	30.1	31.4	32.1
		MCWB	27.3	27.0	26.2	24.1	21.3	19.2	18.4	18.1	20.5	23.9	24.9	26.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.5	30.0	29.2	28.3	25.7	23.7	23.3	22.7	24.4	27.1	28.6	28.4
		MCDB	33.0	32.4	31.6	31.3	28.4	25.7	25.4	25.3	27.6	29.8	31.0	32.5
	2%	WB	28.9	29.3	28.7	27.7	25.0	23.0	22.2	22.1	23.8	26.5	27.7	27.9
		MCDB	32.7	32.0	31.7	30.5	28.6	25.0	24.3	24.3	26.9	29.5	30.5	31.7
	5%	WB	28.5	28.8	28.3	27.2	24.4	22.2	21.6	21.5	23.3	26.1	27.1	27.5
		MCDB	32.1	31.6	31.4	30.2	28.3	24.7	23.8	23.8	26.2	29.1	30.5	31.1
	10%	WB	28.1	28.3	27.9	26.6	23.9	21.4	20.8	20.7	22.6	25.6	26.5	27.1
		MCDB	31.5	31.3	31.0	29.9	27.9	24.2	23.4	23.4	25.5	28.6	30.0	30.5
Mean Daily Temperature Range	5% DB	MDBR	4.7	4.8	4.7	4.6	4.4	4.1	4.6	5.3	5.5	5.7	5.4	5.1
		MCDBR	5.3	5.5	5.5	5.2	5.4	4.9	5.4	5.9	6.2	6.5	6.0	5.8
		MCWBR	2.2	2.6	3.3	3.4	3.7	3.6	3.6	4.0	3.7	3.3	3.3	2.6
	5% WB	MCDBR	5.1	5.2	5.3	4.9	4.9	4.3	4.8	5.2	5.7	5.9	5.5	5.5
MCWBR		2.2	2.4	2.7	3.1	3.4	3.6	3.5	3.3	2.6	2.6	2.9	2.3	
Clear-Sky Solar Irradiance	taub	0.410	0.408	0.381	0.356	0.343	0.327	0.319	0.317	0.344	0.373	0.377	0.387	
	taud	2.525	2.545	2.609	2.633	2.600	2.640	2.638	2.598	2.535	2.484	2.516	2.562	
	Ebn at Noon	936	927	929	915	890	889	907	941	949	948	961	957	
	Edh at Noon	113	109	99	90	86	80	82	91	104	115	113	109	
All-Sky Solar Radiation	RadAvg	7.18	6.97	6.42	5.79	4.82	4.38	4.78	5.83	6.75	7.58	8.00	7.86	
	RadStd	0.61	0.61	0.57	0.33	0.36	0.40	0.29	0.13	0.25	0.16	0.17	0.34	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.49	N/A	N/A	N/A	N/A	+0.48	+0.52	N/A	N/A	+158

Nomenclature: See separate page