

TELFER, Australia

WMO: 943190

Lat: 21.7125S

Lon: 122.2281E

Elev: 293

StdP: 97.86

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	9.4	-14.2	1.1	27.0	-10.2	1.6	24.6	11.1	16.9	10.3	17.4	4.3	140	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	13.2	43.2	20.1	42.2	20.1	41.2	20.1	25.1	31.0	24.6	31.0	24.2	31.0	4.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.6	26.2	23.2	18.6	26.6	22.6	18.0	27.0	78.4	30.9	76.4	30.8	74.8	30.8	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.6	8.7	DB	5.4	45.3	1.3	0.9	4.5	46.0	3.8	46.6	3.1	47.1	2.1	47.8	(4)
(5)			WB	1.5	26.3	0.8	1.0	0.9	27.0	0.4	27.6	-0.1	28.2	-0.7	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	32.9	31.9	30.7	27.6	22.3	18.5	18.3	20.5	25.0	29.6	31.6	33.0	(6)	
	DBStd	6.19	2.95	3.18	3.07	2.99	3.15	2.99	2.81	2.91	3.20	3.04	2.70	2.73	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	87	0	0	0	0	4	34	36	12	1	0	0	0	(9)	
	CDD10.0	6133	711	612	642	528	383	254	258	325	450	609	649	713	(10)	
	CDD18.3	3180	453	379	383	278	129	39	36	79	201	351	399	454	(11)	
	CDH23.3	46317	7085	5660	5502	3506	1340	370	432	1003	2638	5222	6266	7293	(12)	
(13)	CDH26.7	28669	4768	3647	3392	1924	560	80	98	361	1403	3288	4171	4977	(13)	
(14) Wind	WSAvg	4.7	4.7	4.6	4.6	4.4	4.5	4.7	4.6	4.6	4.7	4.8	4.9	4.9	(14)	
(15) Precipitation	PrecAvg	302	42	93	43	15	19	12	10	6	3	2	8	42	(15)	
	PrecMax	680	129	344	128	89	141	48	78	56	24	12	26	209	(16)	
	PrecMin	114	4	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	151	33	103	39	23	35	15	19	15	7	4	8	54	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.8	44.1	42.2	39.1	35.0	31.0	30.9	33.6	37.9	41.4	43.1	44.8	(19)	
		MCWB	21.0	20.2	21.0	19.6	17.3	16.8	15.5	15.5	17.0	18.3	19.1	20.7	(20)	
	2%	DB	43.1	42.8	40.3	37.8	33.4	28.9	29.1	31.9	36.3	40.2	42.0	43.0	(21)	
		MCWB	20.2	20.3	20.6	19.0	16.7	16.0	15.0	14.9	16.4	18.2	19.0	20.2	(22)	
	5%	DB	42.0	41.2	39.1	36.2	31.8	27.2	27.6	30.4	35.1	39.1	40.8	41.8	(23)	
		MCWB	20.4	20.8	20.3	18.9	16.2	14.8	14.3	14.5	16.0	17.9	18.9	20.3	(24)	
	10%	DB	40.6	39.2	37.9	34.8	30.0	25.6	25.9	28.9	33.7	37.9	39.2	40.4	(25)	
		MCWB	20.9	21.1	20.4	18.3	15.4	14.2	13.2	14.0	15.5	17.6	18.8	20.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	26.1	25.1	23.5	21.8	20.4	19.0	18.6	18.9	21.4	23.1	24.7	(27)	
		MCDB	31.5	30.8	30.4	28.2	25.0	24.0	25.3	25.4	31.3	32.2	32.5	32.0	(28)	
	2%	WB	25.1	25.1	24.5	22.5	19.3	18.8	17.2	16.9	18.0	20.5	22.2	24.1	(29)	
		MCDB	31.4	30.8	30.1	28.8	27.3	24.8	25.0	27.5	31.1	32.9	32.9	31.6	(30)	
	5%	WB	24.6	24.6	23.9	21.6	18.1	17.2	15.8	15.9	17.2	19.8	21.5	23.5	(31)	
		MCDB	31.5	30.7	29.9	29.9	27.3	23.6	24.6	27.1	31.2	32.8	33.2	32.1	(32)	
	10%	WB	24.2	24.2	23.4	20.6	17.0	16.0	14.5	14.9	16.5	19.1	20.8	23.0	(33)	
		MCDB	31.6	30.6	30.2	30.7	26.4	22.5	23.7	26.7	30.9	32.8	33.3	32.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.8	12.0	12.0	12.9	13.4	12.9	13.9	15.2	15.3	14.7	14.4	13.2	(35)	
		MCDBR	14.8	14.7	13.8	13.9	15.0	14.1	15.6	16.7	16.5	15.2	15.0	14.5	(36)	
	5% WB	MCWBR	4.5	4.3	4.0	4.6	5.5	5.7	6.8	6.8	5.7	4.8	4.4	4.0	(37)	
		MCWBR	11.9	10.9	10.5	10.8	11.5	10.2	12.6	13.8	14.8	13.8	13.9	12.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.378	0.377	0.372	0.360	0.337	0.321	0.325	0.327	0.345	0.375	0.377	0.374	(40)	
		taud	2.490	2.506	2.495	2.466	2.454	2.488	2.450	2.402	2.380	2.335	2.379	2.470	(41)	
	Ebn at Noon	Ebn at Noon	966	955	933	902	884	882	888	922	944	945	960	971	(42)	
		Edh at Noon	117	113	110	104	97	90	96	109	121	133	130	119	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.44	7.08	6.37	5.70	4.80	4.34	4.72	5.82	6.82	7.55	7.93	7.79	(44)	
	RadStd	RadStd	0.44	0.56	0.47	0.28	0.36	0.35	0.29	0.20	0.27	0.26	0.31	0.44	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page