

ALICE SPRINGS, Australia

WMO: 943260

Lat: 23.7950S

Lon: 133.8889E

Elev: 1795

StdP: 13.77

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	31.9	34.2	1.7	6.4	77.9	7.6	8.7	73.2	19.8	63.6	18.3	63.0	4.4	270	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.4	104.8	65.3	102.5	65.1	100.5	64.9	74.7	84.2	73.4	83.6	72.2	83.8	11.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.7	129.8	77.5	71.2	123.1	77.2	69.4	115.5	77.2	39.6	83.7	38.4	84.1	37.2	82.6	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	18.6	16.9	DB	27.4	108.8	2.9	2.1	25.4	110.3	23.7	111.5	22.1	112.6	20.0	114.1	(4)
(5)			WB	25.0	77.6	3.0	2.8	22.9	79.6	21.1	81.2	19.5	82.8	17.3	84.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.3	85.1	82.6	77.7	69.6	60.3	53.9	54.0	58.0	67.6	74.0	78.7	82.5	(6)	
	DBStd	12.89	5.85	5.57	6.53	6.30	6.44	6.56	6.42	7.36	8.11	7.76	6.93	6.43	(7)	
	HDD50	61	0	0	0	0	2	24	27	8	0	0	0	0	(8)	
	HDD65	1217	0	0	3	26	175	340	346	245	65	15	2	0	(9)	
	CDD50	7459	1087	914	858	587	322	142	152	257	527	744	861	1008	(10)	
	CDD65	3140	622	494	396	163	30	8	6	29	142	294	413	543	(11)	
	CDH74	45706	9309	6976	5369	2337	558	139	162	576	2333	4333	5816	7798	(12)	
	CDH80	25911	5903	4163	2947	1005	145	24	18	167	1085	2338	3377	4739	(13)	
(14) Wind	WSAvg	8.0	9.1	8.8	8.4	7.3	6.7	6.7	6.7	7.5	8.2	8.8	8.9	9.1	(14)	
(15) Precipitation	PrecAvg	11.4	1.9	1.5	1.4	0.6	0.7	0.5	0.6	0.3	0.4	0.8	1.2	1.5	(15)	
	PrecMax	30.8	10.1	9.8	14.1	3.8	4.1	4.0	5.7	2.5	2.2	2.9	6.3	9.0	(16)	
	PrecMin	3.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	6.4	2.4	2.4	2.6	1.0	1.1	0.8	1.1	0.5	0.6	0.8	1.3	1.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.9	105.7	102.5	96.7	87.9	83.8	82.4	89.4	97.0	102.0	104.5	107.9	(19)	
		MCWB	66.8	66.0	66.2	63.9	59.7	58.9	56.5	57.8	60.2	61.4	63.3	65.3	(20)	
	2%	DB	105.4	102.5	99.0	92.9	84.2	77.9	78.7	84.5	93.5	98.7	102.0	104.0	(21)	
		MCWB	66.3	65.7	64.9	62.6	58.5	57.1	54.5	56.3	59.4	61.2	63.1	64.6	(22)	
	5%	DB	102.5	100.2	96.6	89.5	80.5	73.4	74.9	80.6	90.6	96.0	98.9	101.0	(23)	
		MCWB	66.3	65.4	64.3	61.3	56.8	54.5	53.3	54.3	58.5	60.3	62.8	64.5	(24)	
	10%	DB	100.3	97.2	93.3	86.0	76.6	68.4	70.4	76.6	87.4	92.8	95.4	98.5	(25)	
		MCWB	66.1	65.3	63.7	60.0	55.9	52.1	51.7	52.9	57.1	59.7	62.0	64.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.3	76.5	74.2	70.7	65.6	63.2	62.6	61.7	65.7	69.5	71.7	74.9	(27)	
		MCDB	85.7	84.6	83.2	81.0	73.0	74.1	71.9	78.9	80.9	84.2	85.5	83.7	(28)	
	2%	WB	74.6	74.9	72.4	67.5	62.4	60.1	58.1	58.9	63.1	66.7	69.7	72.8	(29)	
		MCDB	84.3	84.3	81.8	81.0	73.8	72.2	71.3	77.1	82.2	80.0	83.4	83.3	(30)	
	5%	WB	73.2	73.6	70.5	64.5	59.9	57.4	55.2	56.4	61.0	64.6	68.1	71.5	(31)	
		MCDB	84.2	83.7	81.9	80.9	74.4	67.5	69.3	76.4	82.9	82.7	82.9	83.4	(32)	
	10%	WB	71.8	72.3	68.4	62.0	57.8	54.5	52.9	54.1	59.0	62.8	66.6	70.1	(33)	
		MCDB	85.3	83.4	84.2	81.4	72.9	66.0	68.4	73.2	83.3	83.4	83.3	83.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	25.4	25.1	26.3	28.5	27.5	27.1	29.0	30.9	30.7	29.2	27.5	25.6	(35)	
		MCDBR	29.1	29.7	29.7	31.8	32.3	31.1	34.0	34.3	33.2	32.6	31.1	30.2	(36)	
	5% WB	MCWBR	9.6	9.7	11.1	12.5	14.1	14.8	16.1	15.5	13.2	12.6	10.8	10.0	(37)	
		MCWBR	20.4	18.9	19.7	25.1	25.5	24.0	27.7	28.5	28.1	25.0	24.5	21.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.362	0.354	0.337	0.316	0.296	0.283	0.283	0.296	0.342	0.346	0.362	0.361	(40)	
		taud	2.511	2.547	2.569	2.588	2.609	2.624	2.607	2.532	2.422	2.441	2.457	2.500	(41)	
	Ebn at Noon		312	309	306	300	293	292	295	302	299	308	309	312	(42)	
		Edh at Noon	36	34	32	29	26	24	25	30	36	38	38	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		2422	2325	2085	1811	1464	1316	1410	1737	2038	2287	2363	2343	(44)	
	RadStd		151	177	158	134	136	95	114	86	121	165	161	175	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page