

ALICE SPRINGS, Australia

WMO: 943260

Lat: 23.7950S

Lon: 133.8889E

Elev: 547

StdP: 94.92

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	0.0	1.2	-16.9	0.9	25.5	-13.5	1.2	22.9	8.9	17.5	8.2	17.2	1.9	270	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	40.4	18.5	39.2	18.4	38.1	18.3	23.7	29.0	23.0	28.7	22.3	28.8	5.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.6	18.5	25.3	21.8	17.6	25.1	20.8	16.5	25.1	74.3	28.7	71.5	28.9	68.7	28.1	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.3	7.5	-2.5	42.7	1.6	1.1	-3.7	43.5	-4.6	44.2	-5.5	44.8	-6.7	45.6		
(5)			-3.9	25.3	1.6	1.6	-5.1	26.4	-6.0	27.3	-7.0	28.2	-8.2	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	29.5	28.1	25.4	20.9	15.7	12.2	12.2	14.4	19.8	23.3	25.9	28.1	
	DBStd	7.16	3.25	3.10	3.63	3.50	3.58	3.64	3.57	4.09	4.51	4.31	3.85	3.57	
	HDD10.0	34	0	0	0	0	1	13	15	4	0	0	0	0	
	HDD18.3	676	0	0	2	14	97	189	192	136	36	8	1	0	
	CDD10.0	4144	604	508	477	326	179	79	84	143	293	413	478	560	
	CDD18.3	1744	346	274	220	91	17	4	3	16	79	163	229	302	
	CDH23.3	25392	5172	3876	2983	1298	310	77	90	320	1296	2407	3231	4332	
CDH26.7	14395	3279	2313	1637	558	81	13	10	93	603	1299	1876	2633		
Wind	WSAvg	3.6	4.1	3.9	3.7	3.3	3.0	3.0	3.0	3.3	3.7	4.0	4.0	4.0	
Precipitation	PrecAvg	289	48	38	36	15	18	12	15	8	9	20	30	39	
	PrecMax	782	256	250	357	96	104	101	144	64	57	73	160	229	
	PrecMin	76	0	0	0	0	0	0	0	0	0	0	0	1	
	PrecStd	163	61	60	66	25	27	20	27	13	15	21	33	43	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.2	41.0	39.2	35.9	31.0	28.8	28.0	31.9	36.1	38.9	40.3	42.1	
		MCWB	19.3	18.9	19.0	17.7	15.4	15.0	13.6	14.4	15.7	16.3	17.4	18.5	
	2%	DB	40.8	39.1	37.2	33.9	29.0	25.5	25.9	29.2	34.1	37.1	38.9	40.0	
		MCWB	19.1	18.7	18.3	17.0	14.7	14.0	12.5	13.5	15.2	16.2	17.3	18.1	
	5%	DB	39.1	37.9	35.9	31.9	26.9	23.0	23.9	27.0	32.6	35.6	37.1	38.3	
		MCWB	19.0	18.6	17.9	16.3	13.8	12.5	11.8	12.4	14.7	15.7	17.1	18.1	
	10%	DB	37.9	36.2	34.1	30.0	24.8	20.2	21.3	24.8	30.8	33.8	35.2	36.9	
		MCWB	19.0	18.5	17.6	15.6	13.3	11.2	10.9	11.6	13.9	15.4	16.6	18.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.6	24.7	23.5	21.5	18.7	17.3	17.0	16.5	18.7	20.8	22.1	23.9
			MCDB	29.8	29.2	28.5	27.2	22.8	23.4	22.2	26.1	27.1	29.0	29.7	28.7
2%		WB	23.7	23.8	22.4	19.7	16.9	15.6	14.5	15.0	17.3	19.3	21.0	22.7	
		MCDB	29.1	29.1	27.7	27.2	23.2	22.3	21.9	25.1	27.9	26.7	28.6	28.5	
5%		WB	22.9	23.1	21.4	18.0	15.5	14.1	12.9	13.5	16.1	18.1	20.1	21.9	
		MCDB	29.0	28.7	27.7	27.2	23.6	19.7	20.7	24.7	28.3	28.2	28.3	28.6	
10%		WB	22.1	22.4	20.2	16.7	14.3	12.5	11.6	12.3	15.0	17.1	19.2	21.2	
		MCDB	29.6	28.6	29.0	27.4	22.7	18.9	20.2	22.9	28.5	28.6	28.5	28.7	
Mean Daily Temperature Range		5% DB	MDBR	14.1	14.0	14.6	15.9	15.3	15.1	16.1	17.1	17.0	16.2	15.3	14.2
			MCDBR	16.1	16.5	16.5	17.7	18.0	17.3	18.9	19.0	18.4	18.1	17.3	16.8
	MCWBR		5.3	5.4	6.1	7.0	7.8	8.2	8.9	8.6	7.3	7.0	6.0	5.6	
	5% WB	MCDBR	11.3	10.5	10.9	13.9	14.2	13.3	15.4	15.8	15.6	13.9	13.6	11.9	
		MCWBR	4.1	3.7	4.3	5.8	6.5	6.8	7.8	7.4	6.5	5.5	4.6	4.3	
Clear-Sky Solar Irradiance	taub	0.362	0.354	0.337	0.316	0.296	0.283	0.283	0.296	0.342	0.346	0.362	0.361		
	taud	2.511	2.547	2.569	2.588	2.609	2.624	2.607	2.532	2.422	2.441	2.457	2.500		
	Ebn at Noon	982	975	965	945	925	920	931	951	944	972	975	983		
	Edh at Noon	114	108	101	91	81	77	80	94	115	119	120	116		
All-Sky Solar Radiation	RadAvg	7.63	7.33	6.57	5.71	4.62	4.15	4.44	5.48	6.43	7.21	7.45	7.39		
	RadStd	0.47	0.56	0.50	0.42	0.43	0.30	0.36	0.27	0.38	0.52	0.51	0.55		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page