

JERVOIS, Australia

WMO: 943270

Lat: 22.9494S

Lon: 136.1442E

Elev: 1079

StdP: 14.13

Time Zone: 9.50 (AUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.2	40.6	0.9	6.0	81.8	6.2	7.9	78.1	16.7	63.8	16.0	63.5	4.6	190	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.7	106.8	66.3	104.6	66.2	102.6	65.8	76.2	85.3	75.0	85.3	73.8	85.3	10.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.2	132.9	79.2	72.6	125.6	79.3	70.7	117.6	79.8	40.5	84.7	39.4	85.3	38.3	84.5	97.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.3	16.6	15.4	DB	33.4	110.0	2.1	2.6	31.8	111.9	30.6	113.4	29.4	114.9	27.9	116.8
			WB	30.0	82.2	2.8	6.7	28.0	87.1	26.3	91.0	24.7	94.8	22.7	99.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.5	87.7	85.6	81.9	73.9	64.4	57.8	57.4	61.0	69.3	76.4	82.1	85.6	(6)
	DBStd	12.47	5.32	4.95	5.80	6.00	5.97	5.75	5.37	6.59	7.70	7.14	6.10	6.34	(7)
	HDD50	4	0	0	0	0	0	2	2	0	0	0	0	0	(8)
	HDD65	779	0	0	1	8	85	230	244	165	40	5	1	0	(9)
	CDD50	8591	1170	997	990	717	447	236	231	340	579	818	962	1104	(10)
	CDD65	3890	705	577	525	275	67	14	8	39	170	358	513	639	(11)
	CDH74	56336	10810	8561	7264	3349	820	193	212	740	2604	5061	7210	9512	(12)
	CDH80	33077	6979	5271	4199	1561	232	44	34	258	1279	2852	4339	6029	(13)
(14) Wind	WSAvg	8.0	8.7	8.7	8.7	7.8	7.2	7.1	6.8	7.6	8.1	8.4	8.5	8.7	(14)
(15) Precipitation	PrecAvg	11.2	1.9	2.4	1.2	0.7	0.8	0.4	0.6	0.3	0.2	0.6	0.9	1.3	(15)
	PrecMax	30.6	9.5	11.2	7.4	7.5	6.2	3.6	5.8	4.6	1.5	1.9	3.1	7.7	(16)
	PrecMin	4.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	5.9	2.6	3.0	1.8	1.5	1.4	0.7	1.2	0.8	0.4	0.6	0.9	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.8	107.1	104.3	98.0	89.0	85.6	84.1	92.0	100.2	104.3	106.9	110.4	(19)
		MCWB	68.0	66.1	66.5	65.2	60.6	60.5	57.2	59.4	61.1	63.2	64.1	65.9	(20)
	2%	DB	106.8	104.2	101.2	94.5	85.8	79.2	79.4	87.0	95.6	100.5	103.5	106.4	(21)
		MCWB	67.7	66.6	65.9	63.7	59.7	57.9	54.6	57.5	60.2	61.8	64.0	65.5	(22)
	5%	DB	104.4	101.8	98.7	91.9	82.5	74.7	75.7	81.8	92.0	97.5	100.6	103.7	(23)
		MCWB	67.5	66.3	65.4	62.4	58.4	55.8	53.6	54.9	59.1	61.4	63.6	65.8	(24)
	10%	DB	101.9	99.3	96.1	88.8	78.8	70.5	71.9	77.3	87.9	94.1	97.8	100.9	(25)
		MCWB	67.0	66.5	65.0	61.3	57.1	53.7	52.5	53.0	57.3	60.6	62.9	65.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.9	77.9	76.2	72.6	67.4	63.8	63.1	63.5	68.9	70.2	73.4	76.6	(27)
		MCDB	87.7	86.1	83.1	84.3	74.3	77.2	73.1	81.4	76.5	81.9	83.0	84.5	(28)
	2%	WB	76.2	75.9	73.6	69.5	63.9	61.1	59.0	59.8	64.5	68.2	71.1	74.4	(29)
		MCDB	86.0	85.3	84.5	81.9	77.7	72.2	70.5	81.0	81.9	81.2	85.9	84.4	(30)
	5%	WB	75.0	74.9	71.6	66.4	61.1	58.5	55.9	56.7	61.9	66.3	69.7	72.9	(31)
		MCDB	85.7	85.6	85.4	82.6	77.0	69.8	71.4	79.8	84.5	85.4	85.0	84.6	(32)
	10%	WB	73.7	73.8	69.6	63.8	58.9	55.7	53.6	54.0	59.4	64.0	68.2	71.5	(33)
		MCDB	85.8	85.8	86.4	82.3	75.2	67.0	69.3	74.7	85.3	86.2	83.9	86.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	23.7	23.7	23.9	25.7	24.8	24.0	27.2	28.9	29.7	28.6	26.3	24.3	(35)
		MCDBR	27.2	28.3	28.0	29.4	30.0	29.2	33.4	35.2	34.5	33.3	31.1	29.1	(36)
		MCWBR	8.2	8.6	9.7	10.5	12.3	12.7	15.2	15.5	13.3	12.0	10.3	9.7	(37)
	5% WB	MCDBR	19.3	18.1	19.7	21.6	23.6	22.5	26.8	29.2	25.1	24.8	22.9	19.8	(38)
		MCWBR	6.2	6.0	7.6	8.2	10.7	10.2	13.0	13.6	11.9	9.7	7.2	6.3	(39)
(40) Clear-Sky Solar Irradiance	taub		0.381	0.371	0.354	0.330	0.311	0.296	0.296	0.309	0.360	0.367	0.378	0.383	(40)
	taud		2.440	2.475	2.494	2.515	2.530	2.552	2.533	2.465	2.348	2.350	2.383	2.412	(41)
	Ebn at Noon		305	305	301	295	289	287	291	298	294	302	305	305	(42)
	Edh at Noon		39	37	35	31	28	26	28	32	39	41	41	40	(43)
(44) All-Sky Solar Radiation	RadAvg		2385	2346	2123	1853	1500	1348	1453	1762	2050	2313	2400	2376	(44)
	RadStd		152	140	146	133	107	78	104	76	135	154	137	177	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page