

TERRITORY GRAPE FARM, Australia

WMO: 943280

Lat: 22.4517S

Lon: 133.6378E

Elev: 1860

StdP: 13.73

Time Zone: 9.50 (AUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	37.4	39.9	7.6	8.7	69.9	11.3	10.5	69.8	19.9	63.6	18.2	62.0	4.7	170	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.3	103.9	65.4	101.7	65.5	99.9	65.6	84.5	86.0	76.5	83.3	74.4	82.9	9.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
84.2	192.1	85.6	75.2	141.6	78.6	72.5	129.2	77.4	50.9	85.4	41.7	84.1	39.4	82.0	98.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.6	17.8	16.2	DB	32.8	107.3	2.4	2.4	31.1	109.0	29.7	110.3	28.3	111.7	26.6	113.4	(4)
(5)			WB	29.0	77.4	2.6	2.3	27.1	79.0	25.6	80.4	24.1	81.6	22.2	83.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.6	84.7	83.8	80.9	73.1	64.0	57.2	57.5	61.0	69.6	76.0	80.7	83.8	(6)	
	DBStd	11.51	4.75	4.18	5.01	5.52	5.74	5.38	5.05	5.78	6.74	6.20	5.57	5.60	(7)	
	HDD50	5	0	0	0	0	0	3	2	0	0	0	0	0	(8)	
	HDD65	764	0	0	0	8	88	244	236	152	31	4	1	0	(9)	
	CDD50	8266	1075	947	959	693	435	217	235	342	588	806	921	1048	(10)	
	CDD65	3553	610	527	494	252	58	9	5	30	169	344	472	583	(11)	
	CDH74	48820	8528	7174	6392	3028	723	141	198	693	2524	4815	6415	8189	(12)	
	CDH80	27181	5141	4202	3539	1349	178	24	17	190	1151	2662	3736	4992	(13)	
(14) Wind	WSAvg	7.9	8.8	8.6	8.3	8.0	6.9	6.6	6.7	7.6	8.0	8.2	8.5	8.4	(14)	
(15) Precipitation	PrecAvg	10.9	2.5	2.2	0.7	0.7	0.9	0.4	0.4	0.2	0.4	0.7	1.0	2.2	(15)	
	PrecMax	16.7	9.8	12.5	4.5	5.0	5.1	1.9	1.5	1.7	3.4	2.7	3.9	8.6	(16)	
	PrecMin	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	(17)	
	PrecStd	3.5	2.3	3.0	1.2	1.3	1.4	0.6	0.4	0.4	0.7	0.7	0.9	1.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.8	104.3	102.6	96.0	88.3	83.5	82.1	89.5	96.9	101.5	103.7	107.6	(19)	
		MCWB	67.1	65.5	66.8	64.4	61.0	64.2	58.2	61.2	63.2	61.5	63.8	65.6	(20)	
	2%	DB	103.3	101.3	99.5	92.8	84.6	77.9	78.8	84.9	93.0	98.8	101.2	104.1	(21)	
		MCWB	66.6	65.6	66.7	63.3	59.3	57.9	55.7	59.6	61.5	61.5	63.5	65.1	(22)	
	5%	DB	101.0	99.3	97.2	90.6	81.6	73.9	76.0	81.3	90.4	96.3	98.7	101.2	(23)	
		MCWB	67.5	66.0	67.2	63.0	58.3	54.9	54.6	57.4	60.6	61.0	63.8	65.6	(24)	
	10%	DB	98.4	97.1	94.6	87.9	78.1	70.3	72.5	77.6	87.2	93.3	96.1	98.5	(25)	
		MCWB	67.3	66.3	66.5	62.5	57.9	53.0	52.8	55.0	59.0	60.7	63.1	66.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	86.1	89.8	93.9	87.3	73.2	67.6	63.6	79.2	85.1	76.6	73.2	76.9	(27)	
		MCDB	87.0	90.6	94.8	88.0	73.3	70.7	72.5	80.2	86.7	81.6	87.7	85.0	(28)	
	2%	WB	76.6	75.9	84.7	75.4	65.4	62.0	60.0	66.6	67.5	69.0	71.0	74.0	(29)	
		MCDB	84.9	83.8	86.4	76.5	75.8	71.3	73.2	71.6	78.0	80.7	86.1	83.6	(30)	
	5%	WB	75.1	74.3	74.4	68.1	61.9	58.7	56.7	60.3	63.5	66.7	69.5	72.9	(31)	
		MCDB	83.2	83.1	81.9	77.1	75.2	68.7	72.3	75.8	81.3	80.5	83.6	83.6	(32)	
	10%	WB	73.8	73.1	71.9	64.8	59.4	55.4	54.2	56.6	60.7	64.6	68.0	71.8	(33)	
		MCDB	83.5	82.7	81.6	81.6	74.7	68.0	69.3	75.9	83.0	82.1	83.0	84.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.3	23.5	23.9	26.3	25.5	26.2	28.8	30.1	29.8	29.2	26.4	24.6	(35)	
		MCDBR	28.0	28.0	27.8	29.1	29.5	29.6	33.0	34.6	33.0	34.2	30.5	29.1	(36)	
	5% WB	MCWBR	8.3	8.9	10.7	11.1	12.5	14.1	15.5	17.5	13.7	12.7	10.3	9.2	(37)	
		MCWBR	18.0	17.9	20.0	21.7	23.0	24.2	28.2	28.3	25.3	23.6	22.4	20.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.360	0.356	0.340	0.318	0.303	0.286	0.287	0.298	0.351	0.358	0.366	0.367	(40)	
		taud	2.544	2.560	2.582	2.592	2.591	2.620	2.594	2.528	2.405	2.412	2.454	2.503	(41)	
	Ebn at Noon		312	309	306	300	292	292	295	302	298	305	308	310	(42)	
		Edh at Noon	35	34	32	29	27	25	26	30	37	39	38	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2357	2292	2081	1843	1514	1379	1471	1784	2057	2282	2355	2311	(44)	
	RadStd		144	158	153	128	136	84	117	79	121	156	155	157	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page