

MOUNT ISA, Australia

WMO: 943320

Lat: 20.6778S

Lon: 139.4875E

Elev: 1118

StdP: 14.11

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.3	44.1	6.0	7.8	79.9	11.5	10.3	74.8	20.4	65.2	18.8	65.4	1.8	180	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	23.9	104.3	67.7	102.4	67.5	100.5	67.3	77.1	85.0	76.3	84.8	75.5	84.5	10.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.4	138.9	79.1	74.5	134.5	78.8	73.5	129.8	78.6	41.5	84.9	40.7	84.1	39.9	84.1	90.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.8	18.0	16.4	DB	34.3	107.8	2.8	2.8	32.2	109.8	30.6	111.4	29.0	113.0	27.0	115.1	(4)
(5)			WB	30.0	79.7	2.5	2.7	28.2	81.6	26.8	83.2	25.4	84.7	23.6	86.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.1	85.5	84.5	82.3	77.6	69.3	63.6	62.6	65.5	73.3	80.1	83.7	86.0		
	DBStd	9.87	4.54	4.08	3.81	4.52	5.47	5.41	4.95	5.48	5.38	5.29	4.44	4.78		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	286	0	0	0	1	22	91	108	60	4	0	0	0		
	CDD50	9533	1101	967	1003	829	597	407	389	482	699	932	1010	1117		
	CDD65	4345	636	547	538	380	154	48	32	77	253	468	560	652		
	CDH74	58746	8585	7150	6723	4435	1700	636	652	1416	3711	6531	7872	9335		
	CDH80	32237	5040	4031	3608	2129	546	130	129	466	1890	3788	4731	5749		
(14) Wind	WSAvg	8.1	8.1	8.0	8.0	7.9	8.0	8.0	7.6	7.9	8.0	8.6	8.5	8.4		
(15) Precipitation	PrecAvg	18.1	4.6	3.9	2.4	0.2	0.5	0.2	0.2	0.2	0.2	0.7	1.3	2.8		
	PrecMax	37.0	20.7	9.4	11.5	1.9	6.9	1.6	2.6	1.7	2.7	3.6	7.3	10.6		
	PrecMin	6.7	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	8.7	4.6	2.8	2.7	0.4	1.1	0.4	0.6	0.3	0.6	0.9	1.5	2.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.4	104.6	102.0	97.0	91.6	87.0	87.2	92.3	98.8	103.7	105.7	107.6		
		MCWB	69.1	68.3	68.4	66.7	64.5	62.5	62.6	62.4	63.8	65.2	66.2	67.9		
	2%	DB	103.1	101.7	98.8	94.5	87.9	83.6	83.4	88.2	95.7	100.6	102.6	104.5		
		MCWB	69.4	69.2	68.5	65.9	63.0	61.9	59.9	60.8	62.8	64.1	65.8	67.6		
	5%	DB	100.6	99.0	96.5	92.5	85.7	80.9	80.7	85.2	93.2	98.3	100.4	102.2		
		MCWB	69.2	68.9	68.3	65.1	62.4	60.1	58.0	58.8	61.9	63.7	65.5	67.6		
	10%	DB	98.2	96.6	94.2	90.2	82.9	77.8	77.8	82.0	90.4	95.5	98.0	99.7		
		MCWB	69.3	69.4	67.9	64.5	61.0	58.4	56.2	56.8	60.6	62.9	65.6	67.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.2	78.0	77.4	74.4	70.1	66.1	67.1	66.0	69.6	72.7	75.1	77.1		
		MCDB	85.6	85.5	84.5	83.6	82.5	81.6	79.6	85.2	84.8	83.9	85.4	85.9		
	2%	WB	77.1	76.9	76.0	72.3	67.9	64.2	63.6	67.2	70.3	73.5	75.7			
		MCDB	85.3	84.7	83.5	83.6	80.2	78.8	78.1	82.7	84.6	85.6	85.1	85.9		
	5%	WB	76.3	76.1	74.8	70.2	65.4	62.4	60.6	61.0	65.4	68.7	72.4	74.8		
		MCDB	85.0	84.5	82.8	83.6	80.0	76.7	75.9	81.1	85.3	86.0	85.5	85.8		
	10%	WB	75.5	75.3	73.7	68.2	63.4	60.3	58.1	58.6	63.3	67.1	71.2	74.0		
		MCDB	84.5	84.4	82.5	83.3	79.1	74.9	74.6	79.1	85.6	86.3	85.6	85.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.5	21.2	21.7	23.7	25.1	25.8	28.4	30.3	30.9	28.2	26.0	23.9		
		MCDBR	26.3	26.7	26.4	27.1	28.3	30.5	34.3	36.0	35.3	33.1	31.4	29.2		
	5% WB	MCWBR	8.0	8.1	8.8	10.1	11.7	14.1	16.2	16.2	14.5	12.4	11.0	10.2		
		MCWBR	18.9	18.4	17.6	20.8	21.7	25.5	27.4	30.8	27.7	26.0	23.5	21.3		
(40) Clear-Sky Solar Irradiance	taub		0.396	0.392	0.368	0.346	0.336	0.317	0.315	0.330	0.370	0.385	0.408	0.410		
	taud		2.455	2.455	2.505	2.516	2.484	2.511	2.494	2.428	2.344	2.328	2.325	2.369		
	Ebn at Noon		301	298	298	292	282	287	293	292	297	295	295	297		
	Edn at Noon		38	38	35	32	30	28	30	34	40	43	43	42		
(44) All-Sky Solar Radiation	RadAvg		2140	2169	2029	1844	1554	1419	1537	1830	2114	2316	2312	2253		
	RadStd		222	167	169	143	95	90	77	67	127	162	120	194		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page