

MOUNT ISA, Australia

WMO: 943320

Lat: 20.6778S

Lon: 139.4875E

Elev: 341

StdP: 97.30

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.6	6.7	-14.5	1.1	26.6	-11.4	1.5	23.8	9.1	18.4	8.4	18.6	0.8	180	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	13.3	40.2	19.9	39.1	19.7	38.1	19.6	25.0	29.5	24.6	29.3	24.2	29.2	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.8	26.2	23.6	19.2	26.0	23.0	18.5	25.9	78.6	29.4	76.7	28.9	75.0	28.9	32.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	8.1	7.3	DB 1.3	42.1	1.6	1.6	0.1	43.2	-0.8	44.1	-1.7	45.0	-2.8	46.1		
(5)			WB -1.1	26.5	1.4	1.5	-2.1	27.6	-2.9	28.5	-3.7	29.3	-4.7	30.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.5	29.7	29.2	28.0	25.4	20.7	17.5	17.0	18.6	22.9	26.7	28.7	30.0
	DBStd	5.48	2.52	2.27	2.12	2.51	3.04	3.01	2.75	3.04	2.99	2.94	2.47	2.65
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	159	0	0	0	1	12	51	60	33	2	0	0	0
	CDD10.0	5296	612	537	557	461	332	226	216	268	388	518	561	621
	CDD18.3	2414	353	304	299	211	86	27	18	43	141	260	311	362
	CDH23.3	32637	4769	3972	3735	2464	944	353	362	787	2062	3628	4373	5186
CDH26.7	17909	2800	2239	2004	1183	303	72	72	259	1050	2104	2628	3194	
Wind	WSAvg	3.6	3.6	3.6	3.6	3.5	3.6	3.6	3.4	3.5	3.6	3.8	3.8	3.7
Precipitation	PrecAvg	461	116	99	62	5	12	5	6	4	6	19	34	71
	PrecMax	939	525	240	291	47	176	41	67	42	69	91	185	270
	PrecMin	169	0	2	0	0	0	0	0	0	0	0	0	0
	PrecStd	221	118	70	68	10	27	9	14	8	14	23	37	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.3	40.3	38.9	36.1	33.1	30.6	30.7	33.5	37.1	39.8	40.9	42.0
		MCWB	20.6	20.2	20.2	19.3	18.1	16.9	17.0	16.9	17.7	18.5	19.0	20.0
	2%	DB	39.5	38.7	37.1	34.7	31.1	28.7	28.6	31.2	35.4	38.1	39.2	40.3
		MCWB	20.8	20.7	20.3	18.8	17.2	16.6	15.5	16.0	17.1	17.8	18.8	19.8
	5%	DB	38.1	37.2	35.8	33.6	29.9	27.1	27.1	29.6	34.0	36.8	38.0	39.0
		MCWB	20.6	20.5	20.2	18.4	16.9	15.6	14.4	14.9	16.6	17.6	18.6	19.8
	10%	DB	36.8	35.9	34.6	32.3	28.3	25.4	25.5	27.8	32.4	35.3	36.7	37.6
		MCWB	20.7	20.8	19.9	18.0	16.1	14.6	13.4	13.8	15.9	17.1	18.6	19.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.6	25.6	25.2	23.6	21.2	18.9	19.5	18.9	20.9	22.6	24.0	25.1
		MCDB	29.8	29.7	29.1	28.6	28.1	27.6	26.4	29.6	29.3	28.8	29.7	29.9
	2%	WB	25.1	24.9	24.5	22.4	19.9	17.9	17.6	17.5	19.6	21.3	23.1	24.3
		MCDB	29.6	29.3	28.6	28.7	26.8	26.0	25.6	28.2	29.2	29.8	29.5	29.9
	5%	WB	24.6	24.5	23.8	21.2	18.6	16.9	15.9	16.1	18.6	20.4	22.4	23.8
		MCDB	29.4	29.2	28.2	28.7	26.7	24.8	24.4	27.3	29.6	30.0	29.7	29.9
	10%	WB	24.1	24.1	23.2	20.1	17.4	15.7	14.5	14.8	17.4	19.5	21.8	23.3
		MCDB	29.2	29.1	28.0	28.5	26.2	23.8	23.6	26.2	29.8	30.2	29.8	29.8
Mean Daily Temperature Range	5% DB	MDBR	11.9	11.8	12.1	13.1	13.9	14.3	15.8	16.8	17.2	15.7	14.4	13.3
		MCDBR	14.6	14.8	14.7	15.1	15.7	16.9	19.1	20.0	19.6	18.4	17.5	16.2
		MCWBR	4.4	4.5	4.9	5.6	6.5	7.8	9.0	9.0	8.1	6.9	6.1	5.6
	5% WB	MCDBR	10.5	10.2	9.8	11.5	12.1	14.2	15.2	17.1	15.4	14.4	13.1	11.8
MCWBR		3.2	3.3	3.5	4.6	5.7	6.8	7.7	7.9	6.5	6.1	4.4	3.8	
Clear-Sky Solar Irradiance	taub		0.396	0.392	0.368	0.346	0.336	0.317	0.315	0.330	0.370	0.385	0.408	0.410
	taud		2.455	2.455	2.505	2.516	2.484	2.511	2.494	2.428	2.344	2.328	2.325	2.369
	Ebn at Noon		949	940	939	920	890	890	904	923	922	936	931	936
	Edh at Noon		121	119	109	100	95	89	93	107	126	134	137	132
All-Sky Solar Radiation	RadAvg		6.75	6.84	6.39	5.81	4.90	4.47	4.84	5.77	6.66	7.30	7.29	7.10
	RadStd		0.70	0.53	0.53	0.45	0.30	0.28	0.24	0.21	0.40	0.51	0.38	0.61

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page