

TREPELL, Australia

WMO: 943380

Lat: 21.8400S

Lon: 140.8925E

Elev: 876

StdP: 14.24

Time Zone: 10.00 (E10)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 42.2	(c) 44.4	(d) 10.4	(e) 9.7	(f) 62.3	(g) 13.0	(h) 11.0	(i) 64.6	(j) 19.9	(k) 70.7	(l) 18.2	(m) 68.7	(n) 6.6	(o) 220	(p) 0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 12	(b) 23.3	(c) 105.7	(d) 67.7	(e) 103.8	(f) 67.7	(g) 101.9	(h) 67.4	(i) 76.0	(j) 86.0	(k) 75.1	(l) 85.4	(m) 74.3	(n) 85.4	(o) 11.2	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.7	129.5	79.6	72.7	125.1	79.3	71.5	120.0	79.4	40.2	86.0	39.3	85.2	38.6	84.5	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.0	(b) 18.8	(c) 17.0	(e) 38.2	(f) 109.1	(g) 2.3	(h) 2.7	(i) 36.5	(j) 111.0	(k) 35.2	(l) 112.6	(m) 33.9	(n) 114.1	(o) 32.2	(p) 116.1		
(4) 21.0	(5) 18.8	(6) 17.0	(7) 38.2	(8) 109.1	(9) 2.3	(10) 2.7	(11) 36.5	(12) 111.0	(13) 35.2	(14) 112.6	(15) 33.9	(16) 114.1	(17) 32.2	(18) 116.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.5	86.9	85.5	83.3	77.5	69.4	62.3	61.9	65.4	73.3	80.6	84.4	87.7
	DBStd	10.90	5.35	5.03	4.92	5.05	6.00	5.98	5.77	6.14	6.78	6.10	5.29	5.15
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	364	0	0	0	2	28	123	130	70	10	1	0	0
	CDD50	9660	1145	994	1031	824	602	370	371	476	699	947	1032	1169
	CDD65	4548	680	574	566	375	165	42	36	82	259	483	582	704
	CDH74	61893	9735	7920	7396	4365	1639	412	465	1208	3387	6631	8252	10483
	CDH80	35217	5946	4684	4156	2133	514	61	68	403	1670	3868	5049	6665
Wind	WSAvg	9.2	10.1	10.1	9.6	8.6	8.3	8.4	8.2	8.7	9.2	10.0	9.8	10.1
Precipitation	PrecAvg	15.4	3.6	3.3	1.8	0.6	0.6	0.5	0.2	0.2	0.3	0.6	1.3	2.5
	PrecMax	33.7	17.2	7.7	14.8	5.7	3.1	4.4	1.5	1.2	3.5	2.8	4.3	11.4
	PrecMin	4.8	0.3	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
	PrecStd	7.2	3.8	2.5	2.9	1.2	0.8	0.9	0.4	0.3	0.7	0.7	1.1	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.4	106.9	104.0	97.5	92.3	84.9	85.1	93.3	99.4	104.2	106.3	108.6
		MCWB	70.2	67.9	69.4	66.9	63.8	61.4	61.2	62.4	63.8	65.2	66.9	68.5
	2%	DB	104.7	102.8	100.7	94.8	87.7	81.8	81.8	88.4	95.7	101.2	103.5	105.8
		MCWB	68.9	68.9	68.4	65.9	63.0	60.8	58.8	59.7	62.5	64.4	66.2	67.4
	5%	DB	102.4	100.4	98.2	92.6	85.4	79.0	79.2	84.4	92.8	98.7	101.3	103.5
		MCWB	68.9	68.5	67.7	64.3	61.7	59.3	57.8	57.7	61.3	63.9	65.7	67.4
	10%	DB	99.6	98.1	95.6	90.6	82.8	75.9	76.3	80.9	89.6	95.8	98.9	101.2
		MCWB	68.9	68.5	67.4	63.7	60.6	57.4	56.3	56.1	60.0	62.9	65.5	67.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.4	76.3	76.2	71.9	69.4	64.8	66.7	65.4	69.0	70.3	73.3	75.6
		MCDB	87.0	87.6	85.7	86.4	82.2	79.0	76.6	84.9	85.9	87.4	88.2	86.7
	2%	WB	76.4	75.2	74.6	70.0	66.3	63.2	63.6	62.2	66.4	68.5	71.9	74.5
		MCDB	85.9	86.5	84.1	83.2	80.9	76.7	75.2	82.0	84.2	87.6	87.2	86.8
	5%	WB	75.6	74.3	73.6	68.4	64.4	61.4	60.5	59.7	64.1	67.1	70.8	73.6
		MCDB	85.2	86.1	83.7	83.4	80.4	74.3	74.4	79.6	86.1	88.1	87.2	87.4
	10%	WB	74.7	73.4	72.5	66.7	62.6	59.6	57.9	57.6	61.9	65.4	69.7	72.6
		MCDB	84.9	85.6	84.2	84.3	79.8	72.9	73.8	79.1	84.8	89.4	87.5	87.6
Mean Daily Temperature Range	5% DB	MDBR	20.2	21.5	21.6	24.3	24.4	24.4	26.3	28.3	28.0	27.3	25.6	23.3
		MCDBR	25.1	24.4	24.5	25.3	25.4	26.3	28.5	30.9	29.4	29.9	28.3	26.5
		MCWBR	8.5	7.4	8.7	9.9	11.0	12.7	14.1	14.6	13.4	12.2	10.7	9.6
	5% WB	MCDBR	16.7	18.1	16.6	20.9	21.7	21.5	23.6	26.9	24.4	23.6	23.2	19.8
MCWBR		4.9	5.3	5.2	7.7	9.8	10.4	12.2	13.0	11.5	9.8	7.6	6.2	
Clear-Sky Solar Irradiance	taub	0.383	0.377	0.357	0.341	0.330	0.312	0.311	0.323	0.365	0.374	0.389	0.395	
	taud	2.481	2.495	2.529	2.528	2.502	2.533	2.506	2.448	2.354	2.353	2.368	2.403	
	Ebn at Noon	305	303	301	293	283	283	287	294	293	300	301	302	
	Edh at Noon	37	36	34	31	30	27	29	33	39	41	42	41	
All-Sky Solar Radiation	RadAvg	2249	2252	2065	1830	1514	1360	1486	1794	2090	2340	2382	2332	
	RadStd	214	140	153	139	86	90	79	69	135	145	125	169	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page