

URANDANGI, Australia

WMO: 943440

Lat: 21.598S

Lon: 138.366E

Elev: 179

StdP: 99.19

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	5.9	-13.4	1.2	20.5	-11.3	1.5	20.3	9.1	22.4	8.3	20.0	1.2	150	0.413

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	41.9	20.5	40.8	20.5	39.7	20.4	26.1	32.1	25.5	31.3	25.0	30.7	4.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.3	27.9	24.2	19.5	27.7	23.5	18.8	27.8	82.1	32.0	79.5	31.2	77.3	30.4	34.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.9	7.1	DB	1.5	43.7	1.1	1.2	0.7	44.5	0.1	45.2	-0.5	45.9	-1.3	46.8	(4)
(5)			WB	-0.9	28.3	1.3	2.5	-1.8	30.1	-2.6	31.6	-3.3	33.0	-4.3	34.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.9	31.4	31.0	29.2	25.5	20.3	17.3	16.3	17.9	22.9	26.9	29.4	31.1	(6)	
	DBStd	6.41	2.72	2.52	2.61	3.05	3.35	3.57	3.22	3.58	3.91	3.72	3.29	3.27	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	221	0	0	0	1	19	62	80	52	6	1	0	0	(9)	
	CDD10.0	5436	662	587	596	464	320	220	196	246	387	523	581	654	(10)	
	CDD18.3	2614	404	354	338	216	81	32	17	39	143	264	331	396	(11)	
	CDH23.3	36168	5984	5129	4481	2468	818	332	281	595	1875	3556	4711	5938	(12)	
(13)	CDH26.7	21202	3782	3180	2573	1259	289	86	65	204	944	2083	2922	3814	(13)	
(14)	Wind	WSAvg	2.9	2.6	2.7	2.8	2.8	2.9	2.7	2.9	3.1	3.1	3.0	3.0	(14)	
(15) Precipitation	PrecAvg	314	67	65	36	13	13	7	9	5	7	15	26	45	(15)	
	PrecMax	820	440	271	176	135	138	100	123	36	45	92	97	362	(16)	
	PrecMin	78	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	166	80	68	46	27	25	16	25	9	10	23	28	63	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	42.4	40.8	37.7	33.3	31.2	30.7	33.3	38.1	40.8	42.3	43.6	(19)	
		MCWB	21.1	21.4	20.1	19.9	18.2	17.7	16.6	17.2	18.6	18.9	19.6	21.0	(20)	
	2%	DB	41.3	40.7	39.2	36.1	31.5	29.1	28.5	31.4	36.0	39.2	40.8	42.0	(21)	
		MCWB	21.3	21.2	20.6	19.0	17.2	17.0	14.9	16.4	17.9	18.4	19.4	20.2	(22)	
	5%	DB	40.1	39.5	37.6	34.6	29.9	27.1	26.5	29.3	34.4	37.4	39.4	40.6	(23)	
		MCWB	21.5	21.2	20.6	18.7	16.8	16.0	14.0	15.1	17.1	17.9	19.1	20.5	(24)	
	10%	DB	38.5	38.0	36.2	33.0	28.0	24.9	24.4	27.0	32.5	35.7	37.8	39.0	(25)	
		MCWB	21.5	21.2	20.5	18.2	16.0	14.8	13.1	14.2	16.2	17.4	19.0	20.7	(26)	
	0.4%	WB	27.2	26.9	25.6	23.8	21.8	19.2	18.1	19.2	21.6	23.5	24.7	26.2	(27)	
		MCDB	35.4	33.6	30.7	30.4	28.7	28.3	26.3	28.8	28.8	30.8	32.4	31.5	(28)	
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.1	26.0	24.9	22.2	19.6	18.1	16.5	17.9	19.9	21.8	23.5	25.2	(29)	
		MCDB	32.7	31.8	29.9	30.2	27.3	26.5	25.5	28.0	31.1	29.7	31.1	31.0	(30)	
	5%	WB	25.4	25.5	24.3	20.8	18.3	17.0	15.0	16.4	18.8	20.8	22.7	24.6	(31)	
		MCDB	31.5	31.1	29.7	29.9	26.4	25.4	24.6	27.3	30.8	30.3	30.6	30.9	(32)	
	10%	WB	24.8	25.0	23.4	19.6	17.1	15.7	13.5	14.9	17.6	19.7	22.0	23.9	(33)	
		MCDB	30.9	30.6	30.1	29.9	26.0	23.1	22.9	26.1	29.6	31.1	30.5	31.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	12.7	13.1	14.5	14.4	14.7	16.1	16.9	16.9	15.5	14.5	12.9	(35)	
		MCDBR	15.0	15.0	15.4	16.5	16.4	16.6	18.5	18.9	18.6	17.7	17.1	15.5	(36)	
		MCWBR	4.9	4.8	5.2	6.2	7.4	7.8	8.9	8.7	8.0	7.2	6.4	5.8	(37)	
	5% WB	MCDBR	10.8	10.6	10.1	12.1	12.7	13.7	15.4	15.8	14.1	13.5	12.1	10.1	(38)	
		MCWBR	3.6	3.1	3.7	4.9	6.0	6.9	7.7	7.7	6.3	5.8	4.3	3.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.391	0.388	0.369	0.346	0.331	0.314	0.315	0.327	0.369	0.383	0.397	0.404	(40)	
	taud		2.437	2.440	2.465	2.482	2.470	2.492	2.464	2.404	2.323	2.306	2.331	2.355	(41)	
	Ebn at Noon		954	944	936	918	892	890	900	922	921	938	942	942	(42)	
	Edh at Noon		123	121	113	103	96	90	95	109	128	136	136	134	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.18	7.17	6.52	5.81	4.82	4.37	4.72	5.66	6.58	7.30	7.49	7.36	(44)	
(45)	RadStd		0.60	0.48	0.46	0.40	0.28	0.24	0.26	0.24	0.40	0.49	0.34	0.59	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page