

PROSERPINE WHITSUNDAY COAST, Australia

WMO: 943650

Lat: 20.4925S

Lon: 148.5550E

Elev: 20

StdP: 101.08

Time Zone: 10.00 (E10)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.8	7.8	1.9	4.3	15.7	3.8	5.0	13.4	10.1	22.2	9.2	22.2	1.1	210	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.5	33.9	24.1	32.7	24.0	31.7	23.8	26.7	30.2	26.1	29.4	25.6	28.9	5.3	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.8	21.2	28.2	25.2	20.4	27.6	24.8	19.9	27.3	83.8	30.4	81.3	29.4	79.2	28.9	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.7	8.9	8.1	DB	2.7	36.7	1.7	1.4	1.4	37.6	0.4	38.4	-0.5	39.2	-1.8	40.2
			WB	2.1	27.7	1.8	0.9	0.8	28.3	-0.2	28.8	-1.2	29.3	-2.5	29.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.9	26.8	26.6	25.8	23.7	20.9	18.5	17.6	18.3	21.0	23.5	25.2	26.6	(6)
	DBStd	3.86	1.38	1.40	1.28	1.39	2.28	2.71	2.75	2.35	2.01	1.85	1.59	1.60	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	117	0	0	0	0	7	31	46	29	3	0	0	0	(9)
	CDD10.0	4694	521	465	489	412	338	256	236	257	331	418	457	514	(10)
	CDD18.3	1769	263	232	231	162	87	37	24	28	84	160	207	256	(11)
	CDH23.3	14113	2428	2039	1795	932	401	125	97	232	654	1246	1735	2429	(12)
	CDH26.7	4338	834	651	499	166	36	8	5	26	146	377	627	963	(13)
(14) Wind	WSAvg	3.7	3.9	3.9	4.1	4.2	3.6	3.4	3.3	3.3	3.5	3.9	3.8	3.9	(14)
(15) Precipitation	PrecAvg	1455	280	342	162	138	86	36	21	23	24	30	93	193	(15)
	PrecMax	2476	819	928	443	451	272	122	73	108	91	147	268	1077	(16)
	PrecMin	856	15	26	22	25	6	0	0	0	0	0	1	46	(17)
	PrecStd	508	219	241	121	125	71	31	20	29	27	38	88	229	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.7	34.8	32.9	30.8	29.2	27.8	27.3	29.0	32.0	33.8	34.5	35.7	(19)
		MCWB	25.0	25.6	25.0	23.1	21.4	20.4	19.4	19.3	19.5	21.5	22.8	24.3	(20)
	2%	DB	32.9	32.6	31.2	29.3	27.6	25.9	25.5	27.2	30.0	31.5	32.6	33.8	(21)
		MCWB	25.2	25.4	24.7	22.7	20.9	19.8	18.7	18.4	19.9	22.0	22.9	24.0	(22)
	5%	DB	31.7	31.2	30.2	28.3	26.5	24.7	24.2	25.8	28.2	30.1	31.2	32.4	(23)
		MCWB	24.8	25.1	24.2	22.5	20.6	19.3	18.1	18.1	19.8	21.6	22.5	23.7	(24)
	10%	DB	30.5	30.1	29.2	27.6	25.6	23.7	23.2	24.4	26.9	28.8	30.1	31.2	(25)
		MCWB	24.4	24.8	23.8	22.2	20.2	18.7	17.7	17.8	19.6	21.2	22.2	23.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.7	26.8	25.7	24.1	22.7	22.0	22.0	23.3	25.3	25.7	26.8	(27)
		MCDB	31.2	31.6	29.8	28.0	26.6	25.2	24.1	25.2	27.5	28.4	29.9	31.0	(28)
	2%	WB	26.6	26.7	26.0	24.6	22.7	21.4	20.7	20.9	22.3	23.7	24.7	25.9	(29)
		MCDB	30.1	30.2	29.2	26.9	25.4	24.1	23.5	24.3	26.5	27.7	29.0	29.9	(30)
	5%	WB	26.0	26.1	25.4	23.7	21.8	20.6	19.7	20.0	21.6	22.8	24.0	25.2	(31)
		MCDB	29.3	29.1	28.4	26.6	25.1	23.3	22.5	23.5	25.6	27.6	28.6	29.2	(32)
	10%	WB	25.5	25.6	24.8	23.0	21.1	19.7	19.0	19.1	20.8	22.2	23.3	24.6	(33)
		MCDB	28.7	28.4	27.7	26.1	24.4	22.4	21.7	22.6	24.6	26.9	27.9	28.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	7.0	7.2	8.0	9.8	10.4	11.8	13.0	12.3	11.0	9.9	9.1	(35)
		MCDBR	9.6	9.0	8.8	9.3	10.5	10.7	12.6	15.3	15.3	13.3	12.1	11.5	(36)
	5% WB	MCWBR	3.3	3.5	3.6	4.1	5.1	5.6	6.7	7.6	6.7	5.1	4.2	3.5	(37)
		MCWBR	7.8	7.6	7.2	7.3	8.5	8.4	9.3	11.3	10.9	10.9	9.9	8.9	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.405	0.399	0.386	0.362	0.347	0.331	0.319	0.328	0.360	0.386	0.394	0.404	(40)
		taud	2.499	2.518	2.540	2.592	2.587	2.623	2.640	2.596	2.499	2.450	2.469	2.471	(41)
	Ebn at Noon	Ebn at Noon	940	934	922	906	882	880	905	927	933	935	944	942	(42)
		Edh at Noon	116	112	105	93	87	80	81	91	108	118	119	119	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.19	5.93	5.50	4.91	4.26	3.83	4.32	5.14	6.21	6.87	6.94	6.90	(44)
	RadStd	RadStd	0.56	0.69	0.57	0.50	0.28	0.38	0.32	0.35	0.44	0.41	0.88	0.74	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page