

SAMUEL HILL, Australia

WMO: 943700

Lat: 22.743S

Lon: 150.658E

Elev: 103

StdP: 14.64

Time Zone: 10.00 (E10)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.2	42.3	32.4	27.0	55.2	36.5	31.8	52.9	16.2	67.8	14.7	67.9	1.0	170	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.9	90.2	75.2	88.4	74.6	86.8	73.9	78.7	84.2	77.7	83.1	76.9	82.2	10.6	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.4	142.9	80.7	76.4	138.1	80.1	75.4	133.6	79.4	42.4	84.6	41.4	82.8	40.5	82.5	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	14.8	13.8	35.4	94.3	3.3	2.4	33.1	96.0	31.1	97.4	29.2	98.8	26.8	100.5		
(5)			34.6	80.3	3.2	1.2	32.3	81.1	30.4	81.8	28.6	82.5	26.3	83.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.1	78.5	78.3	76.4	72.1	66.2	62.3	60.9	61.2	65.7	70.1	73.6	77.0
	DBStd	7.43	2.60	2.38	2.58	2.69	4.23	4.85	4.89	4.36	3.83	3.85	3.28	2.97
	HDD50	1	0	0	0	0	0	0	1	0	0	0	0	0
	HDD65	458	0	0	0	1	38	107	142	131	35	4	0	0
	CDD50	7353	882	794	818	664	503	368	338	347	470	624	708	837
	CDD65	2335	417	374	353	215	76	25	14	13	55	163	258	372
	CDH74	17313	3654	3073	2375	970	240	48	44	118	500	1138	1996	3157
	CDH80	4331	1118	857	458	93	9	0	0	3	49	205	520	1019
Wind	WSAvg	5.9	7.1	7.1	7.3	6.2	5.2	4.8	4.8	4.5	5.0	6.1	6.2	6.7
Precipitation	PrecAvg	55.4	8.8	11.3	7.5	4.6	3.6	3.2	2.8	1.5	1.5	1.9	3.0	5.6
	PrecMax	105.8	24.5	29.3	17.2	7.7	10.6	8.4	11.2	5.4	5.5	4.4	9.2	24.1
	PrecMin	32.4	1.1	2.0	1.9	0.7	0.2	0.2	0.2	0.0	0.0	0.1	0.8	0.3
	PrecStd	18.8	6.1	8.7	5.2	1.9	2.4	2.3	3.0	1.6	1.5	1.2	2.5	5.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.0	91.2	89.0	85.4	81.2	77.8	77.7	79.8	83.8	86.8	89.9	92.7
		MCWB	75.9	77.0	76.4	72.7	69.8	66.7	65.2	66.5	68.2	69.3	71.9	73.5
	2%	DB	89.8	89.0	86.3	82.4	78.7	75.3	75.1	76.9	81.4	84.3	87.0	89.9
		MCWB	75.9	75.9	75.0	70.7	67.4	65.7	64.1	63.9	67.1	70.4	71.9	74.2
	5%	DB	87.8	87.1	84.3	80.7	76.6	73.1	72.8	75.0	79.2	82.4	85.0	87.7
		MCWB	75.1	75.3	74.1	70.5	66.8	65.0	63.3	63.3	66.0	69.6	71.0	73.5
	10%	DB	85.6	85.2	82.6	79.1	74.7	71.2	70.8	72.8	77.0	80.3	83.2	85.5
		MCWB	74.3	74.8	73.3	70.3	66.6	64.1	62.8	62.5	64.8	68.4	70.4	72.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	80.3	79.1	76.8	73.2	70.9	70.5	70.5	72.4	74.4	77.1	79.1
		MCDB	85.3	85.0	84.7	81.0	77.4	73.8	73.2	75.1	78.3	80.6	83.1	85.1
	2%	WB	78.4	78.9	77.5	74.6	71.1	69.0	68.0	68.2	70.5	73.0	74.9	77.3
		MCDB	84.3	83.6	82.5	78.3	75.6	72.0	72.0	74.1	76.1	79.8	81.6	83.3
	5%	WB	77.4	77.8	76.4	73.0	69.4	67.4	66.2	66.0	69.0	71.7	73.6	76.2
		MCDB	83.0	82.7	81.2	76.9	73.9	70.7	69.7	71.3	75.1	78.8	80.9	82.3
	10%	WB	76.4	76.7	75.4	71.9	68.2	66.1	64.5	64.3	67.5	70.4	72.3	75.0
		MCDB	82.1	81.8	79.8	76.6	72.5	69.6	68.4	70.0	74.1	77.2	79.8	81.3
Mean Daily Temperature Range	5% DB	MDBR	13.9	12.6	12.0	14.2	17.7	18.3	20.7	24.1	22.8	19.9	18.3	16.1
		MCDBR	18.5	17.7	15.5	18.3	20.5	20.5	22.6	27.0	26.0	22.5	22.2	21.4
		MCWBR	6.8	6.8	6.4	9.0	11.0	11.6	13.0	15.3	13.3	10.3	9.4	7.9
	5% WB	MCDBR	14.2	13.4	11.8	13.1	15.1	13.8	15.6	21.1	20.2	18.5	18.1	15.8
		MCWBR	6.1	5.8	5.5	7.2	9.1	8.7	10.0	13.1	11.2	9.0	8.0	6.9
Clear-Sky Solar Irradiance	taub	0.400	0.394	0.380	0.357	0.336	0.322	0.313	0.323	0.354	0.380	0.396	0.398	
	taud	2.506	2.530	2.556	2.600	2.609	2.658	2.653	2.609	2.509	2.471	2.454	2.487	
	Ebn at Noon	300	297	293	287	281	280	286	294	296	298	299	301	
	Edh at Noon	36	35	33	29	26	24	25	28	34	37	38	37	
All-Sky Solar Radiation	RadAvg	2074	1916	1744	1509	1299	1132	1283	1556	1896	2096	2186	2173	
	RadStd	135	209	144	130	69	102	95	104	131	127	220	212	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page