

CREAL REEF, Australia

WMO: 943710

Lat: 20.530S

Lon: 150.377E

Elev: 21

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 64.8	(c) 66.3	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 32.4	(k) 69.9	(l) 31.2	(m) 70.2	(n) 19.7	(o) 170	(p) 0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 2.6	(c) 84.1	(d) N/A	(e) 83.5	(f) N/A	(g) 83.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 12.2	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 32.6	(b) 30.0	(c) 27.9	(e) 62.3	(f) 85.8	(g) 1.3	(h) 1.7	(i) 61.3	(j) 87.0	(k) 60.5	(l) 88.0	(m) 59.8	(n) 88.9	(o) 58.8	(p) 90.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.0	80.6	81.2	80.2	78.1	74.9	72.0	70.3	70.6	72.6	74.9	77.2	79.5		
	DBStd	4.17	1.48	1.44	1.45	1.46	1.81	2.16	1.97	1.93	1.69	1.55	1.39	1.51		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	9480	948	874	937	842	771	659	630	640	677	773	815	914		
	CDD65	4005	483	454	472	392	306	209	165	175	227	308	365	449		
	CDH74	26831	5054	4970	4826	3103	1069	142	12	19	145	936	2382	4173		
	CDH80	2902	823	1048	648	61	0	0	0	0	0	0	13	309		
(14) Wind	WSAvg	16.6	16.6	16.8	19.0	19.3	17.9	17.8	16.9	15.0	14.2	14.8	15.1	15.5		
(15) Precipitation	PrecAvg	33.1	5.0	5.8	5.3	2.8	2.1	2.0	1.3	1.3	0.8	1.2	1.7	3.9		
	PrecMax	59.2	13.0	20.5	20.5	8.6	9.3	5.8	7.0	6.6	4.4	4.1	9.1	13.7		
	PrecMin	14.8	1.1	0.8	0.5	0.3	0.4	0.4	0.1	0.0	0.0	0.1	0.2	0.7		
	PrecStd	9.8	2.9	4.0	4.9	2.1	1.6	1.3	1.5	1.5	0.9	1.0	2.1	3.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.6	85.5	84.6	82.2	79.2	76.9	75.3	75.5	77.7	79.2	81.2	83.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	83.7	84.4	83.6	81.4	78.3	76.0	74.3	74.5	76.4	78.3	80.3	82.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	83.3	83.7	83.0	80.8	77.8	75.4	73.6	73.8	75.5	77.7	79.7	82.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	82.7	83.2	82.5	80.1	77.3	74.8	73.1	73.1	74.7	77.2	79.1	81.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.5	2.6	2.6	2.4	2.6	2.8	2.6	2.4	2.1	2.0	2.2	2.3		
		MCDBR	2.8	3.0	3.0	2.8	3.0	2.9	2.9	2.8	2.6	2.6	2.7	2.8		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.396	0.395	0.390	0.363	0.345	0.338	0.325	0.328	0.351	0.377	0.376	0.386		
	taud		2.563	2.578	2.575	2.636	2.644	2.655	2.671	2.652	2.565	2.516	2.558	2.567		
	Ebn at Noon		301	298	292	287	281	277	285	294	299	299	305	304		
	Edh at Noon		35	33	32	28	26	25	25	27	32	35	35	34		
(44) All-Sky Solar Radiation	RadAvg		2160	2004	1821	1629	1386	1223	1356	1646	2006	2223	2314	2305		
	RadStd		139	208	167	117	85	122	92	111	108	108	214	218		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page