

THANGOOL, Australia

WMO: 943760

Lat: 24.4936S

Lon: 150.5708E

Elev: 636

StdP: 14.36

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.5	38.2	20.3	15.6	59.9	24.8	19.3	55.5	17.5	67.9	15.9	67.8	2.7	100	0.344

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.3	96.5	70.8	94.0	70.7	91.8	70.3	76.4	86.7	75.3	85.7	74.4	84.7	7.6	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.9	129.2	80.0	72.6	123.8	79.6	71.4	118.6	79.5	40.4	87.0	39.3	85.4	38.4	84.8	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	15.7	14.0	DB	30.2	102.3	2.3	3.2	28.6	104.6	27.2	106.5	25.9	108.3	24.2	110.6	(4)
(5)			WB	28.2	79.0	2.3	1.9	26.5	80.4	25.1	81.5	23.8	82.6	22.1	84.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.6	79.5	78.6	76.4	70.7	63.8	59.1	57.9	59.7	65.3	71.2	75.3	78.4	(6)	
	DBStd	8.90	3.48	3.51	3.49	3.69	4.95	4.71	4.83	4.38	4.59	4.31	4.14	3.95	(7)	
	HDD50	5	0	0	0	0	0	1	3	1	0	0	0	0	(8)	
	HDD65	713	0	0	0	5	80	181	223	170	49	5	0	0	(9)	
	CDD50	7168	916	801	817	622	429	273	249	302	459	658	760	882	(10)	
	CDD65	2402	451	381	352	177	44	4	4	6	58	198	310	417	(11)	
	CDH74	24748	4764	3898	3256	1570	436	84	74	220	1023	2103	3039	4281	(12)	
	CDH80	10079	2276	1745	1292	405	42	2	1	14	266	750	1287	1999	(13)	
(14) Wind	WSAvg	5.2	6.1	5.8	5.5	4.9	4.4	4.4	4.3	4.6	5.2	5.6	5.7	5.8	(14)	
(15) Precipitation	PrecAvg	26.0	3.7	3.3	2.1	1.5	1.5	1.2	1.0	1.0	1.1	2.4	3.4	3.9	(15)	
	PrecMax	41.4	11.5	11.2	11.0	7.8	7.2	5.0	4.4	4.3	4.6	9.5	6.6	13.5	(16)	
	PrecMin	15.7	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.2	(17)	
	PrecStd	5.5	2.5	2.5	2.1	1.5	1.5	1.3	1.2	1.1	1.2	1.9	1.8	2.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.5	98.6	95.7	90.0	83.9	79.1	78.7	81.8	90.7	94.4	97.2	99.6	(19)	
		MCWB	72.4	71.5	70.6	68.2	64.6	63.4	61.3	61.5	63.7	67.1	69.5	70.9	(20)	
	2%	DB	96.0	94.4	92.1	86.9	81.1	76.8	75.8	78.8	86.2	90.1	92.7	95.2	(21)	
		MCWB	71.6	72.0	70.8	67.5	64.1	62.1	59.8	60.5	63.0	65.7	68.5	70.6	(22)	
	5%	DB	93.2	91.7	89.5	84.5	78.9	74.6	73.7	76.4	83.1	87.1	89.9	92.1	(23)	
		MCWB	71.2	72.2	70.9	67.3	63.4	60.8	58.8	58.9	61.6	65.6	68.4	70.5	(24)	
	10%	DB	90.5	89.1	87.1	82.3	76.6	72.1	71.5	74.1	80.2	84.3	87.1	89.4	(25)	
		MCWB	71.1	71.9	70.5	66.6	62.4	59.7	57.7	57.6	60.7	64.8	67.7	70.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.8	78.0	76.8	73.5	70.5	67.3	66.3	66.3	70.1	72.6	74.1	76.7	(27)	
		MCDB	89.3	88.1	84.6	83.1	78.0	74.2	73.9	76.1	76.9	85.6	86.5	87.8	(28)	
	2%	WB	76.1	76.5	75.2	71.3	67.7	64.4	63.6	64.0	67.2	70.0	72.5	74.8	(29)	
		MCDB	86.8	86.9	84.3	81.2	76.0	73.1	71.4	73.1	77.3	82.2	84.5	86.8	(30)	
	5%	WB	75.0	75.3	74.0	69.8	65.9	62.7	61.5	62.1	65.2	68.7	71.2	73.7	(31)	
		MCDB	85.7	85.0	83.0	79.8	75.1	71.7	69.8	71.8	76.9	80.5	83.2	85.3	(32)	
	10%	WB	73.9	74.1	72.7	68.4	64.3	61.0	59.6	60.2	63.5	67.3	70.0	72.6	(33)	
		MCDB	84.3	84.0	82.1	78.3	73.6	69.8	68.3	70.2	76.1	78.7	82.3	83.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	22.3	21.4	21.6	24.1	25.9	26.4	28.9	30.6	31.0	26.8	24.3	22.6	(35)	
		MCDBR	27.5	26.2	26.6	27.6	28.0	28.5	30.5	33.3	35.2	31.4	28.6	26.9	(36)	
	5% WB	MCWBR	7.8	7.9	8.8	11.1	13.1	14.7	15.8	16.2	15.0	11.2	8.9	7.7	(37)	
		MCWBR	20.6	20.3	19.5	22.8	22.0	24.0	23.8	27.8	27.4	23.8	22.7	20.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.382	0.372	0.352	0.332	0.311	0.302	0.295	0.309	0.345	0.372	0.382	0.390	(40)	
		taud	2.501	2.537	2.583	2.609	2.614	2.644	2.642	2.581	2.475	2.434	2.443	2.457	(41)	
	Ebn at Noon		305	304	301	294	288	284	291	297	298	300	303	303	(42)	
		Edh at Noon	36	35	31	28	26	24	24	29	35	38	39	38	(43)	
(44) All-Sky Solar Radiation	RadAvg		2134	1991	1772	1562	1317	1131	1275	1551	1881	2082	2188	2201	(44)	
	RadStd		154	196	136	129	71	82	97	104	152	161	230	225	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page