

GANNET CAY, AustraliaWMO: **943790**Lat: **21.980S**Lon: **152.473E**Elev: **28**StdP: **14.68**Time Zone: **10.00 (E10)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	63.9	65.3	N/A	N/A	N/A	N/A	N/A	N/A	32.4	69.1	31.1	69.1	18.6	180	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.7	83.5	N/A	82.8	N/A	82.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.1	30.6	28.5	61.3	85.7	1.6	1.4	60.2	86.7	59.3	87.6	58.4	88.4	57.2	89.4
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.2	79.9	80.3	79.4	77.2	74.4	71.5	69.9	69.8	71.5	73.9	76.4	78.6
	DBStd	4.14	1.53	1.57	1.55	1.48	1.89	2.29	2.19	1.83	1.70	1.65	1.54	1.65
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	2	0	0	0	0	0	1	1	0	0	0	0	0
	CDD50	9199	926	848	911	817	756	644	616	615	646	742	791	887
	CDD65	3725	461	428	446	367	291	194	152	150	196	277	341	422
	CDH74	22378	4477	4354	4176	2522	850	99	10	3	45	516	1798	3528
	CDH80	1633	487	610	339	24	1	0	0	0	0	0	4	168
(14) Wind	WSAvg	15.9	16.6	17.3	18.5	19.2	17.0	17.0	15.7	14.3	13.2	13.3	14.3	15.1
(15) Precipitation	PrecAvg	33.1	5.0	5.8	5.3	2.8	2.1	2.0	1.3	1.3	0.8	1.2	1.7	3.9
	PrecMax	59.2	13.0	20.5	20.5	8.6	9.3	5.8	7.0	6.6	4.4	4.1	9.1	13.7
	PrecMin	14.8	1.1	0.8	0.5	0.3	0.4	0.4	0.1	0.0	0.0	0.1	0.2	0.7
	PrecStd	9.8	2.9	4.0	4.9	2.1	1.6	1.3	1.5	1.5	0.9	1.0	2.1	3.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.7	85.1	83.6	81.7	79.8	76.5	75.1	74.5	76.3	78.8	80.7	83.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	83.1	83.7	82.8	80.8	78.2	75.7	74.1	73.5	75.2	77.7	79.9	82.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	82.6	83.0	82.3	80.1	77.5	75.2	73.4	72.8	74.4	77.0	79.2	81.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	82.0	82.5	81.7	79.5	76.9	74.6	72.7	72.2	73.7	76.3	78.5	81.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	2.4	2.7	2.7	2.6	2.9	3.2	3.1	2.9	2.6	2.5	2.4	2.6
		MCDBR	2.9	3.1	3.1	3.2	3.3	3.3	3.2	3.3	2.9	3.1	3.0	3.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.390	0.389	0.380	0.354	0.336	0.333	0.319	0.324	0.346	0.368	0.374	0.380
	taud		2.568	2.582	2.599	2.652	2.656	2.660	2.683	2.652	2.570	2.533	2.548	2.575
	Ebn at Noon		303	299	294	289	283	277	286	294	299	302	306	306
	Edh at Noon		34	33	31	28	25	24	24	27	32	35	35	34
(44) All-Sky Solar Radiation	RadAvg		2216	2046	1828	1609	1363	1180	1312	1621	1982	2204	2341	2321
	RadStd		111	236	165	109	79	102	80	95	89	117	192	178

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page