

SEVENTEEN SEVENTY, Australia

WMO: 943840

Lat: 24.157S

Lon: 151.887E

Elev: 47

StdP: 100.76

Time Zone: 10.00 (E10)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	13.0	-0.6	3.6	15.2	0.9	4.1	18.8	13.8	17.7	12.5	18.3	4.3	230	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.0	30.2	25.6	29.6	25.3	29.1	24.9	26.8	28.9	26.4	28.5	25.9	28.1	4.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.8	28.2	25.7	21.1	27.9	25.2	20.5	27.7	84.7	29.0	82.6	28.6	80.7	28.0	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.0	12.6	10.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.2	26.0	26.3	25.0	23.0	20.6	18.4	17.6	17.9	20.5	22.3	24.2	25.5
	DBStd	3.46	1.48	1.57	1.42	1.57	1.35	1.95	1.50	1.63	1.66	1.59	1.50	1.61
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	84	0	0	0	0	2	22	32	26	3	0	0	0
	CDD10.0	4469	496	456	464	391	327	252	235	246	314	381	426	481
	CDD18.3	1512	237	223	206	141	71	24	9	13	68	122	176	223
	CDH23.3	9308	2109	2032	1475	559	58	6	1	1	56	307	917	1788
(14) Wind	WSAvg	5.1	6.0	5.7	6.0	5.8	4.7	4.5	4.4	4.6	4.4	5.1	5.1	5.4
	PrecAvg	1060	165	185	125	91	71	59	37	39	42	55	70	125
	PrecMax	1876	611	552	362	388	179	179	124	143	158	143	165	497
	PrecMin	754	8	45	15	7	7	12	1	0	0	2	1	17
	PrecStd	248	121	124	98	85	48	51	39	37	44	31	43	89
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.7	31.4	30.0	28.6	25.4	24.0	23.1	23.1	25.3	27.5	29.2	30.5
		MCWB	26.3	26.1	25.3	24.1	20.0	20.2	18.3	18.0	20.0	22.3	22.7	24.9
	2%	DB	30.0	30.4	29.3	27.4	24.7	23.1	21.9	22.2	24.7	26.4	28.0	29.6
		MCWB	25.8	25.8	25.0	22.9	20.3	19.6	17.7	18.2	20.1	22.1	21.9	25.1
	5%	DB	29.4	29.7	28.6	26.6	24.1	22.2	21.2	21.6	24.1	25.7	27.4	29.0
		MCWB	25.4	25.3	24.5	22.4	20.0	19.0	17.1	17.9	19.8	21.5	21.6	24.9
	10%	DB	28.8	29.0	27.9	25.9	23.5	21.6	20.5	21.0	23.5	25.1	26.9	28.4
		MCWB	25.0	24.8	23.9	22.1	19.7	18.5	16.7	17.3	19.6	20.7	21.3	24.5
	0.4%	WB	27.6	27.3	27.1	25.7	23.0	22.2	20.6	20.6	22.8	24.3	25.1	26.9
		MCDB	29.6	29.9	28.7	27.5	24.1	23.4	21.7	21.9	23.9	26.1	27.1	28.8
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.8	26.7	26.2	24.3	22.2	20.8	19.4	19.6	21.9	23.6	24.2	26.4
		MCDB	28.9	29.2	28.1	26.3	23.5	22.2	20.7	21.1	23.1	25.3	26.4	28.4
	5%	WB	26.3	26.1	25.5	23.5	21.5	20.1	18.6	19.0	21.2	23.0	23.7	26.0
		MCDB	28.3	28.6	27.6	25.6	23.1	21.7	20.3	20.6	23.0	24.7	26.1	28.0
	10%	WB	25.8	25.7	24.7	22.8	20.8	19.4	17.8	18.5	20.7	22.2	23.0	25.4
		MCDB	27.9	28.1	27.0	25.0	22.8	21.0	19.8	20.1	22.6	24.2	25.9	27.6
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	5.0	5.2	5.5	5.7	5.6	6.1	6.0	5.7	5.1	5.0	4.9
		MCDBR	5.1	5.3	5.5	5.9	5.9	5.5	6.3	6.1	5.7	5.1	5.2	4.9
		MCWBR	2.9	2.6	2.9	3.5	3.7	3.8	4.3	4.2	3.4	3.2	2.8	2.9
	5% WB	MCDBR	4.8	4.8	4.6	5.1	4.7	4.5	5.4	5.0	4.7	4.6	4.4	4.3
		MCWBR	3.2	2.8	3.0	3.4	3.5	3.3	4.2	3.5	3.3	3.5	2.6	2.9
(40) Clear-Sky Solar Irradiance	taub		0.392	0.387	0.371	0.346	0.327	0.319	0.307	0.319	0.350	0.375	0.376	0.395
	taud		2.532	2.554	2.590	2.642	2.641	2.661	2.674	2.623	2.527	2.492	2.523	2.499
	Ebn at Noon		952	943	931	913	892	880	905	927	936	943	961	951
	Edh at Noon		112	107	99	87	79	75	76	87	103	113	112	116
(44) All-Sky Solar Radiation	RadAvg		6.66	6.13	5.44	4.78	4.03	3.48	3.94	4.83	5.87	6.45	6.88	6.88
	RadStd		0.47	0.64	0.46	0.38	0.22	0.28	0.30	0.33	0.42	0.47	0.63	0.67

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page