

LADY ELLIOT ISLAND, Australia

WMO: 943880

Lat: 24.1117S

Lon: 152.7161E

Elev: 4

StdP: 101.27

Time Zone: 10.00 (E10)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	15.5	3.1	4.7	17.5	4.7	5.3	17.7	13.8	19.7	12.5	20.4	3.9	210	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.8	30.2	25.0	29.7	24.6	29.2	24.3	26.7	28.5	26.1	28.2	25.6	27.8	5.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.7	27.8	25.5	20.7	27.5	24.9	19.9	27.2	84.0	28.6	81.1	28.3	78.8	27.9	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	11.7	10.8	DB	11.2	31.3	1.2	0.6	10.3	31.7	9.5	32.0	8.8	32.4	7.9	32.8	(4)
(5)			WB	8.1	28.0	0.9	1.2	7.5	28.8	7.0	29.5	6.5	30.2	5.9	31.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	26.8	26.8	26.3	24.5	21.9	20.1	19.4	19.9	21.7	23.1	24.5	26.0	(6)
(7)		DBStd	3.04	1.14	1.15	1.14	1.22	1.79	1.91	1.87	1.82	1.45	1.26	1.18	1.21	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	27	0	0	0	0	1	7	12	7	1	0	0	0	(9)
(10)		CDD10.0	4886	521	471	504	433	368	303	290	307	350	407	436	495	(10)
(11)		CDD18.3	1871	263	237	246	183	111	60	43	56	101	149	186	237	(11)
(12)		CDH23.3	10990	2396	2183	2036	873	167	19	9	21	123	398	921	1844	(12)
(13)		CDH26.7	1552	466	398	280	37	1	0	0	0	0	6	72	293	(13)
(14)	Wind	WSAvg	6.0	6.4	7.0	6.9	7.0	6.0	6.0	5.4	5.4	5.2	5.6	5.6	6.0	(14)
(15)	Precipitation	PrecAvg	1166	117	154	124	112	129	93	96	66	32	63	76	89	(15)
(16)		PrecMax	1924	548	767	419	363	436	367	538	275	168	263	204	383	(16)
(17)		PrecMin	657	7	18	9	23	28	11	5	0	0	6	1	2	(17)
(18)		PrecStd	328	105	152	91	75	87	61	89	52	31	48	57	77	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.8	31.0	30.4	28.6	26.6	25.0	24.3	24.8	25.9	27.4	28.8	30.2	(19)
(20)			MCWB	25.5	25.7	25.1	23.5	21.5	21.7	19.6	19.9	21.1	22.5	23.5	24.8	(20)
(21)		2%	DB	30.2	30.3	29.6	27.7	25.7	24.0	23.4	23.9	25.2	26.7	28.1	29.5	(21)
(22)			MCWB	24.9	25.1	24.6	22.4	20.8	20.1	19.1	19.1	20.3	21.9	22.8	24.4	(22)
(23)		5%	DB	29.6	29.6	29.0	27.0	24.9	23.2	22.6	23.2	24.7	26.0	27.5	28.9	(23)
(24)			MCWB	24.6	24.7	24.2	22.1	20.5	19.6	18.7	18.5	19.7	21.3	22.3	24.0	(24)
(25)		10%	DB	29.0	28.9	28.3	26.4	24.2	22.6	21.9	22.4	24.1	25.4	26.9	28.3	(25)
(26)			MCWB	24.3	24.3	23.8	21.8	19.9	19.1	18.3	18.1	19.2	20.7	21.8	23.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	28.8	26.9	25.1	23.7	23.2	21.6	21.6	22.8	24.1	25.9	27.6	(27)
(28)			MADB	29.1	29.0	28.5	26.8	25.3	23.8	22.8	23.2	24.2	26.2	27.4	28.5	(28)
(29)		2%	WB	26.5	26.7	26.0	24.0	22.1	21.4	20.7	20.6	22.0	23.2	24.5	26.1	(29)
(30)			MADB	28.6	28.3	28.1	26.2	24.4	23.0	22.4	22.7	23.9	25.2	26.5	28.0	(30)
(31)		5%	WB	25.9	25.9	25.4	23.2	21.3	20.5	19.9	19.8	21.2	22.6	23.7	25.4	(31)
(32)			MADB	28.1	28.3	27.7	25.9	24.0	22.6	21.8	22.2	23.3	24.6	26.1	27.5	(32)
(33)		10%	WB	25.4	25.3	24.8	22.6	20.7	19.7	19.0	19.0	20.6	22.1	23.0	24.7	(33)
(34)			MADB	27.8	27.8	27.3	25.5	23.7	22.2	21.5	21.9	22.9	24.2	25.7	27.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.0	3.8	3.6	3.6	3.9	3.5	3.9	4.2	4.3	4.4	4.3	4.2	(35)
(36)			MCDBR	4.5	4.5	4.3	4.1	4.2	3.7	4.4	4.6	4.7	4.6	4.8	4.7	(36)
(37)			MCWBR	2.2	2.3	2.3	2.4	2.8	2.9	3.1	2.9	2.6	2.4	2.4	2.4	(37)
(38)		5% WB	MADB	4.0	4.0	3.9	3.6	3.7	3.4	3.5	4.0	4.0	4.2	4.4	4.2	(38)
(39)			MCWBR	2.9	2.8	2.7	2.8	3.1	3.4	3.3	3.5	3.2	3.1	3.4	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.389	0.383	0.374	0.345	0.329	0.323	0.312	0.322	0.350	0.371	0.373	0.388	(40)	
(41)		taud	2.561	2.589	2.603	2.674	2.660	2.675	2.690	2.645	2.550	2.521	2.549	2.539	(41)	
(42)		Ebn at Noon	955	946	928	915	890	876	901	925	937	947	964	957	(42)	
(43)		Edh at Noon	109	104	98	84	78	74	75	85	101	110	109	111	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.93	6.32	5.62	4.84	4.02	3.47	3.91	4.85	5.95	6.59	7.15	7.08	(44)	
(45)		RadStd	0.42	0.65	0.47	0.34	0.20	0.28	0.29	0.31	0.39	0.43	0.57	0.64	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.37	N/A	N/A	N/A	(47)	

Nomenclature: See separate page