

CATO ISLAND, Australia

WMO: 943940

Lat: 23.250S

Lon: 155.542E

Elev: 24

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	64.2	65.4	N/A	N/A	N/A	N/A	N/A	N/A	33.4	68.3	31.0	68.4	13.5	230	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.9	86.1	N/A	84.8	N/A	83.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.8	20

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	(o)	(p)
32.4	30.0	27.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
			DB	61.6	89.2	1.8	3.1	60.3	91.4	59.3	93.2	58.3	95.0	57.0	97.3	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.9	79.6	80.2	79.1	76.7	73.9	71.3	69.6	69.6	71.5	73.8	76.2	78.3
	DBStd	4.24	2.04	1.94	1.74	1.62	1.80	2.26	1.95	1.87	2.24	2.23	2.27	2.15
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9100	918	845	902	800	741	638	607	606	645	737	785	876
	CDD65	3626	453	425	437	350	276	188	143	141	195	272	335	411
	CDH74	19878	4039	3999	3671	1924	563	125	38	41	219	631	1595	3033
	CDH80	1979	539	596	308	45	3	15	0	0	15	20	111	327
Wind	WSAvg	15.7	16.9	17.7	18.6	17.7	15.5	16.0	14.8	14.3	13.7	14.2	14.4	15.0
Precipitation	PrecAvg	29.4	3.0	4.5	4.3	3.0	2.6	2.7	1.5	1.7	1.0	1.5	1.2	2.6
	PrecMax	44.4	12.2	17.5	13.6	6.9	10.3	8.1	7.2	8.0	3.9	8.0	5.9	11.5
	PrecMin	14.2	0.2	0.4	0.5	0.6	0.3	0.3	0.0	0.1	0.0	0.1	0.0	0.1
	PrecStd	8.7	2.8	3.6	3.4	1.8	2.7	1.9	1.5	1.7	0.9	1.7	1.1	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.5	88.2	86.3	83.4	80.2	80.1	77.1	76.7	80.1	82.1	84.8	86.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	85.8	86.0	84.4	81.2	78.3	76.5	75.0	75.2	77.6	80.1	82.6	84.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	84.3	84.5	82.7	79.8	77.4	75.1	73.4	73.7	76.3	78.7	81.1	83.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	82.8	83.2	81.6	78.9	76.5	74.0	72.3	72.4	75.0	77.3	79.7	81.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.9	4.9	4.3	4.1	4.3	4.7	4.7	5.1	5.9	5.4	5.5	5.3
		MCDBR	7.3	6.9	5.9	5.5	5.3	5.9	6.2	7.1	7.9	7.7	7.6	7.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.378	0.380	0.371	0.346	0.331	0.329	0.316	0.318	0.338	0.360	0.360	0.360	0.373
	taud	2.594	2.601	2.622	2.671	2.668	2.671	2.690	2.672	2.587	2.548	2.577	2.586	
	Ebn at Noon	306	302	296	291	283	277	285	296	301	304	310	308	
	Edh at Noon	33	33	30	27	25	24	24	26	31	34	34	34	
All-Sky Solar Radiation	RadAvg	2280	2089	1811	1592	1323	1125	1261	1576	1940	2169	2349	2348	
	RadStd	136	209	161	88	62	95	66	89	70	137	142	173	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page