

CATO ISLAND, Australia

WMO: 943940

Lat: 23.250S

Lon: 155.542E

Elev: 7

StdP: 101.24

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.9	18.5	N/A	N/A	N/A	N/A	N/A	N/A	14.9	20.2	13.9	20.2	6.0	230	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.7	30.1	N/A	29.3	N/A	28.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.4	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 14.5	13.4	12.5	DB	16.4	31.8	1.0	1.7	15.7	33.0	15.1	34.0	14.6	35.0	13.9	36.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.9	26.5	26.8	26.2	24.8	23.3	21.8	20.9	20.9	21.9	23.2	24.5	25.7		
	DBStd	2.36	1.13	1.08	0.96	0.90	1.00	1.26	1.08	1.04	1.24	1.24	1.26	1.19		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	5056	510	469	501	444	412	354	337	337	358	409	436	487		
	CDD18.3	2014	252	236	243	194	153	104	79	78	108	151	186	228		
	CDH23.3	11043	2244	2222	2039	1069	313	69	21	23	122	351	886	1685		
	CDH26.7	1099	299	331	171	25	2	8	0	0	8	11	62	182		
(14) Wind	WSAvg	7.0	7.5	7.9	8.3	7.9	6.9	7.1	6.6	6.4	6.1	6.4	6.4	6.7		
(15) Precipitation	PrecAvg	748	76	114	108	77	66	68	39	43	25	38	30	65		
	PrecMax	1128	310	445	346	174	261	206	184	203	100	202	149	291		
	PrecMin	360	4	9	13	14	8	8	1	2	1	3	1	3		
	PrecStd	220	71	92	87	45	68	48	39	43	22	42	29	67		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.8	31.2	30.2	28.6	26.8	26.7	25.0	24.8	26.7	27.8	29.3	30.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	29.9	30.0	29.1	27.4	25.7	24.7	23.9	24.0	25.3	26.7	28.1	29.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	29.0	29.1	28.2	26.6	25.2	23.9	23.0	23.2	24.6	25.9	27.3	28.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	28.2	28.4	27.5	26.1	24.7	23.4	22.4	22.4	23.9	25.1	26.5	27.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		2.7	2.7	2.4	2.3	2.4	2.6	2.6	2.8	3.3	3.0	3.1	3.0		
	5% DB	MCDBR	4.1	3.8	3.3	3.0	2.9	3.3	3.5	3.9	4.4	4.3	4.2	4.2		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.378	0.380	0.371	0.346	0.331	0.329	0.316	0.318	0.338	0.360	0.360	0.373		
	taud		2.594	2.601	2.622	2.671	2.668	2.671	2.690	2.672	2.587	2.548	2.577	2.586		
	Ebn at Noon		966	951	933	916	892	873	899	932	950	959	976	972		
	Edh at Noon		105	103	96	85	78	75	75	83	98	107	106	106		
(44) All-Sky Solar Radiation	RadAvg		7.19	6.59	5.71	5.02	4.17	3.55	3.98	4.97	6.12	6.84	7.41	7.40		
	RadStd		0.43	0.66	0.51	0.28	0.20	0.30	0.21	0.28	0.22	0.43	0.45	0.55		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page