

MOUNT MAGNET, Australia

WMO: 944290

Lat: 28.1156S

Lon: 117.8425E

Elev: 1340

StdP: 14.00

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.8	42.1	17.2	13.8	70.6	20.0	15.8	69.6	23.9	64.1	21.8	64.6	3.8	120	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.9	106.4	67.1	103.8	66.7	101.4	66.2	74.7	87.0	73.1	87.8	71.6	88.4	11.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.7	123.2	79.7	69.2	112.6	79.6	66.6	102.9	78.8	39.2	86.2	37.8	87.2	36.3	88.1	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.7	20.3	18.5	35.4	111.0	1.3	2.9	34.5	113.0	33.8	114.7	33.1	116.3	32.1	118.4		
(5)			32.2	75.7	1.7	2.4	31.0	77.4	30.1	78.8	29.1	80.2	27.9	81.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.1	86.8	85.3	79.8	72.3	63.7	57.3	55.5	58.4	63.3	71.3	77.7	82.8		
	DBStd	12.43	6.71	6.22	6.68	6.00	5.54	4.77	4.48	5.21	6.05	6.57	7.13	6.80		
	HDD50	11	0	0	0	0	0	3	6	2	0	0	0	0		
	HDD65	969	0	0	1	12	91	233	295	214	103	17	3	0		
	CDD50	7719	1141	989	924	668	426	223	177	262	398	662	831	1018		
	CDD65	3202	676	569	460	230	52	3	1	10	51	213	384	553		
	CDH74	43342	10185	8085	5665	2237	466	34	19	190	754	2650	5105	7952		
	CDH80	24644	6584	4927	3028	903	92	2	0	31	250	1217	2799	4811		
(14) Wind	WSAvg	9.9	11.5	11.0	10.7	8.8	8.3	8.2	8.0	8.8	9.8	10.6	11.4	11.4		
(15) Precipitation	PrecAvg	10.3	0.9	1.4	0.9	1.0	1.1	1.4	1.3	0.7	0.4	0.4	0.5	0.6		
	PrecMax	23.7	6.2	8.2	7.2	8.4	4.0	5.0	4.1	3.0	1.8	2.7	2.7	3.4		
	PrecMin	4.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0	0.0	0.0		
	PrecStd	4.6	1.4	2.1	1.5	1.4	1.1	1.2	1.1	0.6	0.4	0.6	0.6	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	110.9	109.1	103.0	96.0	86.6	77.9	76.4	84.0	91.1	98.1	104.1	106.7		
		MCWB	68.0	66.7	65.9	64.6	60.9	57.1	56.2	56.2	58.7	62.0	63.9	66.3		
	2%	DB	107.4	105.3	100.1	92.4	82.6	73.9	72.7	79.4	86.6	94.5	100.5	104.0		
		MCWB	67.5	67.7	65.4	63.0	59.7	54.9	53.9	55.6	57.4	61.1	63.2	65.9		
	5%	DB	104.6	102.1	97.2	89.1	79.1	71.1	69.4	75.2	82.4	91.1	97.4	101.4		
		MCWB	67.2	67.0	65.9	61.9	58.2	53.9	53.0	53.9	56.5	59.9	62.7	65.5		
	10%	DB	101.7	98.9	93.9	85.4	75.9	68.2	66.4	71.2	78.0	87.2	93.7	98.3		
		MCWB	67.2	67.3	65.4	61.3	57.3	53.2	52.5	53.2	55.1	59.1	61.9	64.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.4	77.3	73.3	69.2	65.4	62.8	61.1	61.2	62.2	65.4	68.0	72.7		
		MCDB	89.6	86.5	85.2	82.2	74.8	68.6	67.2	69.8	75.2	85.7	91.3	90.6		
	2%	WB	74.7	75.1	71.5	67.5	63.3	60.1	58.4	58.7	60.2	63.6	66.0	70.1		
		MCDB	89.0	84.4	83.0	80.7	73.6	66.6	65.3	69.7	78.4	84.5	89.7	91.6		
	5%	WB	73.3	73.5	70.0	66.0	61.5	58.2	56.3	56.9	58.6	62.2	64.7	68.7		
		MCDB	89.2	86.4	83.6	79.0	73.0	65.1	63.6	68.9	76.6	82.9	88.9	90.4		
	10%	WB	71.8	71.9	68.5	64.3	59.8	56.0	54.4	55.2	57.1	60.7	63.5	67.3		
		MCDB	89.7	88.1	84.5	78.7	72.0	64.1	63.0	67.8	74.5	82.1	87.5	89.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.9	22.1	21.1	21.2	21.0	19.6	20.1	22.4	24.1	25.1	24.6	24.6		
		MCDBR	27.0	26.1	24.9	26.0	24.8	24.0	24.7	28.8	30.6	29.7	28.3	26.6		
		MCWBR	8.4	7.5	8.2	9.7	10.0	11.5	11.8	12.4	11.9	11.0	9.7	8.8		
	5% WB	MCDBR	21.8	20.1	20.0	19.7	19.0	16.4	17.8	20.9	25.0	24.6	25.3	23.5		
		MCWBR	7.1	7.1	7.6	8.1	8.6	9.5	10.4	10.6	10.2	9.5	8.6	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.339	0.323	0.308	0.289	0.278	0.275	0.281	0.297	0.308	0.316	0.322		
	taud		2.581	2.591	2.606	2.622	2.632	2.655	2.652	2.617	2.541	2.530	2.543	2.569		
	Ebn at Noon		319	313	308	298	291	288	293	304	312	319	323	324		
	Edh at Noon		34	32	30	27	24	22	23	27	32	34	35	34		
(44) All-Sky Solar Radiation	RadAvg		2553	2312	2001	1601	1282	1094	1181	1509	1952	2303	2562	2668		
	RadStd		150	134	150	70	79	63	63	57	63	113	101	127		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page