

MEEKATHARRA, Australia

WMO: 944300

Lat: 26.6136S

Lon: 118.5372E

Elev: 1703

StdP: 13.81

Time Zone: 8.00 (E08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.6	43.8	6.5	8.2	81.4	11.2	10.4	76.8	20.5	61.6	18.6	61.4	6.1	90	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.0	106.5	65.3	104.3	65.0	101.9	64.3	74.4	85.0	73.0	84.7	71.5	85.0	10.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	126.0	78.5	69.9	117.3	78.4	67.6	107.9	78.7	39.3	84.4	37.9	84.7	36.5	84.2	93.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.6	18.6	16.9	DB	36.7	110.1	1.9	2.4	35.3	111.8	34.2	113.2	33.1	114.6	31.7	116.3	(4)
(5)			WB	33.0	80.1	1.5	6.3	32.0	84.7	31.1	88.4	30.3	91.9	29.2	96.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.6	88.4	85.7	80.3	73.3	65.2	58.2	56.5	60.2	66.1	73.8	79.2	84.5	(6)	
	DBStd	12.27	6.33	6.25	6.61	5.76	5.84	4.68	4.48	5.36	6.03	6.29	6.67	6.23	(7)	
	HDD50	4	0	0	0	0	0	1	3	0	0	0	0	0	(8)	
	HDD65	788	0	0	1	6	71	210	264	170	59	6	1	0	(9)	
	CDD50	8239	1192	999	939	700	472	246	206	316	483	739	877	1070	(10)	
	CDD65	3547	727	579	474	257	78	5	2	21	92	280	427	605	(11)	
	CDH74	47486	11226	8218	5835	2434	604	34	24	281	1158	3355	5593	8724	(12)	
	CDH80	27105	7388	5003	3130	1000	140	1	1	51	387	1584	3080	5340	(13)	
(14) Wind	WSAvg	9.1	10.4	10.2	9.9	8.3	8.0	7.9	7.6	8.1	9.1	9.8	10.2	10.4	(14)	
(15) Precipitation	PrecAvg	9.7	1.2	1.5	1.1	0.9	0.9	1.1	0.9	0.4	0.2	0.2	0.5	0.7	(15)	
	PrecMax	22.3	5.4	6.8	10.1	6.3	3.8	7.4	6.5	2.2	1.6	2.4	4.4	4.4	(16)	
	PrecMin	2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	4.3	1.5	1.7	1.9	1.1	1.0	1.4	1.1	0.4	0.3	0.5	0.9	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.7	109.4	102.4	95.1	88.0	77.7	77.1	84.8	90.8	99.4	103.4	107.1	(19)	
		MCWB	66.0	64.3	64.4	63.0	59.7	56.1	53.0	55.3	57.0	60.5	62.2	64.7	(20)	
	2%	DB	107.1	105.7	99.8	92.0	83.9	74.3	73.6	81.2	88.1	95.3	100.5	104.7	(21)	
		MCWB	65.8	65.2	63.7	61.3	58.2	54.4	51.8	54.3	56.4	59.2	61.8	64.2	(22)	
	5%	DB	104.9	102.7	97.3	89.3	80.5	71.7	70.8	77.0	84.8	92.4	97.5	101.8	(23)	
		MCWB	65.6	65.0	63.8	60.8	57.8	53.3	51.6	53.4	55.5	58.6	61.3	63.5	(24)	
	10%	DB	102.5	99.3	94.0	86.3	77.1	68.7	67.7	73.3	81.1	89.1	94.2	98.9	(25)	
		MCWB	65.0	65.1	63.8	60.5	56.6	52.6	51.1	52.0	54.7	57.9	60.8	63.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.5	76.5	73.8	69.5	65.7	62.9	61.4	60.6	61.9	66.1	69.3	73.6	(27)	
		MCDB	87.8	84.9	82.2	79.9	74.0	67.8	68.1	71.3	76.3	85.1	85.6	86.5	(28)	
	2%	WB	74.2	74.7	71.2	67.5	63.4	60.2	57.7	58.3	59.6	63.5	65.6	71.1	(29)	
		MCDB	86.3	84.1	80.2	78.0	72.7	66.7	63.9	69.8	77.9	80.7	85.4	84.2	(30)	
	5%	WB	72.7	73.5	69.6	66.0	61.7	58.1	55.8	56.1	57.9	61.5	64.2	69.2	(31)	
		MCDB	86.6	84.0	81.6	78.1	72.2	65.3	62.8	70.3	77.7	82.5	87.5	85.7	(32)	
	10%	WB	71.1	72.1	67.8	64.3	60.0	56.1	53.9	54.2	56.4	59.8	62.9	67.3	(33)	
		MCDB	88.6	84.2	84.0	77.2	71.7	63.9	62.5	69.2	76.8	83.3	86.7	88.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.0	20.9	20.4	20.3	19.9	19.4	20.3	22.8	24.8	24.6	23.7	23.4	(35)	
		MCDBR	25.2	25.1	24.3	24.5	23.1	22.8	24.5	27.1	29.4	28.6	26.3	26.0	(36)	
		MCWBR	8.2	7.7	7.6	8.7	8.8	9.8	10.9	11.5	10.9	10.1	8.7	8.7	(37)	
	5% WB	MCDBR	21.0	17.7	17.9	18.1	17.6	16.0	17.0	22.2	24.4	23.5	24.3	22.5	(38)	
		MCWBR	7.5	6.0	6.9	7.6	7.8	8.6	9.5	11.0	9.9	9.0	8.6	8.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.341	0.341	0.327	0.311	0.289	0.276	0.275	0.278	0.297	0.313	0.321	0.325	(40)	
	taud		2.565	2.591	2.595	2.611	2.621	2.647	2.629	2.604	2.521	2.502	2.517	2.559	(41)	
	Ebn at Noon		318	313	308	299	292	291	295	306	313	318	322	323	(42)	
	Edh at Noon		34	33	31	28	25	23	24	27	32	35	36	35	(43)	
(44) All-Sky Solar Radiation	RadAvg		2501	2301	1989	1632	1346	1168	1268	1624	2056	2338	2564	2652	(44)	
	RadStd		168	127	138	68	87	65	86	69	56	127	112	141	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page