

LEONORA, Australia

WMO: 944480

Lat: 28.884S

Lon: 121.330E

Elev: 1247

StdP: 14.05

Time Zone: 8.00 (E08)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.4	40.6	25.5	20.5	65.2	27.8	22.7	65.0	27.2	62.0	22.8	64.6	1.3	90	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.1	105.8	68.6	102.9	68.1	100.1	67.6	76.9	88.5	74.5	87.9	72.4	87.3	5.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.9	132.5	82.9	71.3	121.0	79.8	68.3	108.7	79.0	41.3	88.1	39.0	87.9	37.0	85.9	95.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.7	18.8	17.5	DB	33.8	110.4	1.5	2.4	32.7	112.2	31.9	113.6	31.1	114.9	30.0	116.7	(4)
(5)			WB	32.7	82.0	1.7	5.9	31.5	86.3	30.5	89.7	29.6	93.1	28.4	97.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	84.6	81.6	75.0	69.1	62.1	55.4	54.5	56.7	64.0	69.4	75.8	81.2		
	DBStd	12.14	7.12	7.50	7.78	5.55	6.53	4.88	4.89	6.02	6.41	6.45	7.25	7.44		
	HDD50	24	0	0	0	0	0	7	13	4	0	0	0	0		
	HDD65	1188	0	0	8	24	139	291	328	270	95	28	4	1		
	CDD50	6973	1072	884	774	573	374	168	153	212	420	600	774	969		
	CDD65	2661	607	464	317	147	48	2	2	14	65	163	327	505		
	CDH74	33719	8784	6194	3580	1252	371	15	16	152	819	1902	3892	6742		
	CDH80	18389	5501	3623	1811	400	79	1	1	32	247	788	1969	3937		
(14) Wind	WSAvg	4.8	5.3	5.2	4.9	3.5	3.4	3.5	3.8	4.3	5.1	6.0	6.3	6.1		
(15) Precipitation	PrecAvg	9.8	0.7	1.7	1.1	0.8	1.1	1.0	0.9	0.6	0.4	0.5	0.6	0.7		
	PrecMax	21.7	5.0	11.2	7.0	4.0	4.3	3.9	4.0	3.1	1.9	2.2	2.0	3.7		
	PrecMin	3.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	4.3	1.1	2.3	1.5	0.9	1.1	0.9	1.0	0.7	0.4	0.6	0.5	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.7	111.2	103.9	92.4	86.0	75.3	75.9	84.5	91.0	98.2	102.5	107.2		
		MCWB	69.5	69.7	69.1	63.9	61.2	58.4	55.8	59.0	60.9	62.7	65.9	67.6		
	2%	DB	106.2	105.3	99.1	88.2	81.7	71.5	72.2	78.1	86.2	93.5	98.1	103.2		
		MCWB	68.9	68.8	67.6	63.2	60.4	56.0	54.4	56.7	59.2	63.6	65.6	67.0		
	5%	DB	103.3	101.2	94.8	85.0	78.0	68.7	68.9	73.5	82.5	89.2	94.8	100.3		
		MCWB	68.6	69.1	67.2	63.7	60.3	54.8	54.1	55.2	58.5	62.1	64.9	66.9		
	10%	DB	100.0	97.0	90.1	81.4	74.2	65.9	65.6	69.4	78.6	84.7	90.8	96.8		
		MCWB	68.2	68.7	67.0	62.9	59.0	54.6	53.3	53.5	57.4	59.9	63.6	66.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.9	79.8	77.5	72.5	66.5	63.5	61.3	61.0	63.7	83.4	72.0	80.4		
		MCDB	94.9	91.4	86.8	80.5	76.2	68.4	66.8	75.8	79.2	84.8	88.5	92.0		
	2%	WB	73.9	77.3	73.6	69.0	64.3	60.3	58.2	58.7	61.6	65.7	68.4	74.2		
		MCDB	94.6	88.8	83.0	78.6	75.9	66.5	66.3	72.5	80.3	83.8	89.1	86.5		
	5%	WB	72.3	75.4	71.1	66.9	62.6	58.2	56.2	56.6	60.0	62.7	66.8	70.6		
		MCDB	92.9	87.8	82.9	76.8	71.9	64.8	64.8	70.8	78.5	83.3	88.5	89.9		
	10%	WB	70.5	73.2	69.0	65.2	60.9	56.0	54.6	54.6	58.4	61.0	65.1	68.4		
		MCDB	92.3	85.1	85.0	75.0	70.1	63.2	63.0	67.6	76.0	82.1	86.1	91.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	24.1	22.1	20.7	20.7	20.0	19.7	20.6	22.6	25.4	24.3	22.6	22.9		
		MCDBR	27.6	28.9	27.1	25.9	24.2	23.3	25.5	27.3	30.4	31.1	26.6	26.7		
		MCWBR	8.4	9.1	9.5	10.0	10.3	11.3	12.8	13.2	12.1	12.7	9.4	9.7		
	5% WB	MCDBR	24.4	20.7	21.0	19.6	18.5	17.6	19.5	23.3	26.7	25.8	24.2	24.0		
		MCWBR	8.8	8.2	10.8	9.5	8.7	10.8	12.2	12.6	11.5	12.5	9.2	11.9		
(40) Clear-Sky Solar Irradiance	taub		0.341	0.344	0.324	0.311	0.289	0.278	0.276	0.283	0.300	0.321	0.328	0.330		
	taud		2.580	2.591	2.622	2.630	2.654	2.666	2.661	2.619	2.557	2.514	2.530	2.568		
	Ebn at Noon		317	311	307	297	290	287	292	302	310	315	319	321		
	Edh at Noon		34	32	30	27	23	22	23	26	31	35	35	34		
(44) All-Sky Solar Radiation	RadAvg		2473	2198	1906	1545	1244	1049	1158	1494	1929	2244	2482	2598		
	RadStd		196	182	136	82	80	67	77	81	78	139	107	144		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page