

LAVERTON, Australia

WMO: 944490

Lat: 28.613S

Lon: 122.424E

Elev: 465

StdP: 95.86

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.7	4.1	-11.1	1.5	22.7	-8.9	1.9	24.0	10.7	16.3	9.7	15.9	2.2	80	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	40.8	18.5	39.1	18.3	37.4	18.0	23.6	29.4	22.3	29.3	21.3	29.1	5.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	17.8	26.2	20.6	16.1	24.9	19.1	14.7	24.4	73.2	28.8	68.1	29.1	64.1	28.8	37.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.5	9.6	8.9	-0.3	43.4	1.0	1.2	-1.0	44.3	-1.6	45.0	-2.2	45.7	-2.9	46.6		
			-1.5	25.4	1.3	3.6	-2.4	28.0	-3.2	30.1	-3.9	32.1	-4.8	34.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	28.3	27.1	24.2	21.1	16.2	12.7	12.2	13.9	17.5	21.7	24.3	26.7
	DBStd	6.77	4.37	4.38	4.19	3.42	3.45	2.88	2.94	3.52	3.85	4.34	4.17	4.11
	HDD10.0	23	0	0	0	0	1	7	11	4	1	0	0	0
	HDD18.3	694	1	1	4	12	85	171	192	145	62	18	3	1
	CDD10.0	3836	566	479	439	334	193	87	79	124	225	362	428	517
	CDD18.3	1463	309	246	186	96	19	1	1	7	37	121	181	260
	CDH23.3	18629	4342	3217	2124	877	167	8	13	106	492	1477	2294	3511
	CDH26.7	10025	2641	1868	1057	332	32	0	1	18	168	697	1198	2013
Wind	WSAvg	5.0	5.9	5.8	5.4	4.5	4.1	4.0	3.9	4.4	4.9	5.4	5.6	5.8
Precipitation	PrecAvg	246	21	40	27	23	26	25	20	14	9	10	14	18
	PrecMax	526	179	234	181	87	82	117	66	56	43	57	89	68
	PrecMin	104	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	101	36	51	36	24	20	24	20	15	11	12	16	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.4	42.4	38.7	35.0	29.6	24.4	25.1	28.9	33.2	37.4	40.3	41.6
		MCWB	19.9	18.3	17.7	17.5	14.9	13.0	13.2	13.7	14.3	16.0	17.2	18.5
	2%	DB	40.9	40.3	36.6	32.3	27.2	22.0	22.7	26.4	30.7	35.2	37.3	39.6
		MCWB	19.1	18.4	17.7	16.5	14.4	12.1	11.6	12.9	14.1	15.8	16.9	17.7
	5%	DB	39.1	38.2	34.7	30.4	25.1	20.4	20.9	24.0	28.6	33.1	35.2	37.6
		MCWB	18.9	18.6	17.4	16.0	13.9	11.5	10.9	12.2	13.7	15.6	16.6	17.6
	10%	DB	36.9	35.7	32.5	28.3	23.1	18.7	19.0	21.7	26.2	30.8	33.1	35.4
		MCWB	18.8	18.7	17.5	15.7	13.3	11.0	10.4	11.6	13.1	15.2	16.1	17.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	25.0	22.9	21.1	18.5	15.5	15.7	20.5	19.9	21.9	21.6	22.5
		MCDB	31.7	30.0	29.0	25.5	22.1	19.1	20.9	21.7	23.6	30.3	28.1	30.3
	2%	WB	23.3	23.7	21.4	19.5	16.6	14.3	13.7	14.8	15.9	17.9	19.7	21.2
		MCDB	29.6	29.5	27.0	25.5	23.1	18.7	18.8	20.6	25.5	27.6	28.4	29.5
	5%	WB	22.0	22.5	20.3	18.5	15.6	13.3	12.5	13.3	14.6	16.7	18.6	20.2
		MCDB	30.9	28.8	27.5	24.9	21.5	17.6	17.6	21.2	25.7	28.4	28.8	29.6
	10%	WB	20.9	21.3	19.4	17.6	14.6	12.2	11.4	12.2	13.7	15.8	17.7	19.1
		MCDB	31.3	28.5	27.9	23.9	20.6	16.5	17.2	20.3	24.4	28.2	29.2	30.9
Mean Daily Temperature Range	5% DB	MDBR	12.9	12.0	11.3	11.5	11.4	11.0	12.3	12.9	13.5	13.3	13.2	13.1
		MCDBR	14.9	14.6	14.2	14.2	13.2	12.7	14.6	15.5	16.6	16.0	15.3	15.1
		MCWBR	4.3	4.2	4.5	5.1	5.5	6.1	7.1	7.6	6.9	5.9	5.0	4.7
	5% WB	MCDBR	12.7	11.3	10.9	11.1	10.3	9.8	11.6	13.1	14.3	13.9	13.7	13.2
		MCWBR	5.2	4.8	4.8	5.2	5.0	5.4	6.6	7.7	6.7	5.7	5.2	4.9
Clear-Sky Solar Irradiance	taub	0.343	0.345	0.326	0.312	0.289	0.277	0.276	0.283	0.303	0.323	0.331	0.331	
	taud	2.568	2.583	2.608	2.623	2.642	2.659	2.642	2.604	2.538	2.501	2.520	2.562	
	Ebn at Noon	998	979	968	935	915	906	921	953	975	990	1004	1012	
	Edh at Noon	108	103	95	85	75	70	74	84	100	110	112	109	
All-Sky Solar Radiation	RadAvg	7.71	6.90	5.99	4.88	3.96	3.36	3.71	4.79	6.12	7.04	7.76	8.12	
	RadStd	0.68	0.56	0.42	0.27	0.25	0.21	0.25	0.26	0.26	0.42	0.34	0.44	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page