

WARBURTON, Australia

WMO: 944570

Lat: 26.132S

Lon: 126.584E

Elev: 1508

StdP: 13.91

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.2	39.1	9.4	9.4	72.5	12.4	10.9	70.3	20.8	65.8	19.2	64.9	2.7	130	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.4	107.7	66.2	105.2	65.6	102.8	65.3	75.7	84.8	74.3	85.1	72.7	86.1	11.5	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	133.3	78.8	71.5	122.9	78.6	68.9	112.5	78.9	40.4	84.9	39.0	84.4	37.4	85.7	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 24.6	21.2	19.0	DB	31.6	111.1	2.8	2.2	29.5	112.6	27.9	113.9	26.3	115.2	24.2	116.8	(4)
(5)			WB	27.7	76.8	3.0	2.5	25.5	78.6	23.7	80.1	22.0	81.5	19.8	83.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.1	87.8	85.6	81.1	73.8	63.8	56.5	56.5	60.1	68.4	78.0	81.3	85.3
	DBStd	13.01	6.92	7.33	6.91	6.24	6.27	5.05	5.60	6.28	7.21	7.51	6.88	6.60
	HDD50	14	0	0	0	0	0	5	7	2	0	0	0	0
	HDD65	873	0	1	1	7	101	259	272	180	47	5	0	0
	CDD50	8447	1173	997	963	714	426	199	207	316	551	868	940	1093
	CDD65	3832	708	578	499	271	62	4	7	29	148	408	490	628
	CDH74	51649	10562	8271	6289	2781	656	46	134	483	1939	5184	6450	8854
	CDH80	29999	6843	5168	3511	1225	186	2	16	105	853	2875	3743	5472
Wind	WSAvg	10.2	12.2	12.1	11.5	9.6	8.6	8.5	7.9	8.7	9.7	11.1	11.2	11.4
Precipitation	PrecAvg	12.9	1.3	1.9	1.5	0.9	0.6	0.5	0.5	0.3	0.3	0.8	1.6	2.5
	PrecMax	24.8	5.0	6.1	6.1	3.3	3.7	3.0	1.9	1.9	2.2	3.2	4.6	9.1
	PrecMin	5.3	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.2
	PrecStd	5.1	1.3	1.9	1.9	0.9	0.9	0.7	0.5	0.4	0.6	1.0	1.2	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	112.1	108.4	105.1	97.5	90.3	78.2	82.3	87.1	95.9	103.3	105.6	110.9
		MCWB	68.8	65.7	65.6	64.1	59.8	55.8	56.6	56.7	59.6	61.9	64.1	67.2
	2%	DB	108.0	106.1	101.3	94.2	85.1	75.0	77.6	83.0	92.4	100.2	102.7	106.6
		MCWB	67.0	65.5	65.1	62.9	58.4	54.8	54.2	55.4	58.5	61.6	63.4	65.8
	5%	DB	105.3	103.6	98.6	90.8	81.0	71.8	74.1	79.6	89.0	97.4	99.8	103.2
		MCWB	66.4	65.7	65.1	61.8	57.2	52.7	52.9	54.2	57.5	61.0	63.4	65.5
	10%	DB	102.2	100.4	95.4	87.3	77.2	68.7	70.6	75.8	85.3	94.1	96.5	99.8
		MCWB	66.4	66.4	64.9	61.3	56.2	52.0	51.7	52.9	56.6	60.3	62.8	65.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.3	77.3	75.4	70.0	65.1	63.7	61.2	60.2	63.5	68.0	70.8	75.4
		MCDB	84.7	88.0	81.2	81.4	71.4	68.3	69.0	76.4	79.0	82.0	88.4	80.4
	2%	WB	76.1	75.6	73.7	67.5	62.6	59.9	57.8	57.7	61.3	66.0	69.3	73.6
		MCDB	84.7	87.0	83.8	80.0	71.5	64.8	70.6	76.8	84.3	83.5	86.3	84.9
	5%	WB	74.1	74.2	71.8	66.1	60.9	56.7	55.3	55.8	59.4	64.5	67.8	72.0
		MCDB	86.0	85.7	84.1	79.3	73.7	65.5	70.1	75.6	83.5	83.5	84.8	85.6
	10%	WB	72.1	72.3	69.8	64.6	58.8	54.3	53.2	53.9	57.6	62.9	66.3	70.5
		MCDB	89.1	86.0	85.4	78.8	73.0	64.7	68.1	72.9	82.0	86.1	84.5	86.1
Mean Daily Temperature Range	5% DB	MDBR	22.4	22.2	22.3	23.4	23.7	23.5	26.2	28.4	27.7	25.3	24.2	23.3
		MCDBR	25.3	25.3	25.7	26.6	27.5	27.5	30.5	32.1	31.9	28.7	27.1	26.9
		MCWBR	7.3	7.8	8.2	9.0	11.1	13.2	14.4	14.3	13.1	10.4	8.4	8.4
	5% WB	MCDBR	18.7	19.6	19.3	19.7	19.7	18.4	26.5	27.8	26.9	23.3	24.1	21.4
		MCWBR	6.9	6.2	7.3	7.4	9.4	9.3	13.4	13.2	11.8	8.5	7.7	7.3
Clear-Sky Solar Irradiance	taub	0.354	0.355	0.346	0.334	0.308	0.293	0.298	0.303	0.333	0.348	0.354	0.353	
	taud	2.548	2.564	2.559	2.547	2.559	2.591	2.542	2.507	2.442	2.428	2.470	2.531	
	Ebn at Noon	314	308	302	291	286	285	286	297	301	307	312	315	
	Edh at Noon	35	34	32	30	27	24	27	30	35	38	37	36	
All-Sky Solar Radiation	RadAvg	2433	2231	1977	1624	1363	1202	1302	1660	2030	2260	2391	2423	
	RadStd	188	191	122	87	100	90	81	82	92	132	103	121	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page