

PUKATJA, Australia

WMO: 944740

Lat: 26.2636S

Lon: 132.1772E

Elev: 2308

StdP: 13.51

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	35.5	38.3	5.4	7.9	74.5	10.1	10.0	74.9	26.3	57.2	21.7	58.9	3.8	80	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.6	102.6	63.6	99.9	63.3	97.5	63.1	72.3	83.1	70.8	83.1	69.3	83.1	11.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.0	120.3	75.6	67.4	110.0	75.5	65.1	101.0	75.4	37.7	83.3	36.3	82.9	34.8	83.2	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.9	20.0	17.8	29.5	105.5	2.0	2.7	28.1	107.5	26.9	109.1	25.7	110.6	24.2	112.6		
(5)			26.4	73.5	1.9	2.1	25.0	75.0	23.9	76.2	22.8	77.4	21.5	78.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.8	83.5	81.4	76.5	69.3	59.4	52.8	53.3	56.9	65.1	71.9	76.5	79.5	(6)
(7)		DBStd	12.45	6.51	6.11	6.58	6.08	5.73	4.92	5.40	6.08	7.68	7.70	7.11	7.09	(7)
(8)		HDD50	52	0	0	0	0	1	21	23	7	0	0	0	0	(8)
(9)		HDD65	1344	1	0	4	25	193	369	363	262	96	25	5	1	(9)
(10)		CDD50	6901	1037	879	822	579	293	103	126	221	452	680	795	914	(10)
(11)		CDD65	2716	573	460	361	153	19	1	1	11	97	240	350	450	(11)
(12)		CDH74	34058	7912	6003	4112	1500	192	13	37	196	1193	2903	4263	5734	(12)
(13)		CDH80	17614	4628	3305	1984	516	24	1	1	34	425	1356	2188	3152	(13)
(14)	Wind	WSAvg	9.5	10.5	10.3	10.2	9.0	8.6	8.2	7.9	9.0	9.7	10.2	10.3	10.4	(14)
(15)	Precipitation	PrecAvg	10.6	1.3	1.6	0.6	0.8	0.6	0.6	0.5	0.4	0.5	0.9	1.2	1.5	(15)
(16)		PrecMax	28.1	3.8	7.7	5.4	4.2	3.1	5.3	1.9	1.2	3.3	4.3	3.1	8.1	(16)
(17)		PrecMin	1.7	0.2	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	(17)
(18)		PrecStd	5.2	0.9	1.7	1.1	1.0	0.8	1.0	0.6	0.3	0.6	0.9	0.8	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.9	102.5	100.4	92.7	83.0	75.3	77.9	84.0	91.3	97.7	102.3	105.9	(19)
MCWB			64.9	64.4	63.5	60.7	57.1	54.5	53.3	55.6	57.4	58.9	60.7	63.3	(20)	
2%		DB	103.2	99.9	96.3	89.1	79.1	70.5	73.9	79.5	88.2	94.5	98.3	101.5	(21)	
		MCWB	64.7	64.6	62.7	60.6	56.3	52.8	52.0	53.2	56.4	58.4	60.7	62.3	(22)	
5%		DB	100.1	97.5	93.3	85.9	75.5	66.7	70.1	75.2	85.2	91.6	94.9	98.0	(23)	
		MCWB	64.3	64.0	61.7	58.9	55.2	51.1	50.5	51.8	55.2	57.8	60.2	62.3	(24)	
10%		DB	97.1	95.1	90.1	82.6	71.4	63.4	66.3	71.2	81.5	88.0	91.6	94.3	(25)	
		MCWB	64.3	63.5	61.1	57.9	53.5	49.5	48.8	50.3	54.3	57.0	59.5	61.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.7	73.5	72.0	68.2	62.6	59.4	59.1	58.3	63.5	65.1	69.6	72.7	(27)
MCD B			84.5	86.2	81.1	77.8	69.9	66.3	69.2	74.9	76.8	81.7	83.9	80.6	(28)	
2%		WB	72.7	72.0	69.8	64.8	59.3	56.9	54.6	55.6	59.6	62.8	66.7	70.6	(29)	
		MCD B	82.2	85.9	79.7	75.5	70.7	63.8	67.3	72.4	78.8	77.6	81.1	79.9	(30)	
5%		WB	70.7	70.6	67.6	62.5	57.5	54.0	52.3	53.3	57.4	61.4	65.0	68.5	(31)	
		MCD B	83.5	84.8	80.6	76.5	70.3	63.1	66.2	72.8	79.0	78.2	81.5	80.7	(32)	
10%		WB	68.7	69.1	65.3	60.5	55.6	51.3	50.1	51.2	55.6	59.7	63.2	67.0	(33)	
		MCD B	86.0	84.1	83.5	77.1	69.1	61.2	64.6	69.4	77.8	80.6	80.5	81.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.6	21.8	21.4	22.0	21.0	20.5	22.6	24.1	24.4	24.3	23.2	22.4	(35)
MCDBR			25.1	24.5	25.1	25.4	25.5	25.3	27.7	29.1	28.1	27.5	26.8	27.1	(36)	
MCWBR			8.0	7.7	8.9	9.5	10.8	12.6	13.1	13.1	11.2	10.3	9.1	8.6	(37)	
5% WB		MCDBR	19.8	19.2	18.1	19.2	20.0	18.3	24.0	26.0	24.2	21.2	22.4	19.3	(38)	
		MCWBR	7.6	6.2	7.1	8.3	9.7	9.6	12.7	12.4	10.4	8.8	7.8	7.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.347	0.342	0.329	0.315	0.289	0.275	0.277	0.293	0.332	0.339	0.347	0.345	(40)	
taud		2.524	2.557	2.565	2.570	2.606	2.629	2.607	2.527	2.429	2.438	2.475	2.516	(41)		
Ebn at Noon		316	312	307	298	293	292	294	301	301	310	314	317	(42)		
Edh at Noon		36	34	32	29	25	23	25	30	36	37	37	36	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2488	2319	2060	1692	1373	1206	1302	1643	1995	2253	2388	2420	(44)	
(45)		RadStd	151	206	137	123	109	95	91	81	101	165	111	166	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	-1.89	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page