

OODNADATTA, Australia

WMO: 944760

Lat: 27.5538S

Lon: 135.4457E

Elev: 117

StdP: 99.93

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	3.3	4.7	-10.1	1.6	21.4	-8.5	1.9	21.2	10.2	18.3	9.3	18.3	2.0	190	0.549

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.2	42.9	20.4	41.5	20.0	40.0	19.8	24.2	31.8	23.2	32.8	22.3	32.9	5.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.5	17.5	26.5	20.8	15.7	26.6	19.1	14.1	27.1	73.7	31.9	69.8	32.7	66.2	32.6	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.8	9.7	1.0	45.1	1.1	1.4	0.2	46.1	-0.4	47.0	-1.0	47.7	-1.8	48.8		
(5)			-1.6	25.1	1.1	1.2	-2.4	26.0	-3.1	26.7	-3.7	27.3	-4.6	28.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.4	31.5	30.2	26.9	22.4	17.1	13.1	13.3	15.3	19.8	23.5	26.7	29.1	(6)	(7)
	DBStd	7.40	4.08	4.14	3.96	3.57	3.44	2.71	2.98	3.41	4.32	4.46	4.34	4.08	(7)	(8)
	HDD10.0	7	0	0	0	0	0	3	3	1	0	0	0	0	(8)	(9)
	HDD18.3	536	0	0	0	6	67	158	159	108	32	6	1	0	(9)	(10)
	CDD10.0	4522	667	564	525	372	221	97	105	166	296	418	500	591	(10)	(11)
	CDD18.3	2011	409	331	267	128	29	2	3	15	77	166	251	333	(11)	(12)
	CDH23.3	28751	6517	5007	3498	1406	263	22	52	203	1019	2236	3532	4998	(12)	(13)
	CDH26.7	17196	4415	3230	1966	594	62	2	6	57	463	1182	2067	3152	(13)	(14)
(14) Wind	WSAvg	4.9	6.0	5.6	5.1	4.4	4.0	3.7	3.9	4.5	5.1	5.5	5.4	5.6	(14)	(15)
(15) Precipitation	PrecAvg	162	11	34	10	9	9	13	9	7	8	14	15	20	(15)	(16)
	PrecMax	315	52	122	105	67	32	89	65	46	48	70	48	85	(16)	(17)
	PrecMin	63	0	0	0	0	0	0	0	0	0	0	0	0	(17)	(18)
	PrecStd	81	14	44	22	18	10	19	16	12	13	18	16	21	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.4	43.7	41.2	36.4	30.7	26.0	27.4	31.7	36.7	39.7	42.8	44.1	(19)	(20)
		MCWB	21.2	21.8	19.7	18.6	15.8	14.7	14.0	15.2	17.2	18.0	18.9	20.2	(20)	(21)
	2%	DB	43.4	41.6	38.6	34.2	28.5	23.1	24.7	28.0	34.3	37.7	40.4	41.8	(21)	(22)
		MCWB	20.7	20.7	19.4	17.5	15.5	13.5	13.0	13.5	15.9	17.3	18.6	19.5	(22)	(23)
	5%	DB	41.8	40.2	37.0	32.2	26.4	21.0	22.3	25.3	31.9	35.5	37.9	40.0	(23)	(24)
		MCWB	20.4	20.4	18.9	16.8	14.6	12.4	12.0	12.7	15.1	16.7	18.2	19.3	(24)	(25)
	10%	DB	40.2	38.6	35.1	30.2	24.2	19.3	20.1	23.1	29.1	33.1	35.8	38.0	(25)	(26)
		MCWB	20.1	20.0	18.7	16.1	13.7	11.6	11.2	11.8	14.2	15.9	17.6	18.9	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.1	25.6	24.5	21.8	17.9	17.0	17.0	16.3	19.4	20.2	22.5	24.1	(27)	(28)
		MCDB	35.4	31.0	28.9	26.7	22.8	21.4	23.0	27.2	27.2	32.3	32.1	30.9	(28)	(29)
	2%	WB	23.6	24.5	22.9	20.1	16.6	15.3	14.0	14.7	17.6	19.0	21.1	22.7	(29)	(30)
		MCDB	33.8	31.7	30.7	25.7	24.2	20.2	21.7	25.0	28.8	30.9	31.8	31.8	(30)	(31)
	5%	WB	22.6	23.7	21.6	18.8	15.7	13.8	12.7	13.5	16.2	18.0	20.2	21.8	(31)	(32)
		MCDB	35.2	32.4	31.3	28.0	23.6	19.1	20.6	23.8	29.7	30.7	31.4	32.4	(32)	(33)
	10%	WB	21.7	22.6	20.2	17.5	14.7	12.4	11.7	12.4	15.0	17.0	19.3	20.8	(33)	(34)
		MCDB	35.1	32.9	32.2	28.3	22.8	18.2	19.4	21.9	28.3	30.2	31.4	32.9	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.2	12.5	12.6	12.9	12.3	12.3	12.8	13.7	14.2	14.1	13.7	13.5	(35)	(36)
		MCDBR	14.6	13.7	14.4	14.7	13.9	14.1	15.6	16.0	17.1	16.6	15.6	15.5	(36)	(37)
	5% WB	MCWBR	5.2	4.6	5.6	6.2	6.4	7.6	7.9	7.6	7.4	6.6	5.7	5.6	(37)	(38)
		MCWBR	11.5	9.6	10.3	11.0	11.4	10.8	13.2	14.2	14.5	13.8	12.7	11.9	(38)	(39)
(40) Clear-Sky Solar Irradiance	taub		0.382	0.372	0.349	0.331	0.307	0.291	0.293	0.308	0.349	0.360	0.374	0.366	(40)	(41)
	taud		2.386	2.441	2.474	2.508	2.540	2.567	2.545	2.478	2.369	2.360	2.373	2.422	(41)	(42)
	Ebn at Noon		961	953	945	915	896	891	902	926	929	954	962	978	(42)	(43)
	Edh at Noon		129	119	109	96	84	77	82	97	119	128	130	125	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		8.02	7.40	6.57	5.20	4.12	3.58	3.90	4.93	6.12	7.05	7.61	7.89	(44)	(45)
	RadStd		0.32	0.56	0.34	0.31	0.29	0.23	0.22	0.23	0.30	0.49	0.39	0.40	(45)	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+165	+111

Nomenclature: See separate page