

WINDORAH, Australia

WMO: 944880

Lat: 25.423S

Lon: 142.656E

Elev: 422

StdP: 14.47

Time Zone: 10.00 (E10)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.0	42.2	14.9	11.9	73.9	18.4	14.1	71.0	24.7	64.1	20.1	65.3	1.5	310	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.7	107.4	69.7	105.0	69.8	102.7	69.6	78.0	90.9	76.6	89.7	75.5	89.2	8.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.3	134.7	81.9	73.7	127.5	82.0	71.7	118.9	82.4	41.8	90.5	40.5	89.0	39.4	88.3	95.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.2	19.0	16.4	DB	35.8	111.8	1.4	2.4	34.7	113.5	33.9	114.9	33.1	116.2	32.0	117.9
			WB	32.0	83.2	2.0	5.1	30.6	86.8	29.4	89.8	28.3	92.6	26.9	96.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.6	88.3	87.1	82.9	74.5	65.7	60.0	58.7	62.4	71.0	76.5	82.4	86.4	(6)
	DBStd	12.19	5.28	5.04	5.42	6.42	5.97	6.64	5.65	6.49	7.41	6.59	6.76	5.94	(7)
	HDD50	4	0	0	0	0	0	2	1	1	0	0	0	0	(8)
	HDD65	630	0	0	0	8	67	181	212	130	29	3	0	0	(9)
	CDD50	8972	1189	1038	1021	734	485	303	270	384	629	820	971	1128	(10)
	CDD65	4122	724	618	556	292	87	32	15	48	208	358	521	663	(11)
	CDH74	56800	11120	9053	7361	3198	743	248	157	619	2584	4589	7153	9975	(12)
	CDH80	32977	7215	5568	4154	1471	170	30	14	154	1189	2430	4226	6356	(13)
(14) Wind	WSAvg	6.1	6.4	7.0	5.5	5.1	4.5	4.4	5.0	6.2	6.6	7.3	7.5	7.2	(14)
(15) Precipitation	PrecAvg	10.6	1.7	2.0	1.1	0.7	0.7	0.5	0.6	0.4	0.4	0.6	0.9	1.0	(15)
	PrecMax	18.9	7.2	9.3	5.8	7.0	4.1	2.9	4.4	2.4	2.0	3.7	4.6	4.7	(16)
	PrecMin	2.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	4.6	1.7	2.4	1.3	1.4	1.1	0.7	1.0	0.5	0.5	0.8	1.1	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	110.4	107.8	105.2	97.5	87.7	83.6	81.8	88.8	97.7	104.6	109.4	109.0	(19)
		MCWB	73.2	70.7	68.7	68.4	63.7	61.9	61.1	62.3	64.1	66.4	69.3	69.7	(20)
	2%	DB	107.2	104.9	101.2	94.0	84.5	80.1	78.0	84.4	94.0	99.7	104.2	106.4	(21)
		MCWB	70.9	72.5	68.6	66.8	63.2	62.5	58.6	61.1	63.5	65.2	67.1	68.6	(22)
	5%	DB	104.5	102.3	98.5	91.4	81.8	77.0	75.2	81.3	91.3	96.1	100.4	103.7	(23)
		MCWB	70.7	72.0	69.5	65.6	61.8	60.3	57.3	59.6	63.1	64.1	67.6	68.4	(24)
	10%	DB	101.9	99.5	95.6	88.5	78.3	73.3	72.0	77.4	87.9	92.7	97.3	101.2	(25)
		MCWB	70.4	71.3	68.7	64.9	60.0	58.2	55.0	57.4	61.2	63.3	67.1	68.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.7	79.8	81.6	74.7	69.1	66.9	64.4	66.9	69.9	71.3	75.4	76.5	(27)
		MCDB	98.6	92.7	88.7	89.6	80.1	77.8	77.6	82.1	89.0	90.0	90.1	89.0	(28)
	2%	WB	77.3	78.3	76.7	72.3	66.6	64.5	61.1	63.9	67.1	69.2	73.7	74.8	(29)
		MCDB	91.4	91.3	88.1	83.1	75.3	75.4	74.1	78.4	84.1	86.6	87.5	89.3	(30)
	5%	WB	76.2	77.1	74.9	70.2	64.8	62.4	58.8	61.3	65.2	67.6	72.2	73.6	(31)
		MCDB	90.2	89.8	87.3	81.6	75.4	73.4	71.3	76.9	83.9	86.8	86.7	89.3	(32)
	10%	WB	74.8	75.9	72.9	67.9	62.9	60.1	56.7	59.1	63.5	66.2	70.9	72.4	(33)
		MCDB	89.8	89.5	87.8	83.1	74.4	70.9	69.5	73.7	83.2	85.7	86.7	89.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	23.7	21.9	23.1	23.6	23.3	23.6	25.0	26.7	27.7	27.0	24.8	24.2	(35)
		MCDBR	27.3	25.3	25.8	26.2	25.2	24.8	27.3	28.5	30.3	30.8	28.3	27.8	(36)
		MCWBR	9.3	8.8	9.5	11.0	11.0	11.8	14.0	13.8	13.3	12.7	10.9	10.5	(37)
	5% WB	MCDBR	20.3	20.0	19.2	20.0	19.7	21.6	23.9	24.1	25.9	24.6	22.0	20.5	(38)
		MCWBR	7.5	6.7	8.4	10.0	9.4	11.1	13.0	12.3	12.9	11.7	8.4	8.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.373	0.365	0.347	0.330	0.313	0.301	0.300	0.313	0.361	0.361	0.375	0.377	(40)
	taud		2.463	2.496	2.528	2.526	2.519	2.550	2.523	2.464	2.346	2.373	2.388	2.414	(41)
	Ebn at Noon		308	305	302	293	285	282	286	294	292	303	305	307	(42)
	Edh at Noon		38	36	33	30	28	26	27	32	39	40	41	40	(43)
(44) All-Sky Solar Radiation	RadAvg		2424	2302	2053	1748	1390	1210	1334	1665	1996	2317	2405	2445	(44)
	RadStd		138	181	121	89	62	76	83	67	138	137	135	157	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page