

ROMA, Australia

WMO: 945150

Lat: 26.544S

Lon: 148.778E

Elev: 308

StdP: 97.68

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.8	0.6	-8.7	1.9	17.8	-7.0	2.2	16.1	9.0	17.4	8.3	17.5	1.1	0	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	38.2	19.6	36.6	19.6	35.2	19.5	23.7	30.0	23.0	29.2	22.4	28.7	4.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.3	17.7	25.5	21.4	16.7	25.1	20.6	15.8	24.9	72.7	29.9	69.8	29.0	67.4	28.6	34.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	8.0	7.2	DB	-3.4	41.2	0.9	2.0	-4.1	42.6	-4.6	43.8	-5.1	44.9	-5.8	46.4	(4)
(5)			WB	-3.3	26.4	1.8	3.3	-4.6	28.8	-5.6	30.7	-6.6	32.6	-7.9	34.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	27.5	26.2	24.5	20.1	15.5	12.6	11.8	13.5	18.0	21.7	24.5	26.5	(6)	
	DBStd	6.40	2.70	2.90	2.64	2.96	3.22	3.26	3.13	3.50	3.85	3.54	3.33	3.06	(7)	
	HDD10.0	34	0	0	0	0	1	11	16	6	0	0	0	0	(8)	
	HDD18.3	712	0	0	1	16	98	172	204	156	53	11	1	0	(9)	
	CDD10.0	3746	543	454	448	304	172	90	71	114	241	362	436	511	(10)	
	CDD18.3	1382	285	221	191	71	10	1	1	6	43	115	187	252	(11)	
	CDH23.3	15678	3379	2412	1920	736	143	14	22	133	637	1362	2037	2883	(12)	
	CDH26.7	7469	1810	1210	846	202	18	1	1	31	228	597	1004	1522	(13)	
(14) Wind	WSAvg	3.4	4.1	3.8	3.4	2.8	2.5	2.6	2.8	3.1	3.5	4.0	4.2	4.2	(14)	
(15) Precipitation	PrecAvg	616	81	62	59	39	45	29	38	34	29	52	64	80	(15)	
	PrecMax	896	215	251	258	208	239	108	181	105	93	210	150	268	(16)	
	PrecMin	384	10	2	0	0	0	0	0	0	0	2	0	7	(17)	
	PrecStd	144	54	50	67	53	46	30	42	22	28	40	48	58	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.7	39.6	37.0	32.4	28.7	24.8	25.8	29.9	34.7	36.7	38.9	40.3	(19)	
		MCWB	20.8	20.2	19.3	18.1	16.1	15.2	14.2	15.2	16.9	18.2	19.1	19.2	(20)	
	2%	DB	37.4	36.9	34.6	30.3	26.5	23.2	23.4	26.6	31.4	34.0	36.5	37.9	(21)	
		MCWB	20.2	19.8	19.7	17.7	16.0	14.7	13.3	14.1	15.7	17.5	18.8	19.4	(22)	
	5%	DB	35.9	34.8	32.6	29.0	24.9	21.8	21.6	24.4	29.2	32.1	34.3	35.6	(23)	
		MCWB	20.2	20.3	19.3	17.1	15.3	14.2	12.7	13.0	15.2	17.1	18.2	19.3	(24)	
	10%	DB	34.3	32.9	31.1	27.6	23.4	20.2	19.9	22.4	27.1	30.1	32.2	33.8	(25)	
		MCWB	20.1	20.2	19.0	16.8	14.6	13.4	12.0	12.1	14.5	16.6	17.9	19.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.9	24.6	23.3	21.7	19.4	18.6	17.4	17.5	19.8	24.0	23.4	23.6	(27)	
		MCDB	31.8	30.3	28.8	26.3	23.8	21.6	22.2	25.8	27.2	29.9	29.8	31.0	(28)	
	2%	WB	23.6	23.6	22.4	20.2	18.0	16.6	15.3	15.7	18.1	20.2	21.5	22.6	(29)	
		MCDB	30.0	29.7	27.9	26.2	22.4	20.4	19.8	22.6	25.2	27.4	28.3	29.9	(30)	
	5%	WB	22.9	22.9	21.7	19.3	16.9	15.5	14.1	14.5	17.0	19.2	20.6	21.9	(31)	
		MCDB	29.4	28.6	27.4	25.2	22.1	19.5	18.7	21.1	25.1	25.8	27.6	28.9	(32)	
	10%	WB	22.2	22.3	21.0	18.3	15.9	14.4	13.1	13.4	16.0	18.2	19.8	21.2	(33)	
		MCDB	28.9	28.1	26.9	24.5	21.5	18.5	18.3	20.3	24.0	25.6	27.5	28.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	11.9	12.9	14.4	15.2	14.3	16.0	17.2	16.4	15.0	13.2	12.7	(35)	
		MCDBR	14.3	14.7	14.9	15.7	16.1	15.4	17.5	19.0	18.5	17.5	16.3	15.8	(36)	
	5% WB	MCWBR	4.4	4.5	4.7	6.3	7.5	8.0	9.0	8.9	7.6	6.7	5.6	5.0	(37)	
		MCWBR	11.3	10.9	11.1	12.0	12.3	11.9	13.1	14.6	14.2	13.2	12.1	11.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.365	0.355	0.334	0.318	0.298	0.290	0.283	0.295	0.331	0.351	0.370	0.369	(40)	
	taud		2.518	2.555	2.606	2.607	2.605	2.640	2.636	2.585	2.470	2.449	2.447	2.487	(41)	
	Ebn at Noon		978	972	964	934	912	900	921	946	950	964	966	976	(42)	
	Edh at Noon		113	107	96	88	79	73	76	88	108	117	121	117	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.26	6.75	5.99	5.09	4.11	3.44	3.89	4.89	5.93	6.74	7.16	7.26	(44)	
	RadStd		0.53	0.55	0.35	0.30	0.19	0.27	0.28	0.31	0.41	0.53	0.70	0.64	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	+1.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+1.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page