

ST GEORGE, Australia

WMO: 945170

Lat: 28.049S

Lon: 148.594E

Elev: 653

StdP: 14.35

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.3	37.8	15.9	12.6	71.2	19.5	15.0	68.7	20.0	67.6	17.9	61.3	2.2	250	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.5	102.7	67.2	99.5	66.7	96.9	66.5	74.8	85.8	73.2	84.8	72.0	84.2	10.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.4	123.1	77.8	70.2	113.9	77.0	68.7	107.9	76.8	38.9	86.0	37.3	84.7	36.2	84.3	94.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.2	18.5	16.2	DB	30.3	107.6	1.9	2.8	28.9	109.6	27.8	111.3	26.8	112.9	25.4	115.0	(4)
(5)			WB	29.8	79.4	1.6	7.2	28.6	84.6	27.6	88.8	26.7	92.9	25.5	98.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.5	83.3	80.8	77.0	69.9	61.1	55.8	54.4	57.5	64.7	71.7	77.8	81.2		
	DBStd	11.75	5.44	5.57	5.19	5.14	5.50	5.27	5.33	6.35	6.85	6.80	6.64	6.17		
	HDD50	28	0	0	0	0	0	9	14	5	0	0	0	0		
	HDD65	1132	0	0	1	16	146	280	330	251	88	19	1	0		
	CDD50	7159	1033	861	837	598	345	182	151	236	441	674	834	967		
	CDD65	2787	568	441	373	163	25	2	3	18	79	228	385	502		
	CDH74	32477	7287	5207	3878	1463	221	13	24	222	1029	2531	4427	6175		
	CDH80	16110	4062	2698	1728	408	23	0	1	56	361	1106	2267	3400		
(14) Wind	WSAvg	7.8	9.2	8.7	8.1	6.8	6.0	6.5	6.2	6.9	7.6	8.7	9.3	9.1		
(15) Precipitation	PrecAvg	21.1	3.4	2.1	2.0	1.3	1.9	0.9	1.3	1.1	1.1	1.6	2.0	2.2		
	PrecMax	35.7	13.1	11.5	14.2	8.0	12.2	3.0	4.8	5.4	4.2	4.0	5.5	6.1		
	PrecMin	11.9	0.4	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.4		
	PrecStd	5.6	3.0	2.1	2.6	2.1	2.1	0.7	1.2	1.1	0.9	1.1	1.5	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.2	104.9	99.6	90.6	82.8	76.0	77.2	85.9	93.6	97.8	104.4	105.5		
		MCWB	69.9	68.6	67.4	63.4	60.3	59.7	57.4	59.0	61.1	63.3	67.1	67.2		
	2%	DB	101.8	99.5	95.2	87.0	79.2	72.4	72.8	79.4	88.2	93.5	99.4	101.7		
		MCWB	67.7	67.4	66.6	63.6	60.4	58.5	55.0	57.8	59.6	62.4	65.3	66.7		
	5%	DB	98.6	96.2	91.7	84.4	76.3	69.8	69.5	75.4	84.1	90.0	95.2	98.2		
		MCWB	67.8	67.8	66.1	63.0	59.2	56.8	54.8	55.5	58.3	62.1	64.3	66.1		
	10%	DB	95.5	92.9	88.7	82.0	73.7	66.8	66.4	71.6	80.0	86.4	91.5	94.8		
		MCWB	67.6	67.5	65.9	61.8	58.1	55.5	53.4	54.0	57.2	61.6	64.1	65.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.7	75.5	73.8	70.5	66.8	63.8	63.4	63.3	65.8	71.9	78.3	78.9		
		MCDB	84.7	87.0	82.0	80.4	74.3	69.7	68.8	78.6	79.5	85.1	87.7	88.4		
	2%	WB	75.1	73.5	72.1	68.0	63.8	61.2	59.2	60.4	63.4	68.1	71.0	73.0		
		MCDB	85.8	84.4	82.2	78.3	72.1	68.2	66.8	72.9	76.3	80.8	83.9	85.3		
	5%	WB	73.4	72.4	70.7	66.0	61.8	59.3	57.0	58.1	61.6	66.2	68.9	71.5		
		MCDB	85.6	84.1	81.7	78.2	72.3	66.3	64.8	70.4	75.9	80.5	82.8	83.2		
	10%	WB	72.1	71.3	69.3	64.1	59.9	57.5	55.0	55.9	59.8	64.3	67.5	70.2		
		MCDB	85.3	83.8	81.1	77.3	70.8	64.4	64.6	68.5	75.6	78.3	82.0	83.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.5	20.1	21.2	23.5	24.1	21.3	24.3	26.8	26.8	24.9	22.5	21.5		
		MCDBR	24.5	24.6	24.8	25.1	26.0	24.7	27.3	30.4	31.3	29.2	26.2	26.1		
	5% WB	MCWBR	7.6	7.1	7.8	9.1	11.1	12.3	13.2	13.6	12.4	10.8	8.8	8.5		
		MCWBR	19.0	18.7	18.4	20.3	20.3	18.3	19.7	24.4	24.0	22.3	20.9	19.8		
(40) Clear-Sky Solar Irradiance	taub		0.364	0.359	0.337	0.319	0.300	0.292	0.287	0.299	0.334	0.351	0.372	0.366		
		taud	2.508	2.534	2.587	2.595	2.597	2.630	2.622	2.564	2.455	2.443	2.434	2.483		
	Ebn at Noon		310	306	304	294	286	282	289	297	299	305	306	310		
		Edh at Noon	36	34	31	28	25	23	24	28	35	37	39	37		
(44) All-Sky Solar Radiation	RadAvg		2365	2182	1916	1603	1268	1046	1180	1499	1858	2142	2291	2363		
	RadStd		151	166	103	86	60	83	77	85	125	154	214	191		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	+2.30	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page