

GOONDIWINDI, Australia

WMO: 945300

Lat: 28.521S

Lon: 150.326E

Elev: 717

StdP: 14.32

Time Zone: 10.00 (E10)

Period: 90-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.7	37.3	22.1	17.1	64.1	25.8	20.3	60.1	21.5	61.4	18.9	60.9	0.4	230	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.9	99.3	69.4	96.2	69.5	93.5	68.8	75.3	87.3	74.1	86.1	72.9	84.9	7.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.6	124.1	78.7	70.9	116.9	78.5	69.5	111.3	78.2	39.3	86.8	38.1	85.9	37.0	84.7	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.2	16.6	14.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	29.8	78.7	2.5	3.0	28.0	80.9	26.5	82.7	25.1	84.4	23.3	86.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.6	80.3	78.9	75.0	68.2	61.3	54.9	53.1	55.9	62.1	68.6	75.0	78.2		
	DBStd	10.91	4.61	5.34	4.47	4.96	4.63	5.43	5.15	5.73	6.35	5.40	6.07	5.04		
	HDD50	53	0	0	0	0	0	14	26	12	1	0	0	0		
	HDD65	1273	0	0	1	24	132	305	371	286	126	26	2	0		
	CDD50	6460	938	810	775	545	350	159	121	197	365	575	750	875		
	CDD65	2204	473	390	310	119	17	1	0	6	40	136	302	410		
	CDH74	23838	5428	4405	3016	1066	106	3	4	89	538	1361	3373	4449		
	CDH80	10655	2764	2142	1192	227	6	0	0	15	152	440	1582	2135		
(14) Wind	WSAvg	4.7	5.5	4.7	4.1	3.6	3.2	3.2	3.7	4.6	5.3	6.0	6.8	5.9		
(15) Precipitation	PrecAvg	24.1	3.3	2.5	2.2	1.7	1.9	0.9	1.5	1.3	1.4	1.9	2.5	2.8		
	PrecMax	36.7	9.3	11.1	6.6	10.7	7.7	2.9	5.2	5.7	4.5	5.7	6.9	9.2		
	PrecMin	13.4	0.2	0.2	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.2	0.0	0.0		
	PrecStd	5.4	2.2	2.3	2.1	2.3	1.5	0.7	1.2	1.1	1.1	1.4	1.7	1.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.5	101.5	98.0	88.6	80.8	74.3	74.0	81.1	89.7	92.6	102.2	100.6		
		MCWB	70.7	72.6	68.5	65.6	62.9	60.2	59.4	60.0	63.5	64.4	65.1	68.6		
	2%	DB	99.0	96.6	92.2	85.0	77.2	71.7	70.2	75.5	85.1	88.3	96.6	97.1		
		MCWB	70.7	71.1	68.4	64.5	61.4	59.3	56.8	57.4	62.2	63.5	68.1	68.6		
	5%	DB	95.4	93.8	89.0	82.2	74.6	68.7	67.8	71.9	80.4	85.2	92.0	93.5		
		MCWB	70.0	70.6	67.7	63.0	60.0	57.3	55.7	55.8	59.8	62.5	65.3	68.5		
	10%	DB	92.4	90.7	86.5	80.0	72.3	65.9	65.0	69.1	76.5	82.2	87.9	90.4		
		MCWB	69.3	69.7	66.7	62.3	59.3	56.5	54.1	54.9	58.8	61.7	64.5	68.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.5	77.0	75.3	70.3	67.5	63.6	63.3	62.5	68.9	69.8	73.4	75.9		
		MCDB	89.1	91.1	83.8	80.0	74.4	69.9	69.3	74.7	83.1	82.6	83.3	88.5		
	2%	WB	74.7	75.6	73.3	68.3	65.0	61.4	60.0	60.3	65.2	67.4	71.1	73.7		
		MCDB	88.2	87.2	83.5	78.9	70.8	67.5	65.9	69.7	76.8	80.1	83.5	88.0		
	5%	WB	73.5	74.4	71.7	66.7	63.4	59.7	57.8	58.6	62.9	65.5	69.3	72.1		
		MCDB	86.5	85.4	81.3	76.8	70.0	66.3	64.3	68.5	74.6	77.6	82.5	85.4		
	10%	WB	72.2	73.1	70.1	64.7	61.7	57.7	55.9	56.9	61.1	64.0	67.9	70.7		
		MCDB	85.1	84.3	80.3	75.1	69.6	64.5	62.8	66.6	73.0	76.1	81.5	83.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.9	21.1	22.3	23.5	21.9	21.7	22.1	25.7	25.5	23.7	23.1	21.4		
		MCDBR	25.3	24.0	25.1	25.9	24.8	23.3	25.4	28.4	30.6	28.3	27.7	25.3		
		MCWBR	7.5	7.1	8.3	9.8	10.9	12.0	13.1	13.4	12.1	9.8	9.1	8.1		
		MCDBR	19.8	20.3	19.2	20.6	15.5	18.5	18.6	24.5	22.5	22.4	20.8	21.1		
	5% WB	MCWBR	7.0	7.1	8.6	9.5	8.3	10.3	10.8	12.2	11.1	9.9	8.2	8.8		
(40) Clear-Sky Solar Irradiance	taub		0.362	0.359	0.334	0.318	0.299	0.292	0.286	0.299	0.332	0.355	0.372	0.369		
	taud		2.524	2.543	2.612	2.612	2.613	2.645	2.638	2.571	2.472	2.442	2.443	2.484		
	Ebn at Noon		311	306	305	294	286	282	288	297	300	304	305	309		
	Edh at Noon		36	34	30	27	24	23	23	28	34	37	38	37		
(44) All-Sky Solar Radiation	RadAvg		2344	2149	1859	1568	1237	1018	1142	1461	1814	2088	2265	2336		
	RadStd		148	169	108	69	58	81	75	89	131	160	201	187		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		+0.90	N/A	N/A	+1.91	N/A	N/A	N/A	N/A	+358	+254

Nomenclature: See separate page