

INVERELL, Australia

WMO: 945410

Lat: 29.7753S

Lon: 151.0819E

Elev: 2179

StdP: 13.57

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.8	36.2	17.2	14.2	62.5	21.0	17.1	59.4	14.6	61.6	13.6	58.9	3.2	180	0.399

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	93.0	65.9	90.1	65.5	87.4	64.9	71.6	82.7	70.0	81.7	68.7	79.9	8.6	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.7	114.5	74.9	66.9	107.2	73.7	65.4	101.7	72.8	36.9	82.9	35.4	81.7	34.2	79.9	92.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.8	12.1	27.9	98.5	2.1	4.8	26.4	102.0	25.2	104.8	24.0	107.5	22.5	110.9		
(5)			29.9	78.8	1.5	6.7	28.8	83.6	27.9	87.6	27.1	91.3	26.0	96.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	73.8	73.3	69.6	64.3	56.0	51.4	49.8	51.7	57.4	63.4	68.2	71.3	(6)
(7)		DBStd	9.81	4.50	4.58	4.04	4.05	4.62	4.62	4.28	4.77	5.23	5.61	5.59	5.12	(7)
(8)		HDD50	149	0	0	0	0	10	40	57	36	4	2	0	0	(8)
(9)		HDD65	2012	1	1	7	58	281	408	473	415	236	96	27	9	(9)
(10)		CDD50	4689	739	652	609	428	195	82	49	87	226	416	547	659	(10)
(11)		CDD65	1075	275	233	151	36	0	0	0	1	7	45	124	203	(11)
(12)		CDH74	9936	2538	2121	1146	288	6	0	0	11	93	505	1298	1930	(12)
(13)		CDH80	3399	1004	820	282	26	0	0	0	3	12	88	449	715	(13)
(14)	Wind	WSAvg	6.1	6.8	6.7	6.2	5.7	5.3	5.5	5.4	5.8	6.0	6.3	6.6	6.7	(14)
(15)	Precipitation	PrecAvg	30.2	4.0	3.2	2.4	1.9	2.1	1.3	2.0	1.8	1.7	2.8	3.1	3.9	(15)
(16)		PrecMax	41.3	10.5	10.5	6.9	8.6	7.1	3.5	6.9	6.1	9.4	6.7	7.1	12.3	(16)
(17)		PrecMin	17.1	0.2	0.7	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.2	0.4	(17)
(18)		PrecStd	6.6	2.7	2.4	1.9	1.9	1.8	0.9	1.5	1.4	1.6	1.6	1.7	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.7	96.6	89.7	83.1	74.7	67.2	67.8	73.5	81.6	87.2	94.8	95.0	(19)
(20)			MCWB	67.2	66.6	65.2	61.1	56.3	53.6	52.8	53.6	61.7	59.4	64.5	65.5	(20)
(21)		2%	DB	92.2	92.3	86.2	79.8	71.6	65.1	64.5	68.9	76.8	82.6	89.5	91.3	(21)
(22)			MCWB	67.0	66.8	64.7	60.3	55.5	52.6	51.3	51.4	56.9	58.9	63.2	64.8	(22)
(23)		5%	DB	89.1	88.6	83.1	77.4	69.1	63.2	61.9	65.9	72.8	79.6	85.3	87.7	(23)
(24)			MCWB	66.5	66.2	64.0	59.7	54.0	51.7	50.0	50.1	54.9	59.0	62.0	63.9	(24)
(25)		10%	DB	85.9	85.0	80.3	74.9	66.7	60.7	59.6	63.0	69.5	76.5	81.7	84.1	(25)
(26)			MCWB	65.9	65.7	63.6	58.8	53.1	50.5	49.3	49.0	53.9	58.6	61.4	63.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.4	73.6	71.3	65.6	60.9	58.1	59.3	58.8	63.9	68.2	69.3	71.6	(27)
(28)			MCDWB	84.5	85.9	79.7	75.5	68.7	61.5	62.0	69.6	75.9	76.1	85.5	83.0	(28)
(29)		2%	WB	71.8	71.3	68.7	63.5	58.6	56.1	55.7	55.3	60.3	64.1	67.0	69.2	(29)
(30)			MCDWB	81.7	84.0	78.3	72.9	65.2	60.0	59.6	61.3	70.0	74.2	80.6	81.9	(30)
(31)		5%	WB	70.2	69.7	67.2	61.9	56.8	54.4	52.9	53.2	58.3	62.3	65.5	67.9	(31)
(32)			MCDWB	81.5	81.1	76.2	71.9	64.2	59.2	58.1	61.4	66.8	73.4	77.6	79.6	(32)
(33)		10%	WB	68.8	68.1	65.8	60.4	55.1	52.8	50.7	51.2	56.3	60.5	64.1	66.6	(33)
(34)			MCDWB	80.1	78.6	74.7	71.0	63.7	58.6	57.1	60.3	65.0	72.1	76.0	77.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.4	21.2	20.4	20.7	20.9	17.7	19.3	21.9	22.5	22.3	22.4	21.8	(35)
(36)			MCDBR	26.4	26.6	24.1	23.7	23.3	20.2	22.3	25.4	26.8	26.5	27.5	27.2	(36)
(37)			MCWBR	8.2	8.0	8.1	8.5	9.9	9.9	11.3	12.2	12.4	10.7	9.6	9.0	(37)
(38)		5% WB	MCDBR	20.1	20.4	18.9	19.9	18.0	14.9	15.9	19.2	20.7	21.9	21.7	20.6	(38)
(39)			MCWBR	8.6	8.1	8.9	8.7	9.3	9.0	10.1	11.2	11.3	10.9	8.9	9.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.337	0.314	0.297	0.276	0.272	0.267	0.278	0.312	0.331	0.347	0.344	(40)	
(41)		taud	2.580	2.600	2.663	2.665	2.676	2.690	2.688	2.631	2.516	2.495	2.501	2.540	(41)	
(42)		Ebn at Noon	318	313	311	301	293	288	294	303	306	311	313	317	(42)	
(43)		Edh at Noon	34	32	28	25	23	21	22	26	32	35	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2277	2056	1761	1473	1169	955	1073	1375	1750	2016	2157	2266	(44)	
(45)		RadStd	154	167	120	75	69	82	78	98	138	168	210	187	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+410	+250

Nomenclature: See separate page