

KINGAROY, Australia

WMO: 945490

Lat: 26.5736S

Lon: 151.8397E

Elev: 1425

StdP: 13.96

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.6	33.6	15.7	12.8	61.8	22.0	17.4	55.1	19.8	57.4	18.1	58.2	1.2	180	0.401

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 20.7	(c) 93.6	(d) 68.1	(e) 91.0	(f) 67.9	(g) 88.1	(h) 67.6	(i) 73.9	(j) 83.3	(k) 72.6	(l) 81.8	(m) 71.5	(n) 80.5	(o) 10.3	(p) 330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.7	123.4	76.8	70.2	117.1	75.6	69.1	112.7	74.8	38.5	83.7	37.3	81.4	36.3	80.7	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	16.0	14.3	25.6	99.4	2.1	3.2	24.1	101.7	22.9	103.5	21.7	105.3	20.2	107.7
			24.3	76.6	2.5	2.0	22.5	78.0	21.1	79.2	19.7	80.3	17.8	81.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	75.5	74.2	71.4	65.7	58.3	54.4	52.6	54.6	61.2	66.7	71.1	73.7		
	DBStd	9.29	4.02	3.99	3.86	3.76	4.70	5.00	4.72	4.81	5.09	5.16	4.78	4.64		
	HDD50	53	0	0	0	0	2	15	25	11	0	0	0	0		
	HDD65	1459	0	0	2	35	211	318	384	325	137	40	6	1		
	CDD50	5489	790	677	663	470	260	148	106	153	336	518	632	736		
	CDD65	1420	325	257	199	55	4	1	0	3	23	93	188	272		
	CDH74	12297	2810	1970	1302	407	75	5	5	68	432	1093	1717	2413		
	CDH80	4357	1162	736	362	48	6	1	0	11	103	333	616	979		
(14) Wind	WSAvg	6.5	7.3	7.6	6.9	6.1	5.5	5.7	5.4	6.1	6.7	6.9	7.1	7.3		
(15) Precipitation	PrecAvg	31.2	4.4	3.6	2.6	1.9	2.0	1.4	1.8	1.3	1.5	2.8	3.2	4.6		
	PrecMax	42.9	11.3	9.9	7.6	8.6	6.6	5.6	8.4	3.9	4.8	6.9	6.2	16.4		
	PrecMin	13.3	0.5	0.6	0.3	0.0	0.2	0.0	0.0	0.0	0.0	0.3	0.1	1.1		
	PrecStd	5.9	2.7	2.1	1.8	2.1	1.5	1.2	1.7	1.1	1.2	1.5	1.5	2.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.0	96.3	92.1	84.3	79.9	73.6	74.2	80.1	87.5	93.1	93.8	97.0		
		MCWB	70.7	71.6	68.5	64.8	60.8	58.9	57.4	57.9	61.0	63.1	65.2	66.8		
	2%	DB	92.9	91.5	87.0	81.0	75.7	70.4	71.2	75.2	82.8	87.0	89.9	92.8		
		MCWB	68.8	70.3	68.8	64.1	59.2	57.8	55.9	56.9	59.6	62.8	64.9	68.0		
	5%	DB	89.7	87.6	84.1	78.5	73.1	68.1	68.1	71.8	78.9	83.6	86.5	89.0		
		MCWB	68.9	69.6	68.0	63.2	58.6	56.6	54.0	55.3	59.2	62.3	65.1	68.0		
	10%	DB	86.4	84.3	81.0	76.0	70.3	65.9	65.6	68.7	75.4	80.3	83.3	85.6		
		MCWB	68.6	69.0	67.3	62.9	57.9	56.0	53.7	53.9	57.9	61.5	64.9	67.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.1	75.9	73.5	69.8	65.4	63.1	64.0	63.1	65.7	69.6	73.2	75.5		
		MCDB	84.1	87.5	82.0	78.0	73.3	68.7	68.4	73.1	77.4	81.3	84.5	85.3		
	2%	WB	73.8	73.6	72.0	67.6	63.2	61.3	60.8	60.5	63.6	67.5	70.1	72.6		
		MCDB	82.8	82.9	79.8	74.6	70.9	66.5	65.7	68.9	74.4	77.4	80.7	82.7		
	5%	WB	72.6	72.2	70.7	66.0	61.6	59.7	58.2	58.5	61.9	65.7	68.4	71.0		
		MCDB	81.6	81.2	78.3	73.1	68.8	64.7	63.7	66.5	72.8	75.6	78.5	80.8		
	10%	WB	71.4	71.0	69.5	64.8	60.2	58.2	56.0	56.6	60.3	64.1	67.0	69.9		
		MCDB	80.4	79.7	77.1	72.0	66.9	63.2	62.3	65.0	70.4	74.1	77.2	79.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.7	19.2	19.2	22.0	25.1	23.0	26.7	29.3	28.0	25.4	23.2	21.7		
		MCDBR	26.7	25.5	24.4	26.3	29.4	26.4	31.0	34.0	33.3	31.2	28.4	27.8		
		MCWBR	8.2	7.9	8.9	11.5	15.0	15.0	17.4	17.6	14.0	11.7	9.2	8.9		
		MCDBR	19.6	19.7	18.9	19.2	21.5	18.0	21.7	25.9	25.5	23.7	22.0	21.0		
	5% WB	MCWBR	7.3	7.3	7.8	9.0	11.8	10.9	13.4	14.5	11.6	9.9	8.4	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.364	0.354	0.335	0.317	0.298	0.290	0.284	0.295	0.329	0.353	0.360	0.373		
	taud		2.527	2.571	2.619	2.646	2.645	2.669	2.669	2.615	2.507	2.472	2.493	2.483		
	Ebn at Noon		310	309	305	297	290	286	292	300	302	305	310	308		
	Edh at Noon		36	33	30	27	24	23	23	27	33	36	36	37		
(44) All-Sky Solar Radiation	RadAvg		2106	1936	1686	1470	1230	1032	1183	1472	1795	1993	2141	2148		
	RadStd		167	178	121	94	61	79	97	113	150	181	206	232		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (25 neighbors)	+0.67	+0.99	N/A	N/A	N/A	N/A	N/A	-126	+329	+198

Nomenclature: See separate page