

JIMNA, Australia

WMO: 945570

Lat: 26.6644S

Lon: 152.4606E

Elev: 1716

StdP: 13.81

Time Zone: 10.00 (E10)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.4	37.0	25.5	20.7	56.7	28.4	23.8	52.7	11.6	56.2	10.0	56.3	0.6	180	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.1	89.3	67.9	86.3	67.6	83.7	67.0	72.9	81.0	71.7	79.2	70.5	77.8	6.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.8	120.8	75.2	69.6	116.0	74.5	68.4	111.0	73.4	37.8	80.9	36.6	79.2	35.6	77.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	12.8	11.2	28.4	95.8	1.9	2.6	27.1	97.6	26.0	99.1	25.0	100.5	23.6	102.4		
(5)			27.8	74.9	1.8	1.3	26.6	75.8	25.6	76.6	24.6	77.3	23.3	78.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.3	72.7	71.5	68.7	64.1	57.6	53.8	52.2	54.4	60.1	64.6	68.7	71.4	(6)	(7)
	DBStd	8.37	4.11	3.47	3.41	3.40	4.17	4.66	4.21	4.87	4.96	4.90	4.68	4.45	(7)	(8)
	HDD50	50	0	0	0	0	1	16	23	10	0	0	0	0	(8)	(9)
	HDD65	1604	0	0	5	53	232	335	397	330	163	69	16	4	(9)	(10)
	CDD50	4895	702	603	580	424	237	131	91	148	302	452	562	663	(10)	(11)
	CDD65	975	238	183	120	27	3	0	0	3	15	56	129	201	(11)	(12)
	CDH74	5946	1462	871	503	136	20	2	1	34	178	560	869	1310	(12)	(13)
	CDH80	1595	467	198	97	8	3	0	0	6	29	135	239	413	(13)	(14)
(14) Wind	WSAvg	4.2	5.4	4.7	4.7	4.1	2.9	2.8	3.0	3.5	3.9	4.8	5.5	5.4	(14)	(15)
(15) Precipitation	PrecAvg	33.7	5.2	5.8	3.7	2.0	1.9	1.9	1.2	1.2	1.5	2.3	2.8	5.0	(15)	(16)
	PrecMax	57.1	20.4	18.9	10.5	5.8	4.8	5.8	4.6	5.0	6.4	7.7	6.7	14.4	(16)	(17)
	PrecMin	19.1	0.4	0.5	0.8	0.0	0.1	0.2	0.0	0.0	0.0	0.4	0.3	1.2	(17)	(18)
	PrecStd	9.3	4.2	4.1	2.3	1.7	1.3	1.5	1.0	1.3	1.4	1.7	1.8	2.8	(18)	(19)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.2	89.9	88.0	80.9	76.2	70.7	70.5	78.2	83.5	89.1	89.9	92.3	(19)	(20)
		MCWB	68.9	72.3	68.8	63.7	60.4	60.9	57.0	58.9	59.8	62.2	66.0	67.5	(20)	(21)
	2%	DB	88.4	85.1	82.3	77.6	72.5	67.2	67.0	72.6	79.2	83.7	86.1	88.0	(21)	(22)
		MCWB	69.5	70.6	68.1	63.8	59.1	58.4	55.2	56.6	59.9	61.7	65.2	67.8	(22)	(23)
	5%	DB	85.2	82.1	79.0	75.1	69.7	64.7	64.5	69.0	75.1	80.0	82.6	84.6	(23)	(24)
		MCWB	68.8	69.6	67.1	63.1	57.8	57.1	54.3	55.8	58.7	61.1	65.4	67.7	(24)	(25)
	10%	DB	81.7	79.4	76.4	72.5	67.0	62.8	62.1	65.8	72.1	76.7	79.1	81.3	(25)	(26)
		MCWB	68.4	68.7	66.2	62.6	57.4	56.5	53.9	53.8	57.6	60.8	65.2	67.1	(26)	(27)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	75.0	72.7	69.7	64.5	63.5	62.8	62.7	65.8	68.5	70.5	73.1	(27)	(28)
		MCDB	82.8	85.1	78.8	75.8	71.7	67.3	66.4	72.2	74.7	77.7	80.7	83.3	(28)	(29)
	2%	WB	72.7	73.2	70.9	67.2	62.1	61.5	59.8	60.1	63.3	66.1	68.9	71.5	(29)	(30)
		MCDB	81.1	80.5	77.1	71.8	67.7	64.5	61.9	67.8	71.5	74.7	78.2	80.5	(30)	(31)
	5%	WB	71.5	71.6	69.3	65.6	60.7	59.7	57.2	58.3	61.5	64.6	67.5	70.2	(31)	(32)
		MCDB	79.0	78.3	75.3	71.1	65.6	62.7	62.3	64.8	69.5	73.3	76.1	78.1	(32)	(33)
	10%	WB	70.3	70.1	67.9	64.2	59.4	58.0	55.1	56.5	59.9	63.0	66.3	69.1	(33)	(34)
		MCDB	77.9	76.2	73.9	69.8	63.8	61.2	59.4	62.8	68.0	71.8	74.5	76.4	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	17.1	14.9	15.4	17.3	19.1	17.1	20.1	23.3	22.7	22.1	19.3	17.9	(35)	(36)
		MCDBR	24.0	20.4	20.5	21.9	23.8	19.7	24.1	27.7	28.4	28.8	24.9	24.0	(36)	(37)
	5% WB	MCWBR	7.5	7.3	8.1	9.9	12.2	11.6	13.9	13.2	11.7	10.5	7.6	8.1	(37)	(38)
		MCWBR	18.2	17.1	16.3	15.8	15.6	14.5	16.9	20.6	22.0	21.7	19.1	18.9	(38)	(39)
(40) Clear-Sky Solar Irradiance	taub		0.364	0.354	0.335	0.317	0.298	0.291	0.283	0.294	0.328	0.349	0.354	0.370	(40)	(41)
		taud	2.522	2.561	2.616	2.647	2.651	2.670	2.682	2.624	2.515	2.486	2.507	2.488	(41)	(42)
	Ebn at Noon		311	308	305	297	290	285	293	300	303	306	311	309	(42)	(43)
		Edh at Noon	36	34	30	27	24	23	23	27	33	36	36	37	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		2029	1859	1610	1423	1199	1009	1164	1442	1757	1931	2083	2075	(44)	(45)
	RadStd		181	172	116	92	67	78	99	116	151	183	206	239	(45)	(46)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.61	N/A	N/A	N/A	N/A	N/A	N/A	-112	+317	+196

Nomenclature: See separate page