

GYMPIE, Australia

WMO: 945660

Lat: 26.1831S

Lon: 152.6414E

Elev: 213

StdP: 14.58

Time Zone: 10.00 (E10)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.9	38.6	28.2	22.4	61.4	31.5	26.0	55.6	14.5	66.4	13.4	67.2	0.5	0	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.7	93.7	73.0	90.8	72.4	88.4	71.8	77.7	85.8	76.3	84.5	75.1	83.1	7.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.8	135.9	80.8	74.2	128.7	79.5	72.9	123.0	78.5	41.4	85.8	40.0	84.2	38.8	83.4	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.4	13.0	11.6	DB	31.0	101.1	2.3	2.9	29.4	103.2	28.0	105.0	26.7	106.6	25.1	108.7	(4)
(5)			WB	30.5	79.3	2.3	1.9	28.8	80.7	27.4	81.8	26.1	82.8	24.4	84.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.2	77.4	76.6	74.3	69.2	62.8	59.0	57.3	59.0	65.0	69.5	73.0	76.1
	DBStd	8.31	3.84	3.54	3.36	3.34	4.33	4.63	4.42	4.59	4.90	4.94	4.69	4.43
	HDD50	2	0	0	0	0	0	0	1	1	0	0	0	0
	HDD65	794	0	0	0	5	94	185	243	196	58	11	2	0
	CDD50	6649	849	745	752	577	397	271	227	279	450	604	690	808
	CDD65	1966	384	325	287	133	26	5	4	10	58	150	241	343
	CDH74	15359	3182	2494	1822	718	179	29	29	159	683	1294	1906	2864
	CDH80	5027	1185	861	504	100	13	1	1	21	166	412	651	1112
Wind	WSAvg	3.9	4.9	4.8	4.5	3.8	2.8	3.0	2.8	3.3	4.0	4.4	4.5	4.7
Precipitation	PrecAvg	42.7	6.8	6.3	4.7	3.1	3.1	2.1	2.3	1.5	1.6	2.9	3.8	5.5
	PrecMax	69.5	26.0	27.1	15.9	15.9	9.4	13.8	20.7	3.8	5.2	12.2	8.6	11.7
	PrecMin	23.6	1.5	0.6	0.5	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.5	0.4
	PrecStd	10.3	5.3	5.7	3.5	3.1	2.2	2.6	3.4	1.1	1.3	2.2	2.0	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.6	95.8	92.1	86.3	81.7	77.3	77.2	82.7	89.4	93.1	94.6	97.4
		MCWB	75.3	75.8	74.2	69.1	65.1	64.0	61.8	62.2	65.7	68.6	69.4	71.6
	2%	DB	92.5	91.4	88.3	82.6	78.2	74.0	73.9	78.1	84.5	88.0	89.8	92.5
		MCWB	74.3	74.9	73.5	68.5	64.4	62.8	59.8	61.1	64.1	66.9	69.6	72.6
	5%	DB	89.1	87.9	85.2	80.4	75.8	71.6	71.5	75.0	81.1	84.6	86.7	89.2
		MCWB	73.7	74.2	72.2	67.7	63.4	61.1	58.9	59.5	63.1	66.6	69.2	72.1
	10%	DB	86.3	85.2	82.5	78.3	73.4	69.5	69.2	72.1	77.9	81.2	83.7	86.1
		MCWB	72.9	72.7	71.3	67.1	62.6	60.3	58.2	58.0	62.2	65.7	68.5	71.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.8	79.9	78.2	73.4	70.9	67.7	67.3	66.8	69.3	72.8	74.5	77.6
		MCDB	86.6	89.0	84.4	80.8	75.7	72.2	72.3	76.4	80.7	83.6	85.2	87.9
	2%	WB	77.8	77.4	76.1	71.3	68.2	65.7	64.5	64.7	67.6	71.1	72.7	75.8
		MCDB	85.4	86.0	83.1	78.0	73.9	70.5	69.6	72.5	77.5	80.8	82.1	85.6
	5%	WB	76.3	75.9	74.6	70.0	66.2	63.9	62.1	62.6	66.1	69.6	71.4	74.5
		MCDB	84.3	83.8	81.4	76.4	72.5	68.6	67.6	70.8	75.9	78.6	80.7	83.7
	10%	WB	74.9	74.6	73.4	68.8	64.7	62.4	60.2	60.6	64.7	68.0	70.2	73.3
		MCDB	82.7	81.7	79.6	75.2	70.7	67.3	66.1	68.1	74.0	76.5	79.5	81.5
Mean Daily Temperature Range	5% DB	MDBR	17.7	16.9	16.9	19.2	22.6	22.1	26.3	28.6	26.8	23.3	20.9	19.4
		MCDBR	23.1	22.1	22.0	22.5	26.3	24.7	29.5	32.3	31.5	28.6	25.6	24.6
		MCWBR	7.3	7.4	8.4	9.7	13.1	13.8	15.8	15.5	12.6	10.3	8.0	7.8
	5% WB	MCDBR	18.3	18.7	16.9	17.3	18.7	17.8	20.7	25.2	24.8	22.1	20.0	20.2
MCWBR		6.9	7.0	7.4	8.3	10.3	10.8	12.5	13.3	10.5	8.4	7.1	7.4	
Clear-Sky Solar Irradiance	taub	0.387	0.380	0.361	0.338	0.322	0.312	0.302	0.314	0.356	0.376	0.380	0.396	
	taud	2.499	2.525	2.576	2.625	2.610	2.638	2.648	2.598	2.469	2.448	2.472	2.454	
	Ebn at Noon	303	300	297	290	282	278	286	294	294	298	303	301	
	Edh at Noon	37	35	31	28	25	23	24	28	35	37	37	38	
All-Sky Solar Radiation	RadAvg	2048	1870	1623	1431	1204	1019	1173	1451	1769	1941	2097	2094	
	RadStd	175	167	122	99	65	78	101	115	144	174	202	237	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.99	+2.34	N/A	N/A	N/A	N/A	N/A	-211	+437	N/A
(47) Regional (22 neighbors)		+0.67	+1.01	N/A	N/A	N/A	N/A	N/A	-126	+329	+198

Nomenclature: See separate page