

GYMPIE, Australia

WMO: 945660

Lat: 26.1831S

Lon: 152.6414E

Elev: 65

StdP: 100.55

Time Zone: 10.00 (E10)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.2	3.7	-2.1	3.2	16.3	-0.3	3.7	13.1	6.5	19.1	6.0	19.5	0.2	0	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	34.3	22.8	32.7	22.4	31.3	22.1	25.4	29.9	24.6	29.2	24.0	28.4	3.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.3	19.4	27.1	23.4	18.4	26.4	22.7	17.6	25.8	78.3	29.9	75.1	29.0	72.4	28.5	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.8	5.2	DB	-0.6	38.4	1.3	1.6	-1.5	39.6	-2.2	40.5	-2.9	41.4	-3.8	42.6	(4)
(5)			WB	-0.8	26.3	1.3	1.0	-1.8	27.0	-2.5	27.6	-3.3	28.2	-4.2	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	25.2	24.8	23.5	20.7	17.1	15.0	14.0	15.0	18.3	20.8	22.8	24.5	(6)	
	DBStd	4.62	2.13	1.97	1.87	1.85	2.41	2.57	2.46	2.55	2.72	2.74	2.61	2.46	(7)	
	HDD10.0	1	0	0	0	0	0	0	1	1	0	0	0	0	(8)	
	HDD18.3	441	0	0	0	3	52	103	135	109	32	6	1	0	(9)	
	CDD10.0	3694	472	414	418	321	221	151	126	155	250	336	383	449	(10)	
	CDD18.3	1092	213	181	159	74	14	3	2	6	32	83	134	191	(11)	
	CDH23.3	8533	1768	1386	1012	399	99	16	16	88	379	719	1059	1591	(12)	
(13)	CDH26.7	2793	658	478	280	56	7	1	1	12	92	229	362	618	(13)	
(14)	Wind	WSAvg	1.8	2.2	2.1	2.0	1.7	1.2	1.3	1.2	1.5	1.8	2.0	2.0	2.1	(14)
(15) Precipitation	PrecAvg	1085	172	159	119	80	78	54	59	38	41	73	96	139	(15)	
	PrecMax	1766	660	689	403	405	240	351	525	97	131	310	219	298	(16)	
	PrecMin	600	38	14	13	6	1	3	1	1	0	1	12	9	(17)	
	PrecStd	262	135	144	88	79	57	67	86	29	32	56	52	74	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.9	35.5	33.4	30.1	27.6	25.1	25.1	28.2	31.9	34.0	34.8	36.4	(19)	
		MCWB	24.1	24.4	23.4	20.6	18.4	17.8	16.6	16.8	18.7	20.3	20.8	22.0	(20)	
	2%	DB	33.6	33.0	31.3	28.1	25.7	23.3	23.3	25.6	29.2	31.1	32.1	33.6	(21)	
		MCWB	23.5	23.8	23.1	20.3	18.0	17.1	15.5	16.2	17.8	19.4	20.9	22.6	(22)	
	5%	DB	31.7	31.1	29.6	26.9	24.3	22.0	22.0	23.9	27.3	29.2	30.4	31.8	(23)	
		MCWB	23.1	23.4	22.4	19.9	17.4	16.2	14.9	15.3	17.3	19.2	20.7	22.3	(24)	
	10%	DB	30.2	29.5	28.1	25.7	23.0	20.8	20.7	22.3	25.5	27.3	28.7	30.0	(25)	
		MCWB	22.7	22.6	21.8	19.5	17.0	15.7	14.6	14.4	16.8	18.7	20.3	21.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	26.6	25.7	23.0	21.6	19.9	19.6	19.3	20.7	22.7	23.6	25.3	(27)	
		MCDB	30.3	31.7	29.1	27.1	24.3	22.3	22.4	24.7	27.0	28.6	29.6	31.1	(28)	
	2%	WB	25.4	25.2	24.5	21.8	20.1	18.7	18.1	18.2	19.8	21.7	22.6	24.3	(29)	
		MCDB	29.7	30.0	28.4	25.5	23.3	21.4	20.9	22.5	25.3	27.1	27.8	29.8	(30)	
	5%	WB	24.6	24.4	23.7	21.1	19.0	17.7	16.7	17.0	19.0	20.9	21.9	23.6	(31)	
		MCDB	29.1	28.8	27.4	24.7	22.5	20.4	19.8	21.6	24.4	25.9	27.1	28.7	(32)	
	10%	WB	23.8	23.6	23.0	20.4	18.1	16.9	15.7	15.9	18.2	20.0	21.2	22.9	(33)	
		MCDB	28.1	27.6	26.4	24.0	21.5	19.6	19.0	20.1	23.3	24.7	26.4	27.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	9.4	9.4	10.7	12.6	12.3	14.6	15.9	14.9	12.9	11.6	10.8	(35)	
		MCDBR	12.8	12.3	12.2	12.5	14.6	13.7	16.4	17.9	17.5	15.9	14.2	13.7	(36)	
	5% WB	MCWBR	4.1	4.1	4.7	5.4	7.3	7.6	8.8	8.6	7.0	5.7	4.4	4.3	(37)	
		MCWBR	10.2	10.4	9.4	9.6	10.4	9.9	11.5	14.0	13.8	12.3	11.1	11.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.387	0.380	0.361	0.338	0.322	0.312	0.302	0.314	0.356	0.376	0.380	0.396	(40)	
		taud	2.499	2.525	2.576	2.625	2.610	2.638	2.648	2.598	2.469	2.448	2.472	2.454	(41)	
	Ebn at Noon		956	947	937	915	888	877	901	927	926	940	956	949	(42)	
		Edh at Noon	116	110	99	87	80	74	76	87	109	117	118	121	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.46	5.89	5.12	4.51	3.80	3.21	3.70	4.57	5.58	6.12	6.61	6.60	(44)	
	RadStd		0.55	0.53	0.39	0.31	0.21	0.25	0.32	0.36	0.45	0.55	0.64	0.75	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.55	+1.30	N/A	N/A	N/A	N/A	N/A	-117	+243	N/A
(47)	Regional (22 neighbors)	+0.37	+0.56	N/A	N/A	N/A	N/A	N/A	-70	+183	+110

Nomenclature: See separate page