

SUNSHINE COAST, Australia

WMO: 945690

Lat: 26.6006S

Lon: 153.0903E

Elev: 4

StdP: 101.28

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	6.9	-1.3	3.4	16.4	1.0	4.1	14.5	10.0	18.8	9.1	18.0	2.7	270	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.2	30.3	23.9	29.3	23.7	28.6	23.3	25.8	28.5	25.1	27.8	24.5	27.2	6.6	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	20.1	27.6	24.3	19.2	26.9	23.6	18.5	26.4	79.9	28.5	77.0	28.0	74.2	27.3	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.8	8.9	2.8	34.4	1.0	2.1	2.1	35.9	1.5	37.1	0.9	38.3	0.2	39.8		
			2.2	26.9	0.9	0.9	1.5	27.5	0.9	28.0	0.4	28.5	-0.3	29.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	24.9	24.8	23.7	21.2	18.2	16.1	15.2	15.8	18.2	20.2	22.1	23.8		
	DBStd	3.94	1.52	1.44	1.47	1.66	2.13	2.30	2.21	2.26	2.18	2.05	1.86	1.69		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	318	0	0	0	2	27	71	101	84	28	5	1	0		
	CDD10.0	3773	462	413	426	337	256	184	160	179	247	318	364	427		
	CDD18.3	1050	204	180	168	88	25	5	2	5	24	64	115	169		
	CDH23.3	6177	1539	1314	1006	312	48	6	8	27	89	238	538	1051		
(14) Wind	WSAvg	4.7	5.4	5.4	5.1	4.6	4.0	3.9	3.9	4.1	4.4	4.9	5.1	5.2		
	PrecAvg	1633	216	255	210	158	132	113	68	65	57	89	108	162		
	PrecMax	2944	692	767	540	389	380	304	243	359	188	292	227	616		
	PrecMin	1108	42	37	75	16	3	23	9	0	3	20	21	38		
	PrecStd	418	142	196	116	80	84	81	49	77	47	59	50	117		
	DB	31.5	31.1	30.0	28.4	26.1	24.1	24.4	26.0	28.1	30.2	30.3	31.7			
	MCWB	25.4	24.6	24.1	21.7	19.7	18.2	16.9	16.9	18.4	19.2	21.4	23.7			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	29.9	29.8	28.7	26.8	24.6	22.6	22.4	23.6	25.4	26.8	28.2	29.4			
	2% MCWB	24.2	24.5	23.6	21.3	19.1	17.6	16.2	16.7	18.7	20.6	22.4	23.8			
	5% DB	29.1	28.9	27.9	25.9	23.6	21.6	21.1	22.1	24.1	25.5	27.1	28.4			
	5% MCWB	23.9	23.9	22.9	20.9	18.7	17.1	16.0	16.3	18.6	20.4	21.8	23.2			
	10% DB	28.2	28.1	27.1	25.1	22.7	20.7	20.1	21.0	23.1	24.5	26.1	27.5			
	10% MCWB	23.4	23.1	22.4	20.4	18.2	16.6	15.4	15.8	18.0	19.9	21.2	22.7			
	WB	26.7	26.9	25.9	23.6	22.3	20.5	19.8	19.8	21.6	23.1	24.4	26.0			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	29.5	30.3	28.1	26.3	23.8	21.9	22.3	23.4	24.8	26.1	28.2	29.3			
	2% WB	25.8	25.7	24.8	22.6	20.9	19.3	18.5	18.8	20.5	22.2	23.5	25.1			
	2% MCDB	28.3	28.4	27.4	25.3	23.1	21.1	20.6	21.8	23.8	25.2	27.0	28.2			
	5% WB	25.1	24.9	24.0	21.9	19.9	18.4	17.3	17.9	19.7	21.4	22.7	24.3			
	5% MCDB	27.7	27.5	26.9	24.8	22.4	20.5	19.8	20.8	22.9	24.3	25.9	27.1			
	10% WB	24.4	24.2	23.2	21.2	19.1	17.6	16.4	17.0	19.0	20.6	22.0	23.6			
	10% MCDB	27.1	26.7	26.2	24.1	21.7	19.8	19.1	19.8	22.1	23.5	25.0	26.3			
(35) Mean Daily Temperature Range	MDBR	6.2	6.2	6.6	7.7	8.9	9.0	10.4	11.1	9.9	8.2	7.5	6.8			
	5% DB	7.5	7.5	7.7	8.9	10.1	9.9	11.6	12.7	11.2	9.9	8.8	8.2			
	5% MCWBR	3.4	3.5	3.7	4.6	5.4	5.7	6.6	6.9	6.2	5.3	4.5	4.2			
	5% WB	6.5	6.7	6.8	7.7	7.8	7.4	9.2	10.1	9.3	8.1	7.6	7.3			
	5% MCWBR	3.5	3.8	3.7	4.4	4.6	4.9	6.1	6.3	5.6	4.9	4.3	4.1			
(40) Clear-Sky Solar Irradiance	taub	0.396	0.385	0.363	0.346	0.322	0.316	0.307	0.321	0.357	0.378	0.383	0.397			
	taud	2.498	2.537	2.599	2.622	2.643	2.655	2.662	2.600	2.495	2.471	2.491	2.479			
	Ebn at Noon	948	942	934	905	887	871	895	918	924	938	953	948			
	Edh at Noon	116	108	97	87	77	73	75	87	106	115	116	118			
(44) All-Sky Solar Radiation	RadAvg	6.58	6.05	5.21	4.48	3.71	3.12	3.62	4.50	5.55	6.16	6.75	6.69			
	RadStd	0.56	0.51	0.36	0.26	0.20	0.23	0.30	0.36	0.43	0.52	0.57	0.73			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.35	N/A	N/A	N/A	N/A	-0.81	N/A	-61	+195	+121
(47)	Regional (24 neighbors)	+0.35	N/A	N/A	N/A	N/A	N/A	N/A	-66	+179	+109

Nomenclature: See separate page