

TEWANTIN, Australia

WMO: 945700

Lat: 26.3911S

Lon: 153.0403E

Elev: 8

StdP: 101.23

Time Zone: 10.00 (E10)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	9.0	0.1	3.8	16.2	2.1	4.4	15.5	7.2	18.3	6.5	18.3	0.5	300	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.3	30.7	23.2	29.3	23.4	28.4	23.0	25.5	28.5	24.8	27.7	24.2	27.0	4.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.6	19.6	27.0	24.0	18.9	26.6	23.3	18.1	26.1	78.5	28.7	75.7	27.9	73.3	27.0	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.8	6.2	5.4	35.5	1.0	2.4	4.7	37.2	4.1	38.6	3.6	40.0	2.9	41.7		
(5)			4.0	26.4	1.0	0.7	3.3	26.9	2.7	27.4	2.2	27.8	1.5	28.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	25.0	24.8	24.0	21.7	18.8	16.7	16.0	16.7	19.0	20.9	22.3	24.0
	DBStd	3.69	1.57	1.61	1.37	1.53	1.96	2.14	1.99	2.03	2.12	2.13	1.79	1.82
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	229	0	1	0	1	18	56	77	59	16	2	0	0
	CDD10.0	3943	466	416	433	351	273	201	185	207	271	338	369	434
	CDD18.3	1131	207	183	175	102	33	7	3	8	36	82	120	176
	CDH23.3	6106	1499	1287	984	304	53	7	7	34	128	284	464	1053
CDH26.7	857	242	193	98	16	1	0	1	3	20	57	50	178	
Wind	WSAvg	2.8	3.4	3.4	3.3	2.8	2.1	2.1	2.0	2.2	2.7	3.0	3.2	3.3
Precipitation	PrecAvg	1678	213	234	213	170	162	104	97	60	49	89	147	160
	PrecMax	2626	1132	1229	571	695	455	597	715	174	140	270	377	399
	PrecMin	884	18	20	30	28	24	20	7	0	0	5	12	15
	PrecStd	411	206	224	155	127	107	127	122	47	38	64	75	101
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.6	32.1	30.4	28.5	26.2	24.3	24.1	26.3	29.0	31.5	30.5	33.1
		MCWB	25.2	24.3	23.9	21.2	18.8	18.2	17.3	17.4	19.2	20.0	21.7	23.8
	2%	DB	29.7	29.5	28.7	26.7	24.7	22.7	22.5	24.0	26.5	27.9	27.8	30.1
		MCWB	24.3	24.1	23.5	21.1	18.9	17.3	16.4	16.7	18.6	20.3	22.1	23.3
	5%	DB	28.7	28.6	27.7	25.8	23.6	21.7	21.3	22.5	24.5	25.8	26.6	28.3
		MCWB	23.7	23.7	22.8	20.6	18.4	16.9	16.1	16.1	18.1	20.2	21.6	23.1
	10%	DB	27.9	27.7	26.9	25.0	22.8	20.7	20.2	21.2	23.2	24.6	25.6	27.3
		MCWB	23.2	22.9	22.2	20.2	17.9	16.5	15.5	15.8	17.9	19.9	21.0	22.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.3	26.4	25.6	23.7	21.9	20.1	20.0	20.1	21.3	23.0	24.2	25.7
		MCDB	29.3	30.0	28.2	26.5	23.8	21.6	21.8	24.0	25.0	26.8	27.3	30.0
	2%	WB	25.4	25.5	24.6	22.4	20.6	19.1	18.8	18.8	20.5	22.1	23.3	24.7
		MCDB	28.4	28.2	26.9	25.0	23.0	21.1	20.7	21.8	24.0	25.4	26.1	28.1
	5%	WB	24.7	24.7	24.0	21.7	19.7	18.2	17.6	17.9	19.7	21.3	22.6	24.1
		MCDB	27.6	27.5	26.4	24.5	22.2	20.4	19.8	20.9	23.1	24.5	25.4	27.0
	10%	WB	24.1	23.9	23.4	21.0	19.0	17.6	16.6	17.0	18.9	20.6	21.9	23.4
		MCDB	26.9	26.7	25.9	24.0	21.6	19.7	19.2	19.8	22.2	23.7	24.8	26.3
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.3	5.7	6.5	7.9	8.0	9.0	9.7	8.7	7.2	6.2	5.9
		MCDBR	6.5	6.7	7.0	7.7	9.1	8.7	10.1	11.7	10.9	9.7	7.6	7.7
		MCWBR	2.9	2.9	3.1	3.4	4.3	4.5	5.2	5.7	5.0	4.4	3.5	3.5
	5% WB	MCDBR	6.1	6.3	6.1	6.4	6.8	6.8	7.8	9.2	8.8	8.0	6.6	7.1
		MCWBR	2.9	3.1	3.1	3.2	3.7	3.9	4.6	5.0	4.4	4.0	3.3	3.5
Clear-Sky Solar Irradiance	taub	0.393	0.384	0.365	0.344	0.324	0.317	0.307	0.320	0.357	0.378	0.383	0.395	
	taud	2.504	2.539	2.591	2.630	2.634	2.651	2.661	2.604	2.495	2.469	2.491	2.484	
	Ebn at Noon	950	943	933	908	885	872	896	920	925	938	954	950	
	Edh at Noon	115	108	98	86	78	73	75	87	106	115	116	118	
All-Sky Solar Radiation	RadAvg	6.58	6.04	5.21	4.50	3.73	3.15	3.64	4.53	5.57	6.17	6.75	6.70	
	RadStd	0.56	0.51	0.37	0.28	0.20	0.24	0.31	0.36	0.43	0.52	0.58	0.74	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.43	N/A	N/A	N/A	+0.73	+1.01	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	+0.35	+0.52	N/A	N/A	N/A	N/A	N/A	-66	+180	+110

Nomenclature: See separate page