

BRISBANE ARCHERFIELD, Australia

WMO: 945750

Lat: 27.5716S Lon: 153.0070E Elev: 13 StdP: 101.17 Time Zone: 10.00 (E10) Period: 94-19 WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 5.5	(c) 6.7	(d) -2.7	(e) 3.0	(f) 17.1	(g) -0.8	(h) 3.5	(i) 15.9	(j) 10.2	(k) 18.1	(l) 9.0	(m) 17.4	(n) 1.6	(o) 190	(p) 0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 8.4	(c) 33.0	(d) 22.8	(e) 31.6	(f) 22.6	(g) 30.4	(h) 22.2	(i) 25.1	(j) 29.9	(k) 24.4	(l) 28.8	(m) 23.8	(n) 27.9	(o) 5.5	(p) 30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.8	18.7	26.8	23.1	17.9	26.5	22.5	17.3	26.1	76.9	29.9	74.0	28.9	71.4	28.0	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
							Mean		Standard Deviation		n=5 years		n=10 years		n=20 years	
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	DB	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	8.3	7.4		2.6	37.4	1.2	2.2	1.7	39.0	1.0	40.3	0.4	41.6	-0.5	43.2	
			WB	1.7	26.3	1.4	0.7	0.6	26.8	-0.2	27.3	-1.0	27.7	-2.0	28.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	25.4	24.9	23.6	20.9	17.9	15.5	14.7	15.6	18.5	20.8	22.9	24.3
	DBStd	4.26	2.09	1.95	1.81	1.71	1.97	2.04	1.95	2.00	2.26	2.34	2.37	2.22
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	350	0	0	0	2	31	86	113	89	24	4	1	0
	CDD10.0	3797	478	418	423	328	246	166	147	173	256	334	386	442
	CDD18.3	1106	220	185	164	79	18	2	2	4	30	80	136	184
	CDH23.3	7847	1821	1436	1072	412	88	9	11	53	244	501	864	1335
	CDH26.7	2128	592	432	256	53	3	0	1	6	46	117	230	392
Wind	WSAvg	3.4	4.0	3.8	3.4	3.0	2.8	2.9	2.9	3.1	3.5	3.7	4.0	3.9
Precipitation	PrecAvg	1177	148	155	133	100	101	68	65	42	31	94	120	135
	PrecMax	1964	622	448	458	462	551	494	375	138	97	395	392	444
	PrecMin	589	22	31	5	8	4	2	0	0	0	17	11	37
	PrecStd	335	120	111	108	103	119	99	77	32	29	77	92	84
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.4	34.1	32.8	29.7	27.0	24.5	24.8	27.1	30.7	32.5	33.5	34.4
		MCWB	24.1	24.0	23.5	20.1	18.0	17.1	15.8	16.8	17.2	18.7	20.8	22.3
	2%	DB	32.6	32.0	30.6	28.1	25.3	22.8	22.7	24.6	27.7	29.5	30.9	31.8
		MCWB	24.0	23.7	22.5	19.8	17.5	16.1	14.9	15.5	17.7	19.5	21.5	22.6
	5%	DB	31.0	30.6	29.2	27.0	24.2	21.7	21.5	23.0	25.9	27.6	29.2	30.2
		MCWB	23.2	22.9	21.7	19.4	17.1	15.7	14.5	15.0	17.0	19.1	20.8	22.2
	10%	DB	29.7	29.3	28.0	25.7	23.1	20.5	20.3	21.6	24.4	26.1	27.7	28.8
		MCWB	22.6	22.3	21.2	18.9	16.8	15.2	13.9	14.2	16.5	18.6	20.3	21.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	25.9	25.0	22.7	21.7	19.2	19.0	19.1	20.9	22.5	24.0	25.1
		MCDB	30.9	31.8	28.7	25.9	22.7	21.2	22.5	23.8	25.9	27.6	29.3	31.1
	2%	WB	25.2	25.0	23.9	21.6	20.1	18.1	17.5	17.8	19.8	21.5	23.0	24.0
		MCDB	30.1	29.5	28.1	25.4	22.9	20.6	20.0	21.4	24.3	26.1	27.7	29.2
	5%	WB	24.5	24.3	23.2	20.8	19.0	17.3	16.3	16.7	19.0	20.6	22.2	23.4
		MCDB	28.9	28.3	27.1	24.7	22.2	20.0	19.3	20.5	23.2	25.0	26.8	27.9
	10%	WB	23.8	23.6	22.5	20.0	18.1	16.4	15.2	15.7	18.1	19.8	21.5	22.7
		MCDB	27.8	27.4	26.4	23.9	21.5	19.3	18.7	19.6	22.3	24.1	25.9	26.8
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.4	9.0	10.3	11.1	10.7	12.2	13.2	12.4	10.6	9.3	8.7
		MCDBR	10.1	10.1	10.6	11.8	12.5	12.0	13.9	15.2	14.6	12.8	11.0	10.4
		MCWBR	3.4	3.5	3.8	4.8	5.7	6.2	7.0	7.2	6.1	5.1	4.0	3.8
	5% WB	MCDBR	9.0	8.7	8.8	9.8	8.9	9.2	10.5	12.0	11.5	11.0	9.8	9.1
MCWBR		3.6	3.4	3.6	4.5	4.8	5.3	6.2	6.5	5.4	4.9	4.0	3.8	
Clear-Sky Solar Irradiance	taub		0.390	0.379	0.358	0.339	0.318	0.313	0.301	0.315	0.358	0.378	0.383	0.396
	taud		2.494	2.535	2.590	2.623	2.632	2.641	2.659	2.597	2.472	2.450	2.474	2.463
	Ebn at Noon		952	947	937	909	887	870	897	921	922	937	953	949
	Edh at Noon		116	108	97	86	77	73	74	86	107	117	117	120
All-Sky Solar Radiation	RadAvg		6.50	5.96	5.15	4.43	3.69	3.04	3.54	4.43	5.45	6.05	6.60	6.54
	RadStd		0.53	0.51	0.31	0.22	0.20	0.22	0.28	0.33	0.43	0.55	0.56	0.69

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.39	+0.80	N/A	N/A	N/A	-0.57	N/A	-75	+174
(47) Regional (28 neighbors)		+0.41	+0.52	N/A	N/A	N/A	N/A	N/A	-67	+186