

BRISBANE RAYMOND PARK, Australia

WMO: 945760

Lat: 27.4808S

Lon: 153.0389E

Elev: 8

StdP: 101.23

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	9.3	-2.5	3.1	17.7	-0.4	3.6	17.0	6.6	17.9	5.7	17.2	1.1	220	0.282

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.2	32.5	23.0	31.2	23.0	30.1	22.5	25.1	30.0	24.4	29.0	23.9	28.1	3.6	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.7	18.5	27.6	23.1	17.9	27.0	22.5	17.2	26.6	76.8	30.1	74.1	29.1	71.7	28.1	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	5.8	5.0	5.6	35.7	1.4	1.6	4.6	36.8	3.8	37.8	3.0	38.6	2.0	39.8		
(5)			3.6	26.4	1.2	0.9	2.7	27.0	2.0	27.5	1.4	28.0	0.5	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.2	25.8	25.5	24.2	21.8	18.9	16.7	16.0	16.8	19.4	21.4	23.3	24.8
	DBStd	3.92	1.80	1.83	1.64	1.52	1.76	1.90	1.79	1.83	2.05	2.16	2.04	2.04
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	213	0	0	0	1	14	54	76	55	11	2	0	0
	CDD10.0	4079	489	434	439	356	274	201	185	210	281	353	398	459
	CDD18.3	1252	231	201	181	106	31	6	3	7	42	96	148	201
	CDH23.3	8410	1937	1596	1145	459	105	11	13	59	229	504	869	1483
	CDH26.7	2063	571	469	246	51	4	0	1	7	39	95	175	405
Wind	WSAvg	2.0	2.5	2.4	2.2	1.9	1.7	1.7	1.6	1.7	2.0	2.2	2.4	2.4
Precipitation	PrecAvg	1183	163	138	131	98	89	66	62	40	35	94	118	133
	PrecMax	2194	872	438	480	548	410	647	330	140	121	457	413	410
	PrecMin	608	25	27	5	9	4	2	0	0	0	3	8	38
	PrecStd	350	152	99	107	119	90	115	70	33	30	83	82	74
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	33.8	32.4	29.5	27.1	24.6	24.7	27.3	30.4	31.5	31.8	34.5
		MCWB	24.3	23.9	23.6	21.0	18.3	17.5	15.7	16.3	17.4	19.2	21.6	21.6
	2%	DB	31.9	31.8	30.4	28.1	25.6	23.1	23.0	24.8	27.4	29.0	29.8	31.7
		MCWB	23.9	23.8	22.7	20.3	17.8	16.5	15.4	15.7	17.7	19.5	21.8	22.5
	5%	DB	30.6	30.6	29.1	27.0	24.5	22.0	21.8	23.2	25.7	27.4	28.6	30.1
		MCWB	23.3	23.2	22.1	19.8	17.2	15.8	14.8	15.3	17.4	19.4	21.1	22.4
	10%	DB	29.6	29.5	28.0	26.0	23.3	20.9	20.6	21.9	24.4	26.1	27.4	28.8
		MCWB	22.8	22.6	21.4	19.5	16.8	15.5	14.3	14.6	16.9	18.9	20.6	22.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.0	26.1	24.7	23.0	20.9	19.4	19.3	19.5	21.0	22.7	24.1	25.1
		MCDB	31.1	31.6	29.0	26.6	24.2	22.0	22.3	23.7	26.0	28.0	29.5	31.0
	2%	WB	25.1	25.1	24.0	21.9	19.5	18.2	17.9	18.2	19.9	21.7	23.0	24.2
		MCDB	29.8	29.9	28.1	25.8	23.5	21.0	20.4	22.1	24.4	26.4	27.5	29.2
	5%	WB	24.5	24.3	23.4	21.1	18.7	17.5	16.6	17.0	19.1	20.9	22.2	23.5
		MCDB	28.8	28.7	27.3	25.0	22.6	20.4	19.8	21.0	23.6	25.2	26.8	28.1
	10%	WB	23.8	23.6	22.7	20.3	18.0	16.6	15.6	16.1	18.3	20.1	21.6	22.9
		MCDB	27.9	27.8	26.6	24.4	21.6	19.6	19.1	20.1	22.6	24.5	26.1	27.2
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.4	7.6	8.5	9.6	8.9	10.2	11.1	10.5	9.0	7.8	7.6
		MCDBR	8.4	8.9	9.1	9.9	10.9	10.1	11.7	12.9	12.4	11.0	9.1	9.2
		MCWBR	3.1	3.1	3.3	3.8	4.6	4.9	5.5	5.9	5.2	4.6	3.8	3.8
	5% WB	MCDBR	7.7	8.2	7.7	8.3	8.6	7.7	8.8	10.9	10.2	9.4	8.0	8.2
		MCWBR	3.2	3.3	3.3	3.6	4.0	4.4	4.9	5.9	4.7	4.5	3.7	3.7
Clear-Sky Solar Irradiance	taub	0.391	0.380	0.359	0.340	0.320	0.313	0.303	0.316	0.359	0.379	0.383	0.396	
	taud	2.495	2.535	2.594	2.626	2.630	2.644	2.659	2.598	2.475	2.452	2.477	2.465	
	Ebn at Noon	951	946	936	909	885	869	896	920	921	936	953	949	
	Edh at Noon	116	108	97	86	77	73	74	86	107	117	117	120	
All-Sky Solar Radiation	RadAvg	6.51	5.98	5.16	4.44	3.69	3.05	3.55	4.44	5.46	6.06	6.62	6.55	
	RadStd	0.53	0.50	0.31	0.23	0.19	0.22	0.28	0.33	0.43	0.54	0.56	0.69	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	+0.94	N/A	N/A	N/A	N/A	N/A	-70	+203	N/A	(46)
(47) Regional (28 neighbors)		+0.41	+0.52	N/A	N/A	N/A	N/A	N/A	-67	+186	+112	(47)

Nomenclature: See separate page