

GLEN INNES, Australia

WMO: 945880

Lat: 29.6781S

Lon: 151.6939E

Elev: 3428

StdP: 12.96

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.8	24.6	15.3	13.6	37.3	18.9	16.1	35.9	27.8	49.0	25.6	48.3	4.7	100	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.2	86.4	63.7	83.2	63.0	80.3	62.4	68.2	78.7	66.8	76.3	65.5	74.4	11.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.4	106.6	71.2	63.9	101.3	69.6	62.7	96.8	68.7	34.5	78.8	33.3	76.6	32.3	74.3	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	22.2	19.7	15.6	91.0	2.6	3.5	13.7	93.6	12.2	95.6	10.7	97.6	8.8	100.2
			15.0	70.8	2.6	1.5	13.1	71.8	11.6	72.7	10.1	73.5	8.2	74.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.2	66.9	65.9	62.9	56.4	48.6	44.4	42.8	44.2	50.5	55.9	60.4	64.4	(6)
	DBStd	9.75	4.33	4.35	3.96	4.37	4.89	4.79	4.43	4.40	4.82	5.07	5.22	4.79	(7)
	HDD50	745	0	0	0	6	84	177	228	188	50	10	2	0	(8)
	HDD65	3814	29	36	87	257	507	619	688	646	436	284	156	69	(9)
	CDD50	2646	525	446	401	199	41	8	5	7	64	192	313	445	(10)
	CDD65	241	89	62	23	0	0	0	0	0	0	1	16	50	(11)
	CDH74	2817	909	593	260	22	0	0	0	1	16	103	304	609	(12)
	CDH80	689	255	172	40	1	0	0	0	0	0	12	64	145	(13)
(14) Wind	WSAvg	9.7	10.5	11.1	10.4	9.5	8.5	9.3	9.0	9.3	9.5	9.6	9.6	9.9	(14)
(15) Precipitation	PrecAvg	35.9	4.8	3.5	2.8	1.9	2.4	1.7	2.4	2.2	2.4	3.0	3.6	4.8	(15)
	PrecMax	46.5	11.1	9.1	8.9	8.7	8.7	5.7	6.3	5.0	11.0	9.2	7.1	8.9	(16)
	PrecMin	22.1	0.5	0.6	0.0	0.1	0.2	0.0	0.1	0.1	0.1	1.1	0.6	0.7	(17)
	PrecStd	6.0	2.4	2.0	2.2	2.0	2.0	1.2	1.5	1.3	1.9	1.8	1.7	2.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.8	90.3	84.6	77.1	69.2	62.4	62.7	67.9	76.5	81.0	86.0	88.5	(19)
		MCWB	64.8	64.7	61.6	58.6	54.5	51.1	49.3	50.8	55.6	56.7	62.4	63.3	(20)
	2%	DB	86.0	85.3	79.9	73.1	66.1	59.6	59.3	63.2	72.0	76.5	81.3	84.0	(21)
		MCWB	64.3	64.6	61.8	57.3	52.5	49.8	48.1	48.5	53.8	56.4	60.2	62.7	(22)
	5%	DB	82.7	80.9	76.5	70.2	63.3	57.6	56.8	60.1	68.0	73.5	77.3	80.4	(23)
		MCWB	63.9	63.9	61.6	56.6	51.3	49.0	47.6	47.2	52.4	56.3	59.8	62.2	(24)
	10%	DB	79.3	77.1	73.8	67.3	60.6	55.2	54.4	57.0	64.3	70.0	73.5	77.1	(25)
		MCWB	63.7	63.6	61.0	56.1	50.6	48.3	46.2	46.1	51.0	55.5	58.9	61.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.1	70.7	66.7	62.6	58.6	55.4	56.0	55.3	58.4	63.0	66.8	68.3	(27)
		MCDB	80.8	82.3	74.4	70.3	64.8	58.0	58.6	62.3	69.3	70.5	78.7	79.9	(28)
	2%	WB	68.3	68.2	65.3	60.4	55.8	53.1	52.6	52.0	56.6	60.4	64.3	66.5	(29)
		MCDB	79.0	78.0	72.5	66.9	60.9	56.3	56.1	57.7	65.7	69.2	74.9	77.1	(30)
	5%	WB	66.9	66.4	63.9	58.8	54.1	51.2	49.6	50.0	54.8	58.7	62.6	65.0	(31)
		MCDB	76.8	74.9	71.5	65.5	59.1	55.0	53.4	56.0	63.1	68.2	71.9	74.8	(32)
	10%	WB	65.6	64.8	62.6	57.4	52.5	49.6	47.6	48.0	53.1	57.1	61.0	63.5	(33)
		MCDB	74.5	73.0	70.3	64.8	58.0	53.6	52.3	54.3	61.3	66.5	69.4	72.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.2	20.4	20.9	22.1	24.3	21.6	23.5	26.0	26.3	25.3	22.9	22.8	(35)
		MCDBR	29.3	27.9	26.5	26.6	28.3	25.7	28.3	32.1	33.6	32.8	30.5	29.3	(36)
	5% WB	MCWBR	10.9	10.8	11.3	12.4	15.9	16.5	17.5	19.0	17.5	15.3	13.2	11.8	(37)
		MCWBR	22.8	22.3	20.5	21.2	20.3	17.8	18.8	22.9	25.3	24.6	23.0	23.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.328	0.323	0.301	0.285	0.267	0.261	0.257	0.268	0.302	0.323	0.337	0.332	(40)
		taud	2.592	2.621	2.694	2.696	2.701	2.720	2.711	2.649	2.530	2.500	2.508	2.555	(41)
	Ebn at Noon		321	317	315	305	298	293	298	307	309	313	316	321	(42)
		Edh at Noon	33	31	28	25	22	20	22	25	32	35	36	35	(43)
(44) All-Sky Solar Radiation	RadAvg		2198	1975	1692	1434	1154	951	1071	1369	1732	1970	2100	2190	(44)
	RadStd		162	172	118	73	73	76	80	104	141	174	213	192	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.99	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	+0.86	N/A	N/A	+1.60	N/A	N/A	N/A	N/A	+367	+216

Nomenclature: See separate page