

GLEN INNES, Australia

WMO: 945880

Lat: 29.6781S

Lon: 151.6939E

Elev: 1045

StdP: 89.39

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-5.6	-4.1	-9.3	1.9	2.9	-7.3	2.3	2.2	12.4	9.4	11.4	9.0	2.1	100	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	30.2	17.6	28.4	17.2	26.8	16.9	20.1	25.9	19.3	24.6	18.6	23.6	5.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	15.2	21.8	17.7	14.5	20.9	17.1	13.8	20.4	62.5	26.0	59.6	24.8	57.3	23.5	23.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.3	9.9	8.8	-9.1	32.8	1.5	2.0	-10.1	34.2	-11.0	35.3	-11.8	36.4	-12.9	37.9		
			-9.4	21.5	1.5	0.8	-10.5	22.1	-11.3	22.6	-12.2	23.1	-13.2	23.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	19.4	18.9	17.2	13.6	9.2	6.9	6.0	6.8	10.3	13.3	15.8	18.0
	DBStd	5.42	2.40	2.41	2.20	2.43	2.71	2.66	2.46	2.45	2.68	2.82	2.90	2.66
	HDD10.0	414	0	0	0	3	47	98	127	104	28	6	1	0
	HDD18.3	2119	16	20	48	143	282	344	382	359	242	158	87	38
	CDD10.0	1470	292	248	223	111	23	4	3	4	36	107	174	247
	CDD18.3	134	49	34	13	0	0	0	0	0	0	1	9	28
	CDH23.3	1565	505	329	144	12	0	0	0	1	9	57	169	338
CDH26.7	383	142	96	22	1	0	0	0	0	0	7	36	81	
Wind	WSAvg	4.3	4.7	4.9	4.7	4.2	3.8	4.1	4.0	4.2	4.2	4.3	4.3	4.4
Precipitation	PrecAvg	911	123	89	71	49	62	44	60	56	62	77	92	123
	PrecMax	1181	283	230	227	220	220	144	159	127	280	234	181	225
	PrecMin	562	13	15	0	2	6	0	3	3	3	28	14	19
	PrecStd	152	62	50	57	51	51	31	37	32	48	46	42	58
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	32.4	29.2	25.1	20.7	16.9	17.1	19.9	24.7	27.2	30.0	31.4
		MCWB	18.2	18.2	16.4	14.8	12.5	10.6	9.6	10.4	13.1	13.7	16.9	17.4
	2%	DB	30.0	29.6	26.6	22.8	18.9	15.3	15.1	17.4	22.2	24.7	27.4	28.9
		MCWB	18.0	18.1	16.6	14.0	11.4	9.9	9.0	9.2	12.1	13.5	15.7	17.0
	5%	DB	28.2	27.1	24.7	21.2	17.4	14.2	13.8	15.6	20.0	23.1	25.2	26.9
		MCWB	17.7	17.7	16.4	13.6	10.7	9.5	8.7	8.4	11.3	13.5	15.4	16.8
	10%	DB	26.3	25.0	23.2	19.6	15.9	12.9	12.5	13.9	17.9	21.1	23.1	25.1
		MCWB	17.6	17.6	16.1	13.4	10.4	9.0	7.9	7.9	10.6	13.1	14.9	16.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	21.5	19.3	17.0	14.8	13.0	13.3	12.9	14.7	17.2	19.3	20.1
		MCDB	27.1	27.9	23.5	21.3	18.2	14.4	14.8	16.8	20.7	21.4	25.9	26.6
	2%	WB	20.2	20.1	18.5	15.8	13.2	11.7	11.5	11.1	13.6	15.8	17.9	19.2
		MCDB	26.1	25.5	22.5	19.4	16.1	13.5	13.4	14.3	18.7	20.7	23.8	25.0
	5%	WB	19.4	19.1	17.7	14.9	12.3	10.7	9.8	10.0	12.6	14.8	17.0	18.3
		MCDB	24.9	23.8	22.0	18.6	15.1	12.8	11.9	13.3	17.3	20.1	22.1	23.8
	10%	WB	18.7	18.2	17.0	14.1	11.4	9.8	8.7	8.9	11.7	14.0	16.1	17.5
		MCDB	23.6	22.8	21.3	18.2	14.4	12.0	11.3	12.4	16.3	19.2	20.8	22.4
Mean Daily Temperature Range	5% DB	MDBR	12.3	11.4	11.6	12.3	13.5	12.0	13.1	14.4	14.6	14.1	12.7	12.7
		MCDBR	16.3	15.5	14.7	14.8	15.7	14.3	15.7	17.8	18.7	18.2	16.9	16.3
		MCWBR	6.0	6.0	6.3	6.9	8.8	9.2	9.7	10.5	9.7	8.5	7.3	6.6
	5% WB	MCDBR	12.7	12.4	11.4	11.8	11.3	9.9	10.5	12.7	14.1	13.6	12.8	13.0
		MCWBR	5.7	5.6	5.6	6.1	6.9	7.0	7.5	8.4	8.2	7.3	6.4	6.3
Clear-Sky Solar Irradiance	taub		0.328	0.323	0.301	0.285	0.267	0.261	0.257	0.268	0.302	0.323	0.337	0.332
	taud		2.592	2.621	2.694	2.696	2.701	2.720	2.711	2.649	2.530	2.500	2.508	2.555
	Ebn at Noon		1013	1000	993	962	938	923	941	967	975	988	997	1011
	Edh at Noon		105	99	87	78	69	64	68	80	100	110	113	109
All-Sky Solar Radiation	RadAvg		6.93	6.23	5.33	4.52	3.64	3.00	3.38	4.32	5.46	6.21	6.62	6.90
	RadStd		0.51	0.54	0.37	0.23	0.23	0.24	0.25	0.33	0.44	0.55	0.67	0.60

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	+0.48	N/A	N/A	+0.89	N/A	N/A	N/A	N/A	+204	+120

Nomenclature: See separate page