

CAPE MORETON LH, Australia

WMO: 945940

Lat: 27.0314S

Lon: 153.4661E

Elev: 331

StdP: 14.52

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	52.6	54.5	32.8	27.6	59.2	35.8	31.2	59.0	41.3	62.9	36.7	63.7	16.2	240	0.682

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.6	83.4	74.5	82.2	74.1	81.1	73.4	77.7	80.4	76.6	79.8	75.6	79.1	13.4	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	141.5	79.4	75.6	135.9	78.9	74.5	130.6	78.3	41.5	80.5	40.4	79.8	39.5	79.2	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
41.2	36.4	32.8	49.1	86.8	1.8	2.4	47.8	88.5	46.8	89.9	45.7	91.3	44.4	93.1		
			42.3	79.1	1.8	1.3	41.0	80.0	39.9	80.8	38.9	81.5	37.6	82.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.1	77.0	77.0	75.6	71.8	67.4	63.4	62.2	63.4	66.9	69.6	72.6	75.1
	DBStd	5.95	2.41	2.41	2.36	2.77	3.20	3.56	3.28	3.16	2.83	2.76	2.55	2.68
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	266	0	0	0	1	14	71	96	67	14	3	0	0
	CDD50	7349	836	756	794	655	539	402	379	417	508	608	678	777
	CDD65	2142	371	336	329	206	89	23	10	19	73	146	228	312
	CDH74	7696	2166	1975	1421	315	26	0	0	2	12	95	424	1260
	CDH80	495	183	165	65	2	0	0	0	0	0	4	6	70
(14) Wind	WSAvg	17.8	19.3	20.2	19.8	18.9	17.0	16.3	15.5	16.0	17.1	17.7	18.0	18.2
(15) Precipitation	PrecAvg	60.3	6.0	5.8	6.4	5.6	6.7	6.1	4.8	3.2	2.0	3.7	4.3	5.3
	PrecMax	96.4	28.3	17.2	15.9	17.2	17.9	23.1	22.4	6.5	6.6	15.2	13.5	14.6
	PrecMin	35.0	1.5	0.9	0.7	0.9	0.8	1.1	0.3	0.1	0.0	0.2	0.6	0.6
	PrecStd	14.3	5.0	4.1	4.4	4.1	4.1	4.3	3.9	1.7	1.7	2.9	2.6	3.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.0	85.2	83.5	80.1	76.5	72.5	70.9	72.6	75.4	78.3	80.7	83.7
		MCWB	75.8	75.3	74.5	70.4	67.2	65.2	63.2	62.9	64.4	67.2	71.1	72.2
	2%	DB	83.3	83.4	81.8	78.3	74.5	71.0	69.5	70.6	73.6	76.2	78.9	81.8
		MCWB	75.1	74.9	73.7	69.9	66.3	64.1	62.7	62.7	64.9	68.4	70.7	73.3
	5%	DB	82.0	82.1	80.5	76.9	73.0	69.9	68.4	69.3	72.3	74.8	77.6	80.4
		MCWB	74.5	74.1	72.9	69.0	65.8	63.3	61.8	61.9	64.5	67.6	69.9	72.7
	10%	DB	80.8	80.8	79.2	75.8	72.0	68.7	67.3	68.2	71.1	73.6	76.4	79.1
		MCWB	73.8	73.5	72.3	68.5	65.1	62.5	60.8	61.4	64.1	67.0	69.4	72.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.1	78.8	78.2	74.3	71.1	68.2	67.8	67.7	70.3	73.3	75.3	77.5
		MCDB	81.5	81.5	80.2	77.3	73.0	70.3	69.2	70.1	72.5	75.1	77.1	80.3
	2%	WB	77.8	77.4	76.5	72.1	69.6	66.4	66.0	65.9	68.7	71.3	73.7	76.1
		MCDB	80.6	80.5	79.3	76.0	72.4	69.1	68.2	68.7	71.2	73.9	76.1	79.2
	5%	WB	76.7	76.3	75.2	70.8	67.9	65.0	63.9	64.5	67.4	70.1	72.6	75.0
		MCDB	79.9	79.8	78.7	75.2	71.7	68.4	67.0	68.1	70.5	73.1	75.5	78.3
	10%	WB	75.5	75.3	74.0	69.8	66.5	63.8	62.2	62.9	66.2	68.8	71.4	74.0
		MCDB	79.2	79.3	77.8	74.6	70.9	67.7	66.3	67.1	69.7	72.1	75.0	77.5
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	6.6	6.5	6.8	7.5	7.6	8.1	8.2	7.6	7.1	7.0	7.0
		MCDBR	7.9	7.9	7.7	7.5	7.9	7.3	7.9	8.5	8.4	8.2	8.0	8.4
	5% WB	MCWBR	4.2	4.1	4.4	4.6	5.0	5.3	6.2	6.3	5.8	5.4	4.5	4.8
		MCWBR	7.3	7.0	7.0	6.7	6.7	6.9	7.2	6.8	7.4	7.1	7.1	7.7
(40) Clear-Sky Solar Irradiance	taub		0.384	0.375	0.355	0.338	0.319	0.313	0.303	0.316	0.352	0.371	0.372	0.387
		taud	2.538	2.572	2.629	2.658	2.658	2.671	2.685	2.626	2.518	2.495	2.528	2.514
	Ebn at Noon		304	302	298	290	282	277	285	292	295	299	305	304
		Edh at Noon	35	33	30	26	24	23	23	27	33	36	35	36
(44) All-Sky Solar Radiation	RadAvg		2105	1938	1666	1408	1159	964	1124	1407	1742	1945	2143	2120
	RadStd		169	150	107	74	60	68	90	105	127	155	162	221

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	-119	+322	+196

Nomenclature: See separate page